

ELECTRICAL-NATIONAL ELECTRICAL CODE

	yes	no
Have exposed wires, frayed cords, and deteriorated insulation been repaired or replaced?	<input type="checkbox"/>	<input type="checkbox"/>
Are junction boxes, outlets, switches, and fittings covered?	<input type="checkbox"/>	<input type="checkbox"/>
Is all metal fixed electrical equipment grounded?	<input type="checkbox"/>	<input type="checkbox"/>
Are flexible cord and cables fastened so that there is no direct pull on joints or terminal screws?	<input type="checkbox"/>	<input type="checkbox"/>
Are flexible cords and cables never substituted for fixed wiring?	<input type="checkbox"/>	<input type="checkbox"/>
Are flexible cords and cables not attached to building surfaces?	<input type="checkbox"/>	<input type="checkbox"/>
Do flexible cords and cables not run through holes in walls or ceilings or through doorways or windows?	<input type="checkbox"/>	<input type="checkbox"/>
Are flexible cords and cables free from splices or taps?	<input type="checkbox"/>	<input type="checkbox"/>
Does all equipment connected by cord and plug have grounded connections?	<input type="checkbox"/>	<input type="checkbox"/>
Are electrical appliances such as vacuums, coffee machines, vending machines, etc. grounded?	<input type="checkbox"/>	<input type="checkbox"/>
Are all portable electrical hand tools grounded? (doubly insulated tools are acceptable without grounding.)	<input type="checkbox"/>	<input type="checkbox"/>
Are breaker switches identified as to their use?	<input type="checkbox"/>	<input type="checkbox"/>