

ELEVATED SURFACES

	yes	no
Are signs posted, when appropriate, showing the elevated surface load capacity?	<input type="checkbox"/>	<input type="checkbox"/>
Are surfaces elevated more than 30 inches above the floor or ground provided with standard guardrails?	<input type="checkbox"/>	<input type="checkbox"/>
Are all elevated surfaces (beneath which people or machinery could be exposed to falling objects) provided with standard 4-inch toeboards?	<input type="checkbox"/>	<input type="checkbox"/>
Is a permanent means of access and egress provided to elevated storage and work surfaces?	<input type="checkbox"/>	<input type="checkbox"/>
Is required headroom provided where necessary?	<input type="checkbox"/>	<input type="checkbox"/>
Is material on elevated surfaces piled, stacked or racked in a manner to prevent it from tipping, falling, collapsing, rolling, or spreading?	<input type="checkbox"/>	<input type="checkbox"/>
Are dock boards or bridge plates used when transferring materials between docks and trucks or rail cars?	<input type="checkbox"/>	<input type="checkbox"/>