



www.basiclab.com

2218 Railroad Avenue
Redding, California 96001

voice 530.243.7234
fax 530.243.7494

3860 Morrow Lane, Suite F
Chico, California 95928

voice 530.894.8966
fax 530.894.5143

January 12, 2018

Lab ID: 18A0278

RICHARD BEALL
ENTEK CONSULTING GROUP
4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
RE: CHICO STATE LEAD TESTING 17-4612


Dear RICHARD BEALL ,

Enclosed are the analysis results for Work Order number 18A0278. All analyses were performed under strict adherence to our established Quality Assurance Plan. Any abnormalities are listed in the qualifier section of this report.

If you have any questions regarding these results, please feel free to contact us at any time. We appreciate the opportunity to service your environmental testing needs.

Sincerely,


For



Ricky D. Jensen
Laboratory Director

California ELAP Certification Number 1677



www.basiclab.com

2218 Railroad Avenue voice 530.243.7234
Redding, California 96001 fax 530.243.7494

3860 Morrow Lane, Suite F voice 530.894.8966
Chico, California 95928 fax 530.894.5143

Report To: ENTEK CONSULTING GROUP
4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677

Lab No: 18A0278
Reported: 01/12/18
Phone: (916) 632-6800
P.O. #

Attention: RICHARD BEALL
Project: CHICO STATE LEAD TESTING 17-4612

Metals - Total

Analyte	Units	Results	Qualifier	MDL	RL	Method	Analyzed	Prepared	Batch
ESKN-HW-108-001 - Grab	Drinking Water	(18A0278-01)	Sampled:01/05/18 07:15				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0929	
ESKN-HW-108-002 - Grab	Drinking Water	(18A0278-02)	Sampled:01/05/18 07:15				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0929	
ESKN-HW-27-001 - Grab	Drinking Water	(18A0278-03)	Sampled:01/05/18 07:26				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0929	
ESKN-HW-27-002 - Grab	Drinking Water	(18A0278-04)	Sampled:01/05/18 07:26				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0929	
ESKN-HW-58-001 - Grab	Drinking Water	(18A0278-05)	Sampled:01/05/18 07:31				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0929	
ESKN-HW-58-002 - Grab	Drinking Water	(18A0278-06)	Sampled:01/05/18 07:31				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0929	
ESKN-HW-208-001 - Grab	Drinking Water	(18A0278-07)	Sampled:01/05/18 07:36				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0929	
ESKN-HW-208-002 - Grab	Drinking Water	(18A0278-08)	Sampled:01/05/18 07:36				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0929	
MCHD-HW-14-001 - Grab	Drinking Water	(18A0278-09)	Sampled:01/05/18 07:45				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0929	
MCHD-HW-14-002 - Grab	Drinking Water	(18A0278-10)	Sampled:01/05/18 07:45				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0929	
MCHD-039-001 - Grab	Drinking Water	(18A0278-11)	Sampled:01/05/18 07:49				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0929	
MCHD-HW-27-001 - Grab	Drinking Water	(18A0278-12)	Sampled:01/05/18 07:51				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0929	
MCHD-HW-27-002 - Grab	Drinking Water	(18A0278-13)	Sampled:01/05/18 07:51				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0929	
MCHD-HW-47-001 - Grab	Drinking Water	(18A0278-14)	Sampled:01/05/18 07:56				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0929	
MCHD-HW-47-002 - Grab	Drinking Water	(18A0278-15)	Sampled:01/05/18 07:56				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0929	
MCHD-HW-58-001 - Grab	Drinking Water	(18A0278-16)	Sampled:01/05/18 08:00				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0929	
MCHD-HW-58-002 - Grab	Drinking Water	(18A0278-17)	Sampled:01/05/18 08:00				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0929	
KONK-601-001 - Grab	Drinking Water	(18A0278-18)	Sampled:01/05/18 08:10				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0929	
KONK-601-002 - Grab	Drinking Water	(18A0278-19)	Sampled:01/05/18 08:10				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0929	
KONK-501-001 - Grab	Drinking Water	(18A0278-20)	Sampled:01/05/18 08:17				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0929	
KONK-501-002 - Grab	Drinking Water	(18A0278-21)	Sampled:01/05/18 08:17				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0930	
KONK-401-001 - Grab	Drinking Water	(18A0278-22)	Sampled:01/05/18 08:22				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0930	

Approved By

Basic Laboratory Inc
California ELAP Cert #1677 and #2718



www.basiclab.com

2218 Railroad Avenue Redding, California 96001 voice 530.243.7234 fax 530.243.7494

3860 Morrow Lane, Suite F Chico, California 95928 voice 530.894.8966 fax 530.894.5143

Report To: ENTEK CONSULTING GROUP 4200 ROCKLIN ROAD, SUITE 7 ROCKLIN, CA 95677

Attention: RICHARD BEALL

Project: CHICO STATE LEAD TESTING 17-4612

Lab No: 18A0278 Reported: 01/12/18 Phone: (916) 632-6800 P.O. #

Metals - Total

Table with columns: Analyte, Units, Results, Qualifier, MDL, RL, Method, Analyzed, Prepared, Batch. Rows include various sample IDs like KONK-401-002, OCON-HW-136-001, and YOLO-HW-244-003 with corresponding lead levels and sampling details.

Approved By [Signature]

Basic Laboratory Inc California ELAP Cert #1677 and #2718



www.basiclab.com

2218 Railroad Avenue voice 530.243.7234
Redding, California 96001 fax 530.243.7494

3860 Morrow Lane, Suite F voice 530.894.8966
Chico, California 95928 fax 530.894.5143

Report To: ENTEK CONSULTING GROUP
4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677

Lab No: 18A0278
Reported: 01/12/18
Phone: (916) 632-6800
P.O. #

Attention: RICHARD BEALL
Project: CHICO STATE LEAD TESTING 17-4612

Metals - Total

Analyte	Units	Results	Qualifier	MDL	RL	Method	Analyzed	Prepared	Batch
UHOF-SNK-001 - Grab Drinking Water (18A0278-45)			Sampled:01/05/18 10:37				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0931	
UHOF-SNK-002 - Grab Drinking Water (18A0278-46)			Sampled:01/05/18 10:37				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0931	
AGYM-140-002 - Grab Drinking Water (18A0278-47)			Sampled:01/05/18 07:14				Received:01/05/18 12:10		
Lead	ug/l	5.2		5.0	EPA 200.8	01/08/18	01/08/18	B8A0931	
AGYM-140-003 - Grab Drinking Water (18A0278-48)			Sampled:01/05/18 07:15				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0931	
AGYM-140-001 - Grab Drinking Water (18A0278-49)			Sampled:01/05/18 07:19				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0931	
AGYM-140-004 - Grab Drinking Water (18A0278-50)			Sampled:01/05/18 07:23				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0931	
AGYM-140-005 - Grab Drinking Water (18A0278-51)			Sampled:01/05/18 07:24				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0931	
AGYM-000-001 - Grab Drinking Water (18A0278-52)			Sampled:01/05/18 07:32				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0931	
AGYM-000-002 - Grab Drinking Water (18A0278-53)			Sampled:01/05/18 07:32				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0931	
AGYM-000-003 - Grab Drinking Water (18A0278-54)			Sampled:01/05/18 07:34				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0931	
AGYM-128-001 - Grab Drinking Water (18A0278-55)			Sampled:01/05/18 07:38				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0931	
AGYM-128-002 - Grab Drinking Water (18A0278-56)			Sampled:01/05/18 07:39				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0931	
AGYM-128-003 - Grab Drinking Water (18A0278-57)			Sampled:01/05/18 07:40				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0931	
AGYM-128-004 - Grab Drinking Water (18A0278-58)			Sampled:01/05/18 07:48				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0931	
AGYM-128-005 - Grab Drinking Water (18A0278-59)			Sampled:01/05/18 07:49				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0931	
AGYM-117-001 - Grab Drinking Water (18A0278-60)			Sampled:01/05/18 07:52				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0931	
SHUM-HW-100-001 - Grab Drinking Water (18A0278-61)			Sampled:01/05/18 07:57				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/07/18	B8A0932	
SHUM-HW-100-002 - Grab Drinking Water (18A0278-62)			Sampled:01/05/18 07:58				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/07/18	B8A0932	
SHUM-HW-100-003 - Grab Drinking Water (18A0278-63)			Sampled:01/05/18 07:59				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/07/18	B8A0932	
SHC-117-001 - Grab Drinking Water (18A0278-64)			Sampled:01/05/18 08:11				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/07/18	B8A0932	
SHC-117-002 - Grab Drinking Water (18A0278-65)			Sampled:01/05/18 08:12				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/07/18	B8A0932	
SHC-148-001 - Grab Drinking Water (18A0278-66)			Sampled:01/05/18 08:16				Received:01/05/18 12:10		
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/07/18	B8A0932	

Approved By

Basic Laboratory Inc
California ELAP Cert #1677 and #2718



www.basiclab.com

2218 Railroad Avenue voice 530.243.7234
Redding, California 96001 fax 530.243.7494

3860 Morrow Lane, Suite F voice 530.894.8966
Chico, California 95928 fax 530.894.5143

Report To: ENTEK CONSULTING GROUP
4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677

Lab No: 18A0278
Reported: 01/12/18
Phone: (916) 632-6800
P.O. #

Attention: RICHARD BEALL
Project: CHICO STATE LEAD TESTING 17-4612

Metals - Total

Analyte	Units	Results	Qualifier	MDL	RL	Method	Analyzed	Prepared	Batch
SHC-HW-137-001 - Grab	Drinking Water	(18A0278-67)	Sampled:01/05/18 08:20	Received:01/05/18 12:10					
Lead	ug/l	6.0		5.0	EPA 200.8	01/08/18	01/07/18	B8A0932	
SHC-HW-256-001 - Grab	Drinking Water	(18A0278-68)	Sampled:01/05/18 08:24	Received:01/05/18 12:10					
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/07/18	B8A0932	
SHC-HW-240-001 - Grab	Drinking Water	(18A0278-69)	Sampled:01/05/18 08:28	Received:01/05/18 12:10					
Lead	ug/l	30.3		5.0	EPA 200.8	01/08/18	01/07/18	B8A0932	
SHC-HW-220-001 - Grab	Drinking Water	(18A0278-70)	Sampled:01/05/18 08:37	Received:01/05/18 12:10					
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/07/18	B8A0932	
SHUM-102-001 - Grab	Drinking Water	(18A0278-71)	Sampled:01/05/18 08:43	Received:01/05/18 12:10					
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/07/18	B8A0932	
SHUM-102-002 - Grab	Drinking Water	(18A0278-72)	Sampled:01/05/18 08:46	Received:01/05/18 12:10					
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/07/18	B8A0932	
SHUM-HW-166-001 - Grab	Drinking Water	(18A0278-73)	Sampled:01/05/18 08:59	Received:01/05/18 12:10					
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/07/18	B8A0932	
AGYM-141-001 - Grab	Drinking Water	(18A0278-74)	Sampled:01/05/18 09:01	Received:01/05/18 12:10					
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/07/18	B8A0932	
AGYM-141-002 - Grab	Drinking Water	(18A0278-75)	Sampled:01/05/18 09:02	Received:01/05/18 12:10					
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/07/18	B8A0932	
AGYM-142-001 - Grab	Drinking Water	(18A0278-76)	Sampled:01/05/18 09:20	Received:01/05/18 12:10					
Lead	ug/l	5.3		5.0	EPA 200.8	01/08/18	01/07/18	B8A0932	
AGYM-143-001 - Grab	Drinking Water	(18A0278-77)	Sampled:01/05/18 09:28	Received:01/05/18 12:10					
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/07/18	B8A0932	
AGYM-144-001 - Grab	Drinking Water	(18A0278-78)	Sampled:01/05/18 09:32	Received:01/05/18 12:10					
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/07/18	B8A0932	
AGYM-144-002 - Grab	Drinking Water	(18A0278-79)	Sampled:01/05/18 09:36	Received:01/05/18 12:10					
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/07/18	B8A0932	
AGYM-144-003 - Grab	Drinking Water	(18A0278-80)	Sampled:01/05/18 09:40	Received:01/05/18 12:10					
Lead	ug/l	5.9		5.0	EPA 200.8	01/08/18	01/07/18	B8A0932	
AGYM-206-001 - Grab	Drinking Water	(18A0278-81)	Sampled:01/05/18 09:47	Received:01/05/18 12:10					
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0933	
AGYM-202-001 - Grab	Drinking Water	(18A0278-82)	Sampled:01/05/18 09:56	Received:01/05/18 12:10					
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0933	
AGYM-203-001 - Grab	Drinking Water	(18A0278-83)	Sampled:01/05/18 10:07	Received:01/05/18 12:10					
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0933	
AGYM-201-001 - Grab	Drinking Water	(18A0278-84)	Sampled:01/05/18 10:13	Received:01/05/18 12:10					
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0933	
LANG-HW-122-001 - Grab	Drinking Water	(18A0278-85)	Sampled:01/05/18 10:35	Received:01/05/18 12:10					
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0933	
LANG-HW-122-002 - Grab	Drinking Water	(18A0278-86)	Sampled:01/05/18 10:36	Received:01/05/18 12:10					
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0933	
LANG-HW-103-001 - Grab	Drinking Water	(18A0278-87)	Sampled:01/05/18 10:40	Received:01/05/18 12:10					
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0933	
LANG-HW-103-002 - Grab	Drinking Water	(18A0278-88)	Sampled:01/05/18 10:41	Received:01/05/18 12:10					
Lead	ug/l	ND		5.0	EPA 200.8	01/08/18	01/08/18	B8A0933	

Approved By

Basic Laboratory Inc
California ELAP Cert #1677 and #2718



www.basiclab.com

2218 Railroad Avenue voice 530.243.7234
Redding, California 96001 fax 530.243.7494

3860 Morrow Lane, Suite F voice 530.894.8966
Chico, California 95928 fax 530.894.5143

Report To: ENTEK CONSULTING GROUP
4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677

Attention: RICHARD BEALL
Project: CHICO STATE LEAD TESTING 17-4612

Lab No: 18A0278
Reported: 01/12/18
Phone: (916) 632-6800
P.O. #

Metals - Total

Analyte	Units	Results	Qualifier	MDL	RL	Method	Analyzed	Prepared	Batch
LANG-HW-205-001 - Grab Drinking Water (18A0278-89) Sampled:01/05/18 10:52 Received:01/05/18 12:10									
Lead	ug/l	6.1			5.0	EPA 200.8	01/08/18	01/08/18	B8A0933

Notes and Definitions

- DET Analyte DETECTED
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- dry Sample results reported on a dry weight basis
- RPD Relative Percent Difference
- < Less than reporting limit
- ≤ Less than or equal to reporting limit
- > Greater than reporting limit
- ≥ Greater than or equal to reporting limit
- MDL Method Detection Limit
- RL/ML Minimum Level of Quantitation
- MCL/AL Maximum Contaminant Level/Action Level
- mg/kg Results reported as wet weight
- TTLC Total Threshold Limit Concentration
- STLC Soluble Threshold Limit Concentration
- TCLP Toxicity Characteristic Leachate Procedure
- Note 1 Received Temperature - according to EPA guidelines, samples for most chemistry methods should be held at ≤6 degrees C after collection, including during transportation, unless the time from sampling to delivery is <2 hours. Regulating agencies may invalidate results if temperature requirements are not met.
- Note 2 According to 40 CFR Part 136 Table II, the following tests should be analyzed in the field within 15 minutes of sampling: pH, chlorine, dissolved oxygen, and sulfite.



Approved By

Basic Laboratory Inc
California ELAP Cert #1677 and #2718



18A0278

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1/15/18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Rick Beall

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
ESKN-HW-27-002 Sample Number Date Initials 24 HR Time COC	Building: <u>Esken Hall</u> Outlet: <u>BS</u>
	Floor: <u>1st</u> Manufacturer: <u>Fisher</u>
	Location: <u>Hall by Room 27</u> Filter: Aerator:
	Description/Observation/Comments: <u>15.6^c</u>
ESKN-HW-58-001 Sample Number Date Initials 24 HR Time COC	Building: <u>Esken Hall</u> Outlet: <u>WC</u>
	Floor: <u>2nd</u> Manufacturer: <u>ElKay</u>
	Location: <u>Hall by Room 58</u> Filter: Aerator:
	Description/Observation/Comments: <u>16.3</u>
ESKN-HW-58-002 Sample Number Date Initials 24 HR Time COC	Building: <u>Esken Hall</u> Outlet: <u>BS</u>
	Floor: <u>2nd</u> Manufacturer: <u>Fisher</u>
	Location: <u>Hall by Room 58</u> Filter: Aerator:
	Description/Observation/Comments: <u>16.6</u>

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: Rick Beall Date: 1/15/18 Time: 1210 AM/PM

Received by: Byron Egan Date: 1/15/18 Time: 1210 AM/PM

Received by Lab: TLLW 1-5-18 12:44 1543 1448



18A0278

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
 ROCKLIN, CA 95677
 (916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 / 5 / 18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
 Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Rick Beall

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
 Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, metzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
ESKN-HW-208-001 Sample Number <u>ups</u> Initials <u>15/18</u> Date <u>0736</u> 24 HR Time COC	Building: <u>EsKen</u> Floor: <u>2nd</u> Location: <u>Hall by Room 208</u> Description/Observation/Comments: <u>14.8°</u> Outlet: <u>WC</u> Manufacturer: <u>Elkay</u> Filter: Aerator:
ESKN-HW-208-002 Sample Number <u>ups</u> Initials <u>1-5-18</u> Date <u>0736</u> 24 HR Time COC	Building: <u>EsKen</u> Floor: <u>2nd</u> Location: <u>Hall by Room 208</u> Description/Observation/Comments: <u>16.2°</u> Outlet: <u>BS</u> Manufacturer: <u>Fisher</u> Filter: Aerator:
MCHD-HW-14-001 Sample Number <u>ups</u> Initials <u>1-5-18</u> Date <u>0745</u> 24 HR Time COC	Building: <u>Mechoopda</u> Floor: <u>1st</u> Location: <u>Hall by Room 14</u> Description/Observation/Comments: <u>15.1°</u> Outlet: <u>WC</u> Manufacturer: <u>Elkay</u> Filter: Aerator:

Z:\Clients\Chico State\17-4612 Campus Wide Water Testing - Lead\Water COC & Forms\Water Request Rick.wpd

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: Rick Beall Date: 1 / 5 / 18 Time: 1210 AM/PM

Received by: Byron Liu Date: 1 / 5 / 18 Time: 1210 AM/PM
1448
1-5-18
1448-1543

100012040405



18A0278

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 15 18

Lab: Basic Laboratory, Inc. Basic Laboratory, Inc.
2218 Railroad Avenue 3860 Morrow Lane, # F
Redding, CA 96001 Chico, CA 95928

Job Number: 17-4612

Collected by: Rick Beall

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information	
MCHD-HW-14-002 Sample Number <u>ups</u> Initials Date <u>1-5-18</u> 24 HR Time <u>0745</u> COC	Building: <u>Mechoopda</u>	*Outlet <u>BS</u>
	Floor: <u>1st</u>	Manufacturer: <u>Fisher</u>
	Location: <u>Hall by Room 14</u>	Filter: Aerator:
	Description/Observation/Comments: <u>15.1</u>	
MCHD-039-001 Sample Number <u>ups</u> Initials Date <u>1-5-18</u> 24 HR Time <u>0749</u> COC	Building: <u>Mechoopda</u>	*Outlet <u>KF</u>
	Floor: <u>1st</u>	Manufacturer: <u>Glacier Bay</u>
	Location: <u>Kitchen (Room 39)</u>	Filter: Aerator:
	Description/Observation/Comments: <u>15.6°</u>	
MCHD-HW-27-001 Sample Number <u>ups</u> Initials Date <u>1-5-18</u> 24 HR Time <u>0751</u> COC	Building: <u>Mechoopda</u>	*Outlet <u>WC</u>
	Floor: <u>1st</u>	Manufacturer: <u>Elkay</u>
	Location: <u>Hall by Room 27</u>	Filter: Aerator:
	Description/Observation/Comments: <u>16.1°</u>	

-10

-11

-12

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
CM = Coffee Machine GF = Glass Filler

Delivered by: Rick Beall Date: 1 15 18 Time: 1210 AM/PM

Received by: Byron Smith Date: 1 15 18 Time: 1210 AM/PM

Received By Lab: TW 1-5-18 TW1448 1543 1448



18A0278

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1/5/18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Rick Beall

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information	
MCHD-HW-27-002 <u>1-5-18</u> Sample Number Date <u>WPS</u> <u>0751</u> Initials 24 HR Time COC	Building: <u>Mechoopda</u>	*Outlet <u>BS</u>
	Floor: <u>1st</u>	Manufacturer: <u>Fisher</u>
	Location: <u>Hall by Room 27</u>	Filter: Aerator:
	Description/Observation/Comments: <u>15.4</u>	
MCHD-HW-47-001 <u>1-5-18</u> Sample Number Date <u>WPS</u> <u>0756</u> Initials 24 HR Time COC	Building: <u>Mechoopda</u>	*Outlet <u>WC</u>
	Floor: <u>2nd</u>	Manufacturer: <u>EIKay</u>
	Location: <u>Hall by Room 47</u>	Filter: Aerator:
	Description/Observation/Comments: <u>15.6</u>	
MCHD-HW-47-002 <u>1-5-18</u> Sample Number Date <u>WPS</u> <u>0756</u> Initials 24 HR Time COC	Building: <u>Mechoopda</u>	*Outlet <u>BS</u>
	Floor: <u>2nd</u>	Manufacturer: <u>Fisher</u>
	Location: <u>Hall by Room 47</u>	Filter: Aerator:
	Description/Observation/Comments: <u>16.1</u>	

-13

-14

-15

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: Rick Beall Date: 1/5/18 Time: 1210 AM/PM

Received by: Byron E... Date: 1/5/18 Time: 1210 AM/PM

Received By Lab: TLW 1-5-18 1210 1448



18A0278

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 15 18

Lab: Basic Laboratory, Inc. Basic Laboratory, Inc.
2218 Railroad Avenue 3860 Morrow Lane, # F
Redding, CA 96001 Chico, CA 95928

Job Number: 17-4612

Collected by: Rick Beall

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample		Information	
MCHD-HW-58-001 Sample Number <u>ups</u> Initials	<u>1-5-18</u> Date <u>0800</u> 24 HR Time COC	Building: <u>Mechoopda</u>	*Outlet <u>WC</u>
		Floor: <u>2nd</u>	Manufacturer: <u>Elkay</u>
		Location: <u>Hall by Room 58</u>	Filter: Aerator:
		Description/Observation/Comments: <u>16.3</u>	
MCHD-HW-58-002 Sample Number <u>ups</u> Initials	<u>1-5-18</u> Date <u>0800</u> 24 HR Time COC	Building: <u>Mechoopda</u>	*Outlet <u>BS</u>
		Floor: <u>2nd</u>	Manufacturer: <u>Fisher</u>
		Location: <u>Hall by Room 58</u>	Filter: Aerator:
		Description/Observation/Comments: <u>16.3°</u>	
KONK-101-001 Sample Number <u>ups</u> Initials	<u>1/5/18</u> Date <u>0810</u> 24 HR Time COC	Building: <u>KonKow Hall-6</u>	*Outlet <u>KF</u>
		Floor: <u>2nd</u>	Manufacturer: <u>Unknown</u>
		Location: <u>Kitchen Island</u>	Filter: Aerator:
		Description/Observation/Comments: <u>15.9</u>	

-16

-17

-18

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: Rick Beall Date: 1 15 18 Time: 1210 AM/PM

Received by: Byron Em Date: 1 15 18 Time: 1210 AM/PM

Received By Lab: TW 1-5-18 1210 AM/PM 1448 1543 1448



18A0278

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
 ROCKLIN, CA 95677
 (916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1/5/18

Lab: Basic Laboratory, Inc. Basic Laboratory, Inc.
 2218 Railroad Avenue 3860 Morrow Lane, # F
 Redding, CA 96001 Chico, CA 95928

Job Number: 17-4612

Collected by: Rick Beall

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
 Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, metzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
-601- KONK- 101 -002 Sample Number <u>URS</u> Initials <u>1-5-18</u> Date <u>0810</u> 24 HR Time COC	Building: <u>KonKow - 6</u> Outlet <u>KF</u>
	Floor: <u>2nd</u> Manufacturer: <u>Unknown</u>
	Location: <u>Kitchen - Island</u> Filter: <u>Aerator</u>
	Description/Observation/Comments: <u>16.2^c</u>
KONK-501-001 Sample Number <u>URS</u> Initials <u>1-5-18</u> Date <u>0817</u> 24 HR Time COC	Building: <u>KonKow Hall - 5</u> Outlet <u>KF</u>
	Floor: <u>2nd</u> Manufacturer: <u>Unknown</u>
	Location: <u>Kitchen</u> Filter: <u>Aerator</u>
	Description/Observation/Comments: <u>16.0^c</u>
KONK-501-002 Sample Number <u>URS</u> Initials <u>1-5-18</u> Date <u>0817</u> 24 HR Time COC	Building: <u>KonKow Hall - 5</u> Outlet <u>KF</u>
	Floor: <u>2nd</u> Manufacturer: <u>Unknown</u>
	Location: <u>Kitchen - Island</u> Filter: <u>Aerator</u>
	Description/Observation/Comments: <u>16.7</u>

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: Rick Beall Date: 1/5/18 Time: 1210 AM/PM

Received by: Byron En Date: 1/5/18 Time: 1210 AM/PM

Received by Lab: TW 1-5-18 1210 AM/PM 1448 1543-1448



18A0278

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 / 5 / 18

Lab: Basic Laboratory, Inc. Basic Laboratory, Inc.
2218 Railroad Avenue 3860 Morrow Lane, # F
Redding, CA 96001 Chico, CA 95928

Job Number: 17-4612

Collected by: Rick Beall

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, mmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample		Information	
KONK-401-001 Sample Number <u>ups</u> Initials	<u>1-5-18</u> Date <u>0822</u> 24 HR Time COC	Building: <u>KonKow Hall - 4</u>	Outlet <u>KF</u>
		Floor: <u>2nd</u>	Manufacturer: <u>Unknown</u>
		Location: <u>Kitchen</u>	Filter: Aerator:
		Description/Observation/Comments: <u>16.8°</u>	
KONK-401-002 Sample Number <u>ups</u> Initials	<u>1-5-18</u> Date <u>0822</u> 24 HR Time COC	Building: <u>KonKow Hall - 4</u>	Outlet <u>KF</u>
		Floor: <u>2nd</u>	Manufacturer: <u>Unknown</u>
		Location: <u>Kitchen - Island</u>	Filter: Aerator:
		Description/Observation/Comments: <u>15.6°</u>	
KONK-301-001 Sample Number <u>ups</u> Initials	<u>1-5-18</u> Date <u>0830</u> 24 HR Time COC	Building: <u>KonKow Hall - 3</u>	Outlet <u>KF</u>
		Floor: <u>2nd</u>	Manufacturer: <u>Unknown</u>
		Location: <u>Kitchen</u>	Filter: Aerator:
		Description/Observation/Comments: <u>16.8°</u>	

-22

-23

-24

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: Rick Beall Date: 1 / 5 / 18 Time: 1210 AM/PM

Received by: Byron Ems Date: 1 / 5 / 18 Time: 1210 AM/PM

Received by Lab: TW 1-5-18 TW 1448 1543
144.8



18A0278

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 15 /18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Rick Beall

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, metzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample		Information	
KONK-301-002 Sample Number <u>ups</u> Initials	<u>1-5-18</u> Date <u>0830</u> 24 HR Time COC	Building: <u>Kon Kow Hall-3</u>	Outlet <u>KF</u>
		Floor: <u>2nd</u>	Manufacturer: <u>Unknown</u>
		Location: <u>Kitchen - Island</u>	Filter: Aerator:
		Description/Observation/Comments: <u>16.9^c</u>	
KONK-201-001 Sample Number <u>mps</u> Initials	<u>1/5/18</u> Date <u>0830</u> 24 HR Time COC	Building: <u>Kon Kow Hall-2</u>	Outlet <u>KF</u>
		Floor: <u>2nd</u>	Manufacturer: <u>Unknown</u>
		Location: <u>Kitchen</u>	Filter: Aerator:
		Description/Observation/Comments: <u>16.1^c</u>	
KONK-201-002 Sample Number <u>ups</u> Initials	<u>1/5/18</u> Date <u>0830</u> 24 HR Time COC	Building: <u>Kon Kow Hall-2</u>	Outlet <u>KF</u>
		Floor: <u>2nd</u>	Manufacturer: <u>Unknown</u>
		Location: <u>Kitchen - Island</u>	Filter: Aerator:
		Description/Observation/Comments: <u>16.8^c</u>	

-25

-26

-27

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: R. Beall Date: 1 15 18 Time: 1210 AM/PM

Received by: Byron Lewis Date: 1 15 18 Time: 1210 AM/PM

Received By Lab: TW 1-5-18 TW 1448-1543 1448



18A0278

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
 ROCKLIN, CA 95677
 (916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 15 18 Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001 Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612 Collected by: Rick Beall

Client Name: California State University, Chico Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead Chico, California ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample		Information	
-101- KONK- 601 -001 Sample Number	<u>1-5-18</u> Date	Building: <u>Kon Kow Hall - 1</u>	Outlet <u>KF</u>
		Floor: <u>2nd</u>	Manufacturer: <u>Unknown</u>
<u>YRS</u> Initials	<u>0843</u> 24 HR Time	Location: <u>Kitchen</u>	Filter: Aerator:
		Description/Observation/Comments: <u>17.3</u>	
-101- KONK- 601 -002 Sample Number	<u>1-5-18</u> Date	Building: <u>Kon Kow Hall - 1</u>	Outlet <u>KF</u>
		Floor: <u>2nd</u>	Manufacturer: <u>Unknown</u>
<u>YRS</u> Initials	<u>0843</u> 24 HR Time	Location: <u>Kitchen Island</u>	Filter: Aerator:
		Description/Observation/Comments: <u>16.2</u>	
OCON-HW-136-001 Sample Number	<u>1-5-18</u> Date	Building: <u>O'Connell Tech Center</u>	Outlet <u>WC</u>
		Floor: <u>Hall by Mens Restroom</u>	Manufacturer: <u>ElKay</u>
<u>YRS</u> Initials	<u>0915</u> 24 HR Time	Location: <u>1st</u>	Filter: Aerator:
		Description/Observation/Comments: <u>16.6°</u>	

-28

-29

-30

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: Rick Beall Date: 1 15 18 Time: 1210 AM/PM

Received by: Bryan Smith Date: 1 15 18 Time: 1210 AM/PM

Received By Lab: TW 1448-1543 1/15/18



18A0278

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 / 5 / 18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Rick Beall

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample		Information	
OCON-HW-123-001	<u>1-5-18</u>	Building: <u>O'Connell Tech Center</u>	*Outlet <u>WC</u>
Sample Number	Date	Floor: <u>1st</u>	Manufacturer: <u>El Kay</u>
<u>MPS</u>	<u>0921</u>	Location: <u>Hall by 123</u>	Filter: Aerator:
Initials	24 HR Time COC	Description/Observation/Comments: <u>10.9°</u>	
OCON-HW-123-002		Building: <u>O'Connell Tech Center</u>	*Outlet <u>BS</u>
Sample Number	Date	Floor: <u>1st</u>	Manufacturer: <u>El Kay</u>
<u>MPS</u>	<u>0921</u>	Location: <u>Hall by 123</u>	Filter: Aerator:
Initials	24 HR Time COC	Description/Observation/Comments: <u>10.9°</u> <u>12.2</u>	
OCON-HW-254-001		Building: <u>O'Connell Tech Center</u>	*Outlet <u>WC</u>
Sample Number	Date	Floor: <u>2nd</u>	Manufacturer: <u>Haws</u>
<u>MPS</u>	<u>0928</u>	Location: <u>Hall by Room 254</u>	Filter: Aerator:
Initials	24 HR Time COC	Description/Observation/Comments: <u>15.1°</u>	

-31

-32

-33

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: Rick Beall Date: 1 / 5 / 18 Time: 12:10 AM/PM

Received by: Byron Eric Date: 1 / 5 / 18 Time: 12:10 AM/PM

Received By Lab: TW 1-5-18 1448 TW+448+1543



18A278

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1/5/18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Rick Beall

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, metzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
OCON-HW-235-001 Sample Number <u>1/5/18</u> Date <u>MB</u> Initials <u>0932</u> 24 HR Time COC	Building: <u>O'Connell Tech Center</u> *Outlet <u>WC</u>
	Floor: <u>2nd</u> Manufacturer: <u>Elkay</u>
	Location: <u>Hall by 235-236</u> Filter: Aerator:
	Description/Observation/Comments: <u>8.3°</u>
OCON-HW-311-001 Sample Number <u>1/5-18</u> Date <u>Yres</u> Initials <u>0938</u> 24 HR Time COC	Building: <u>O'Connell Tech Center</u> *Outlet <u>WC</u>
	Floor: <u>3rd</u> Manufacturer: <u>Haws</u>
	Location: <u>Hall by Room 311</u> Filter: Aerator:
	Description/Observation/Comments: <u>6.9°</u>
OCON-HW-326-001 Sample Number <u>1-5-18</u> Date <u>Yres</u> Initials <u>0942</u> 24 HR Time COC	Building: <u>O'Connell Tech Center</u> *Outlet <u>WC</u>
	Floor: <u>3rd</u> Manufacturer: <u>Haws</u>
	Location: <u>Hall by Rooms 324/327</u> Filter: Aerator:
	Description/Observation/Comments: <u>10.4°</u>

-34

-35

-36

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: Rick Beall Date: 1/5/18 Time: 1210 AM/PM

Received by: Byron Date: 1/5/18 Time: 1210 AM/PM

Retained by Lab: TW 1-5-18 1448 1548



ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
 ROCKLIN, CA 95677
 (916) 632-6800 PHONE (916) 632-6812 FAX

18A0278

Date of Sampling: 1/5/18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
 Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Rick Beall

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
 Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, mmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
OCON-HW-408-001 Sample Number Date <u>UPB</u> <u>0945</u> Initials 24 HR Time COC	Building: <u>O'Connell Tech Center</u> *Outlet <u>WC</u>
	Floor: <u>4th</u> Manufacturer: <u>Elkay</u>
	Location: <u>Hallway by Room 408</u> Filter: Aerator:
	Description/Observation/Comments: <u>9.50</u>
OCON-HW-436-001 Sample Number Date <u>UPB</u> <u>0949</u> Initials 24 HR Time COC	Building: <u>O'Connell Tech Center</u> *Outlet <u>WC</u>
	Floor: <u>4th</u> Manufacturer: <u>Unknown</u>
	Location: <u>Hall by Room 436</u> Filter: Aerator:
	Description/Observation/Comments: <u>8.40</u>
YOLO-HW-109-001 Sample Number Date <u>UPB</u> <u>1003</u> Initials 24 HR Time COC	Building: <u>Yolo Hall</u> *Outlet <u>WC</u>
	Floor: <u>1st</u> Manufacturer: <u>Unknown</u>
	Location: <u>Hall by Room 109A</u> Filter: Aerator:
	Description/Observation/Comments: <u>17.0</u>

37

38

39

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: Rick Beall Date: 1/5/18 Time: 1210 AM/PM

Received by: Brynn Smith Date: 1/5/18 Time: 1210 AM/PM

Invoiced By Lab: TW 1543 1448



ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
 ROCKLIN, CA 95677
 (916) 632-6800 PHONE (916) 632-6812 FAX

18A0278

Date of Sampling: 1 15 18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
 Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Rick Beall

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
 Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
YOLO-HW-109-002 Sample Number Date Initials 24 HR Time COC	Building: <u>Yolo Hall</u> *Outlet <u>WC</u>
	Floor: <u>1st</u> Manufacturer: <u>HAWES</u>
	Location: <u>Hall by Room 109K</u> Filter: Aerator:
	Description/Observation/Comments: <u>9.5°</u>
YOLO-HW-124-001 Sample Number Date Initials 24 HR Time COC	Building: <u>Yolo Hall</u> *Outlet <u>WC</u>
	Floor: <u>1st</u> Manufacturer: <u>Unknown</u>
	Location: <u>Hall by Room 124</u> Filter: Aerator:
	Description/Observation/Comments: <u>7.5</u>
YOLO-HW-244-001 Sample Number Date Initials 24 HR Time COC	Building: <u>Yolo Hall</u> *Outlet <u>WC</u>
	Floor: <u>2nd</u> Manufacturer: <u>Elkay</u>
	Location: <u>Hall by Room 244</u> Filter: Aerator:
	Description/Observation/Comments: <u>12.5</u> <u>Lower water cooler</u> <u>Back flow preventers replaced on day of sampling</u>

-40

-41

-42

Z:\Clients\Chico State\17-4612 Campus Wide Water Testing - Lead\Water COC & Forms\Water Request Rick.wpd

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: Rick Beall Date: 1 15 18 Time: 12:00 AM/PM

Received by: Byron Eric Date: 1 15 18 Time: 12:10 AM/PM

15430448



ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
 ROCKLIN, CA 95677
 (916) 632-6800 PHONE (916) 632-6812 FAX

18A0278

Date of Sampling: 1/5/18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
 Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Rick Beall

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
 Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
YOLO-HW-244-002 Sample Number <u>UPS</u> Initials <u>1-5-18</u> Date <u>1013</u> 24 HR Time COC	Building: <u>Yolo Hall</u> Floor: <u>2nd</u> Location: <u>Hall by Room 244</u> Description/Observation/Comments: <u>Upper water cooler</u> *Outlet <u>WC</u> Manufacturer: <u>ElKay</u> Filter: Aerator:
YOLO-HW-244-003 Sample Number <u>UPS</u> Initials <u>1-5-18</u> Date <u>1016</u> 24 HR Time COC	Building: <u>Yolo Hall</u> Floor: <u>2nd</u> Location: <u>Hall by Room 244</u> Description/Observation/Comments: <u>4.4'</u> *Outlet <u>BS</u> Manufacturer: <u>ElKay</u> Filter: Aerator:
UHOF-SWK-001 Sample Number <u>UPS</u> Initials <u>1-5-18</u> Date <u>1037</u> 24 HR Time COC	Building: <u>UH Admin</u> Floor: <u>1st</u> Location: <u>Kitchen</u> Description/Observation/Comments: <u>Main Faucet</u> *Outlet <u>KF</u> Manufacturer: <u>Delta</u> Filter: Aerator:

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: Rick Beall Date: 1/5/18 Time: 1210 AM/PM

Received by: Byron Sun Date: 1/5/18 Time: 1210 AM/PM

Received by: TW 1543 1448



ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
 ROCKLIN, CA 95677
 (916) 632-6800 PHONE (916) 632-6812 FAX

18A0278

Date of Sampling: 1 15 18

Lab: Basic Laboratory, Inc. Basic Laboratory, Inc.
 2218 Railroad Avenue 3860 Morrow Lane, # F
 Redding, CA 96001 Chico, CA 95928

Job Number: 17-4612

Collected by: Rick Beall

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
 Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information	
<u>UHQF-SUK-002</u> Sample Number <u>MS</u> Initials <u>1-5-18</u> Date <u>1037</u> 24 HR Time COC	Building: <u>UH Admin</u>	*Outlet <u>KF</u>
	Floor: <u>1st</u>	Manufacturer: <u>Unknown</u>
	Location: <u>Kitchen</u>	Filter: <u>yes</u> Aerator:
	Description/Observation/Comments: <u>Secondary faucet with filter 6.9°</u>	
	Building:	*Outlet
	Floor:	Manufacturer:
	Location:	Filter: Aerator:
	Description/Observation/Comments:	
	Building:	*Outlet
	Floor:	Manufacturer:
	Location:	Filter: Aerator:
	Description/Observation/Comments:	

46

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: Rick Beall Date: 1 15 18 Time: 1210 AM/PM

Received by: Byron Sims Date: 1 15 18 Time: 1210 AM/PM

Received at Lab: TW 1-5-18 1543 PM 1/15/18



18A0278
47

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 / 5 / 18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Ryan Metzen

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
AGYM - 140 - 002 Sample Number <u>RM</u> Initials	Building: <u>Acker GYM</u> Floor: <u>1</u> Location: <u>Room 140 - new 141</u> Filter: Aerator: Description/Observation/Comments: <u>16.7°</u>
<u>1-5-18</u> Date <u>07:14</u> 24 HR Time COC	*Outlet <u>WC</u> Manufacturer: <u>Hawes</u>
AGYM - 140 - 003 Sample Number <u>RM</u> Initials	Building: <u>Acker GYM</u> Floor: <u>1</u> Location: <u>Room 140 - new 141</u> Filter: Aerator: Description/Observation/Comments: <u>16.9°</u>
<u>1-5-18</u> Date <u>07:15</u> 24 HR Time COC	*Outlet <u>WC</u> Manufacturer: <u>Hawes</u>
AGYM - 140 - 001 Sample Number <u>RM</u> Initials	Building: <u>Acker GYM</u> Floor: <u>1</u> Location: <u>Room 140 (New 140B)</u> Filter: Aerator: Description/Observation/Comments: <u>15.6°</u>
<u>1-5-18</u> Date <u>07:19</u> 24 HR Time COC	*Outlet <u>WC</u> Manufacturer: <u>HAWES</u>

47
48
49

Z:\Clients\Chico State\17-4612 Campus Wide Water Testing - Lead\Water COC & Forms\Water Request Ryan Metzen.wpd

Verified by Pro

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: R. Beall Date: 1 / 5 / 18 Time: 12:10 AM/PM

Received by: Bryan Liu Date: 1 / 5 / 18 Time: 12:10 AM/PM

Received on 1-5-18 RW 154300 448



ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

18A0278

Date of Sampling: 11518

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Ryan Metzen

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample		Information	
AGYM - 140 - 004 Sample Number <u>RM</u> Initials	<u>1-5-18</u> Date <u>07:23</u> 24 HR Time COC	Building: <u>ACKER GYM</u>	Outlet <u>WC</u>
		Floor: <u>1</u>	Manufacturer: <u>Hawes</u>
		Location: <u>Room 140 near SE Ent</u>	Filter: Aerator:
		Description/Observation/Comments: <u>16.5°</u>	
AGYM - 140 - 005 Sample Number <u>RM</u> Initials	<u>1-5-18</u> Date <u>07:24</u> 24 HR Time COC	Building: <u>ACKER GYM</u>	Outlet <u>WC</u>
		Floor: <u>1</u>	Manufacturer: <u>Hawes</u>
		Location: <u>Room 140 near SE Ent</u>	Filter: Aerator:
		Description/Observation/Comments: <u>16.8°</u>	
AGYM - 000 - 001 Sample Number <u>RM</u> Initials	<u>1-5-18</u> Date <u>07:32</u> 24 HR Time COC	Building: <u>ACKER GYM</u>	Outlet <u>WC</u>
		Floor: <u>1</u>	Manufacturer: <u>EXM</u>
		Location: <u>Lobby near women's ex</u>	Filter: Aerator:
		Description/Observation/Comments: <u>15.8°</u>	

50

51

52

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: Raf Beall Date: 11518 Time: 1210 AM/PM

Received by: Byron Ent Date: 11518 Time: 1210 AM/PM

Received By Lab: TW 1-5-18 1543 1448



ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
 ROCKLIN, CA 95677
 (916) 632-6800 PHONE (916) 632-6812 FAX

18A0278

Date of Sampling: 1 15 18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
 Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Ryan Metzen

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
 Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample		Information	
AGYM - 000 - 002 Sample Number <u>RM</u> Initials	<u>1-5-18</u> Date <u>07:32</u> 24 HR Time COC	Building: <u>Acker GYM</u>	Outlet <u>WC</u>
		Floor: <u>1</u>	Manufacturer: <u>Eluay</u>
		Location: <u>Lobby near women's RR</u>	Filter: Aerator:
		Description/Observation/Comments: <u>13.8°</u>	
AGYM - 000 - 003 Sample Number <u>RM</u> Initials	<u>1-5-18</u> Date <u>07:34</u> 24 HR Time COC	Building: <u>Acker GYM</u>	Outlet <u>BS</u>
		Floor: <u>1</u>	Manufacturer:
		Location: <u>Lobby near women's RR</u>	Filter: Aerator:
		Description/Observation/Comments: <u>15.6°</u>	
AGYM - 128 - 001 Sample Number <u>RM</u> Initials	<u>1-5-18</u> Date <u>07:38</u> 24 HR Time COC	Building: <u>Acker GYM</u>	Outlet <u>DW</u>
		Floor: <u>1</u>	Manufacturer: <u>Unknown</u>
		Location: <u>Lobby South</u>	Filter: Aerator:
		Description/Observation/Comments: <u>14.8°</u>	

53

54

55

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: R. Beall Date: 1 15 18 Time: 1210 AM/PM

Received by: Bryan Smith Date: 1 15 18 Time: 1710 AM/PM

Received in Lab: TW 1-5-18 154301448



ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
 ROCKLIN, CA 95677
 (916) 632-6800 PHONE (916) 632-6812 FAX

18A0278

Date of Sampling: 1 15 18

Lab: Basic Laboratory, Inc. Basic Laboratory, Inc.
 2218 Railroad Avenue 3860 Morrow Lane, # F
 Redding, CA 96001 Chico, CA 95928

Job Number: 17-4612

Collected by: Ryan Metzen

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
 Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: *Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu*

Place Label for Each Sample	Information	
AGYM - 128 - 002 Sample Number <u>RM</u> Initials Date <u>1-5-18</u> 24 HR Time <u>07:39</u> COC	Building: <u>Acker Gym</u>	Outlet <u>DW</u>
	Floor: <u>1</u>	Manufacturer: <u>unknown</u>
	Location: <u>Lobby South</u>	Filter: Aerator:
	Description/Observation/Comments: <u>15.4</u>	
AGYM - 128 - 003 Sample Number <u>RM</u> Initials Date <u>1-5-18</u> 24 HR Time <u>07:40</u> COC	Building: <u>Acker Gym</u>	Outlet <u>DW</u>
	Floor: <u>1</u>	Manufacturer: <u>unknown</u>
	Location: <u>Lobby South</u>	Filter: Aerator:
	Description/Observation/Comments: <u>16.8</u>	
AGYM - 128 - 004 Sample Number <u>RM</u> Initials Date <u>1-5-18</u> 24 HR Time <u>07:48</u> COC	Building: <u>Acker Gym</u>	Outlet <u>WC</u>
	Floor: <u>1</u>	Manufacturer: <u>Elkor</u>
	Location: <u>Room 128</u>	Filter: Aerator:
	Description/Observation/Comments: <u>15.8</u>	

56

57

58

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: R. Beall Date: 1 15 18 Time: 1210 AM/PM

Received by: Ryan Eris Date: 1 15 18 Time: 1210 AM/PM

Delivered by: TW Date: 1-5-18 Time: 1543 AM/PM



18A0278

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1/5/18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Ryan Metzen

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
AGYM - 128 - 005 Sample Number <u>RM</u> Initials <u>1-5-18</u> Date <u>07:49</u> 24 HR Time COC	Building: <u>ACKER GYM</u> Floor: <u>1</u> Location: <u>Room 128</u> Description/Observation/Comments: <u>15.4°</u> Outlet: <u>BS</u> Manufacturer: <u>Elkey</u> Filter: Aerator:
<u>AGYM-117-001</u> Sample Number <u>RM</u> Initials <u>1-5-18</u> Date <u>07:52</u> 24 HR Time COC	Building: <u>ACKER GYM</u> Floor: <u>1</u> Location: <u>Hallway by 117</u> Description/Observation/Comments: <u>16.4°</u> Outlet: <u>WC</u> Manufacturer: <u>UNKNOWN</u> Filter: Aerator:
SHUM-HW-100-001 Sample Number <u>RM</u> Initials <u>1-5-18</u> Date <u>07:57</u> 24 HR Time COC	Building: <u>SHRUMEX GYM</u> Floor: <u>1</u> Location: <u>New Room 100</u> Description/Observation/Comments: <u>16.1°</u> Outlet: <u>WC</u> Manufacturer: <u>Elkey</u> Filter: Aerator:

59

60

61

*Outlet Type: DW = Drinking Water Bubler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: R. E. Beall Date: 1/5/18 Time: 1210 AM/PM

Received by: Bryan Smith Date: 1/5/18 Time: 1710 AM/PM

Received at Lab: TLW 754381448



ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
 ROCKLIN, CA 95677
 (916) 632-6800 PHONE (916) 632-6812 FAX

18A0278

Date of Sampling: 1/5/18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
 Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Ryan Metzen

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
 Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information	
SHUM-HW-100-002 Sample Number Date <u>RM</u> <u>07:58</u> Initials 24 HR Time COC	Building: <u>Shrumer Gym</u>	Outlet <u>WC</u>
	Floor: <u>1</u>	Manufacturer: <u>EIKay</u>
	Location: <u>Outside Room 106</u>	Filter: Aerator:
	Description/Observation/Comments: <u>16.6°</u>	
SHUM-HW-100-003 Sample Number Date <u>RM</u> <u>07:59</u> Initials 24 HR Time COC	Building: <u>Shrumer Gym</u>	Outlet <u>BS</u>
	Floor: <u>1</u>	Manufacturer: <u>EIKay</u>
	Location: <u>Outside Room 106</u>	Filter: Aerator:
	Description/Observation/Comments: <u>15.0°</u>	
SHC-117-001 Sample Number Date <u>RM</u> <u>08:11</u> Initials 24 HR Time COC	Building: <u>Student Health Center</u>	Outlet <u>WC</u>
	Floor: <u>1</u>	Manufacturer: <u>EIKay</u>
	Location: <u>Waiting Area</u>	Filter: Aerator:
	Description/Observation/Comments: <u>15.3°</u>	

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: Rip Beall Date: 1/5/18 Time: 1210 AM/PM

Received by: Byron Sun Date: 1/5/18 Time: 1210 AM/PM

Received by: Lab Date: 1-5-18 Time: 1543/1448



18A0278

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 15 18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Ryan Metzen

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information	
SHC-117-002 Sample Number <u>RM</u> Initials Date: <u>1-5-18</u> 24 HR Time: <u>08:12</u> COC	Building: <u>Student Health Center</u>	Outlet: <u>BS</u>
	Floor: <u>1</u>	Manufacturer: <u>Elkay</u>
	Location: <u>Waiting Area</u>	Filter: Aerator:
	Description/Observation/Comments: <u>Water was running when staff arrived. Cut around 07:40</u> 14.8°	
SHC-148-001 Sample Number <u>RM</u> Initials Date: <u>1-5-18</u> 24 HR Time: <u>09:16</u> COC	Building: <u>Student Health Center</u>	Outlet: <u>WC</u>
	Floor: <u>1</u>	Manufacturer: <u>Haws</u>
	Location: <u>Hallway near room 148</u>	Filter: Aerator:
	Description/Observation/Comments: 16.9°	
SHC-HW-137-001 Sample Number <u>RM</u> Initials Date: <u>1-5-18</u> 24 HR Time: <u>08:20</u> COC	Building: <u>Student Health Center</u>	Outlet: <u>KF</u>
	Floor: <u>1</u>	Manufacturer: <u>Elkay</u>
	Location: <u>Room 137</u>	Filter: Aerator:
	Description/Observation/Comments: 16.4°	

65

66

67

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: R. P. Beall Date: 1 15 18 Time: 1210 AM/PM

Received by: Byron Date: 1 15 18 Time: 1210 AM/PM

Received by: TL Date: 1-5-18 Time: 1543 1448



ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
 ROCKLIN, CA 95677
 (916) 632-6800 PHONE (916) 632-6812 FAX

18A0278

Date of Sampling: 1 15 /18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
 Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Ryan Metzen

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
 Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information	
SHC-HW-256-001 Sample Number <u>RM</u> Initials Date <u>1-5-18</u> 24 HR Time <u>08:24</u> COC	Building: <u>Student Health Center</u>	Outlet <u>WC</u>
	Floor: <u>2</u>	Manufacturer: <u>HAW S</u>
	Location: <u>Waiting Area 256</u>	Filter: Aerator:
	Description/Observation/Comments: <u>15.3^c</u>	
SHC-HW-240-001 Sample Number <u>RM</u> Initials Date <u>1-5-18</u> 24 HR Time <u>08:28</u> COC	Building: <u>Student Health Center</u>	Outlet <u>KF</u>
	Floor: <u>2</u>	Manufacturer: <u>Unknown</u>
	Location: <u>Room 246</u>	Filter: Aerator:
	Description/Observation/Comments: <u>16.2^c</u>	
SHC-HW-220-001 Sample Number <u>RM</u> Initials Date <u>1-5-18</u> 24 HR Time <u>08:37</u> COC	Building: <u>Student Health Center</u>	Outlet <u>KF</u>
	Floor: <u>2</u>	Manufacturer: <u>Elkay</u>
	Location: <u>Room 22C</u>	Filter: Aerator:
	Description/Observation/Comments: <u>16.1^c</u>	

68

69

70

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: R. Beall Date: 1 15 /18 Time: 1210 AM/PM

Received by: Bryan Smith Date: 1 15 /18 Time: 1210 AM/PM

Received by: 711.0 1-5-18 1543 1448



18A0278

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 / 5 / 18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Ryan Metzger

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: *Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu*

Place Label for Each Sample		Information	
SHUM-102-001 Sample Number <u>RM</u> Initials	<u>1-5-18</u> Date <u>08:43</u> 24 HR Time COC	Building: <u>Shrummer GYM</u>	Outlet <u>WC</u>
		Floor: <u>1</u>	Manufacturer: <u>HAWES</u>
		Location: <u>Room 102</u>	Filter: Aerator:
		Description/Observation/Comments: <u>15.4^u</u>	
SHUM-102-002 Sample Number <u>RM</u> Initials	<u>1-5-18</u> Date <u>08:46</u> <u>08:40</u> 24 HR Time COC	Building: <u>Shrummer GYM</u>	Outlet <u>WC</u>
		Floor: <u>1</u>	Manufacturer: <u>HAWES</u>
		Location: <u>Room 102</u>	Filter: Aerator:
		Description/Observation/Comments: <u>14.9^u</u>	
SHUM-HW-166-001 Sample Number <u>RM</u> Initials	<u>1-5-18</u> Date <u>08:59</u> 24 HR Time COC	Building: <u>Shrummer GYM</u>	Outlet <u>WC</u>
		Floor: <u>1</u>	Manufacturer: <u>HAWES</u>
		Location: <u>Hallway near Room 166</u>	Filter: Aerator:
		Description/Observation/Comments: <u>15.7^u</u>	

71

72

73

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1 / 5 / 18 Time: 1210 AM/PM

Received by: [Signature] Date: 1 / 5 / 18 Time: 1210 AM/PM

Received By Lab: [Signature] 7111 1543 1448



ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
 ROCKLIN, CA 95677
 (916) 632-6800 PHONE (916) 632-6812 FAX

18A0278

Date of Sampling: 1 15 18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
 Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Ryan Metzen

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
 Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
AGYM - 143 - 001 Sample Number <u>RM</u> Initials <u>1-5-18</u> Date <u>69:28</u> 24 HR Time COC	Building: <u>ACKER GYM</u> Floor: <u>1</u> Location: <u>Room 143</u> Description/Observation/Comments: <u>14.4°</u> Outlet <u>WC</u> Manufacturer: <u>Haws</u> Filter: Aerator:
AGYM - 144 - 001 Sample Number <u>RM</u> Initials <u>1-5-18</u> Date <u>09:32</u> 24 HR Time COC	Building: <u>ACKER GYM</u> Floor: <u>1</u> Location: <u>Men's Locker Room 144</u> Description/Observation/Comments: <u>11.3°</u> Outlet <u>WC</u> Manufacturer: <u>Haws</u> Filter: Aerator:
AGYM - 144 - 002 Sample Number <u>RM</u> Initials <u>1-5-18</u> Date <u>09:36</u> 24 HR Time COC	Building: <u>ACKER GYM</u> Floor: <u>1</u> Location: <u>Room 144 Men's Locker</u> Description/Observation/Comments: <u>7.9°</u> Outlet <u>WC</u> Manufacturer: <u>Haws</u> Filter: Aerator:

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: R. Beall Date: 1 15 18 Time: 1210 AM/PM

Received by: Byron Smith Date: 1 15 18 Time: 1210 AM/PM

Received by: 711 Date: 1-5-18 Time: 1542100X



18A0278

ENTEK CONSULTING GROUP, INC.
 4200 ROCKLIN ROAD, SUITE 7
 ROCKLIN, CA 95677
 (916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 / 5 / 18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
 Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Ryan Metzner

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
 Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
AGYM-144-003 Sample Number <u>RM</u> Initials Date: <u>1-3-18</u> 24 HR Time: <u>09:40</u> COC	Building: <u>Acker Gym</u> Floor: <u>1</u> Location: <u>Room 144 - Men's Locker</u> Description/Observation/Comments: <u>3.6°</u> Outlet: <u>WC</u> Manufacturer: <u>Haws</u> Filter: Aerator:
AGYM-206-001 Sample Number <u>RM</u> Initials Date: <u>1-3-18</u> 24 HR Time: <u>09:47</u> COC	Building: <u>Acker Gym</u> Floor: <u>2</u> Location: <u>By Room 206</u> Description/Observation/Comments: <u>10.4°</u> Outlet: <u>WC</u> Manufacturer: <u>Haws</u> Filter: Aerator:
202 001 AGYM-202-001 Sample Number <u>RM</u> Initials Date: <u>1-5-18</u> 24 HR Time: <u>09:56</u> COC	Building: <u>Acker Gym</u> Floor: <u>2</u> Location: <u>Room 202</u> Description/Observation/Comments: <u>14.9°</u> Outlet: <u>WC</u> Manufacturer: <u>Haws</u> Filter: Aerator:

80

81

82

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: R. Beall Date: 1 / 5 / 18 Time: 1210 AM/PM

Received by: Byron Smith Date: 1 / 5 / 18 Time: 1210 AM/PM
1542



ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

18A0278

Date of Sampling: 1/5/18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Ryan Metzen

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
AGYM - 203 - 001 Sample Number <u>EW</u> Initials <u>1-5-18</u> Date <u>10:07</u> 24 HR Time COC	Building: <u>Acker GYM</u> Floor: <u>2</u> Location: <u>203</u> Description/Observation/Comments: <u>14.3</u> Outlet <u>WC</u> Manufacturer: <u>Haws</u> Filter: Aerator:
²⁰¹ AGYM - 202 - 001 Sample Number <u>RM</u> Initials <u>1-5-18</u> Date <u>10:13</u> 24 HR Time COC	Building: <u>Acker GYM</u> Floor: <u>2</u> Location: <u>Room 201</u> Description/Observation/Comments: <u>14.1</u> Outlet <u>WC</u> Manufacturer: <u>Haws</u> Filter: Aerator:
LANG-HW-122-001 Sample Number <u>RM</u> Initials <u>1-5-18</u> Date <u>10:35</u> 24 HR Time COC	Building: <u>Langdon Hall</u> Floor: <u>1</u> Location: <u>Hallway outside/22 A</u> Description/Observation/Comments: <u>10.2°</u> Outlet <u>WC</u> Manufacturer: <u>Elkay</u> Filter: Aerator:

83

84

85

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: R.P. Beall Date: 1/5/18 Time: 1210 AM/PM

Received by: Ryan Metzen Date: 1/5/18 Time: 1210 AM/PM

711) 1543 11148



18A0278

ENTEK CONSULTING GROUP, INC.
 4200 ROCKLIN ROAD, SUITE 7
 ROCKLIN, CA 95677
 (916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 15 18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
 Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Ryan Metzen

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
 Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
LANG-HW-122-002 <u>1-5-18</u> Sample Number Date <u>RM</u> <u>16:36</u> Initials 24 HR Time COC	Building: <u>Langdon Hall</u> Outlet <u>WC</u> Floor: <u>1</u> Manufacturer: <u>Elkay</u> Location: <u>outside room 122A</u> Filter: Aerator: Description/Observation/Comments: <u>8.6^c</u>
LANG-HW-103-001 <u>1-5-18</u> Sample Number Date <u>RM</u> <u>10:46</u> Initials 24 HR Time COC	Building: <u>Langdon Hall</u> Outlet <u>WC</u> Floor: <u>1</u> Manufacturer: <u>Elkay</u> Location: <u>Hallway outside 103</u> Filter: Aerator: Description/Observation/Comments: <u>6.6</u>
LANG-HW-103-002 <u>1-5-18</u> Sample Number Date <u>RM</u> <u>10:41</u> Initials 24 HR Time COC	Building: <u>Langdon Hall</u> Outlet <u>WC</u> Floor: <u>1</u> Manufacturer: <u>Elkay</u> Location: <u>Hallway outside 103</u> Filter: Aerator: Description/Observation/Comments: <u>11.8^c</u>

86

87

88

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: R. Beall Date: 1 15 18 Time: 1210 AM/PM

Received by: Ryan Metzen Date: 1 15 18 Time: 1210 AM/PM
1543 1448



18A0278

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
 ROCKLIN, CA 95677
 (916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1-5-18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
 Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Ryan Metzzen

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
 Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information	
LANG-HW-205-001 Sample Number Date <u>RM</u> <u>1-5-18</u> Initials 24 HR Time COC	Building: <u>Langdon Hall</u>	Outlet <u>WC</u>
	Floor: <u>2</u>	Manufacturer: <u>Hows</u>
	Location: <u>Hallway outside 205</u>	Filter: Aerator:
	Description/Observation/Comments: <u>14.30</u>	
	Building:	Outlet
	Floor:	Manufacturer:
	Location:	Filter: Aerator:
	Description/Observation/Comments:	
	Building:	Outlet
	Floor:	Manufacturer:
	Location:	Filter: Aerator:
	Description/Observation/Comments:	

89

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: R. Bull Date: 1-5-18 Time: 12:10 AM/PM

Received by: Byron Liu Date: 1-5-18 Time: 12:10 AM/PM

TerriLynn Wilhelmson

From: Richard Beall <rbeall@entekgroup.com>
Sent: Sunday, January 07, 2018 1:18 PM
To: TerriLynn Wilhelmson
Subject: RE: BASIC LABORATORY 18A0278

TerriLynn,

Sample bottle with the label KONK-101-001 should be KONK-601-001, since it was collected in Hall 6 designated by the 601 series. We forgot to change the number from -601 to -101 on the bottle.

Bottle with the label crossed out KONK-601-001 and with the hand written KONK-101-001 is correct. It is -101 since it was collected in Hall 1 designated by the 101 series. The hand written number -101 is correct.

Thank you for catching this error. Call me on my cell on Monday if this is not clear.

Rick Beall, CIH, CSP
President
Entek Consulting Group, Inc.
4200 Rocklin Road, Suite 7
Rocklin, CA 95677
(916) 632-6800 office
(916) 632-6812 fax
(916) 417-5276 cell
rbeall@entekgroup.com
www.entekgroup.com

From: TerriLynn Wilhelmson [<mailto:twilhelmson@basiclab.com>]
Sent: Friday, January 05, 2018 3:41 PM
To: Richard Beall
Subject: BASIC LABORATORY 18A0278

Hi Rick,

I have a few questions for today's samples. There are duplicate ID's on sample numbers 18 & 28, I matched the samples to the times. Sample 18 looks like it might be 608 on the chain but changed to 101 on the bottle. Sample 28 used to be 601 but now 101 and time matches on the bottle.

Sample 19 the original typed ID matches the bottle and so does the time. So is it 101 or 601 and the same above?

I have attached the pages for the chain of custody and a picture so you can see what I am talking about. Get back to me asap.

*''')
,:.'',:.*''') ,:.*''')
(,.'', (,.'''*

Thank you for choosing Basic Laboratory

TerriLynn Wilhelmson