



www.basiclab.com

2218 Railroad Avenue  
Redding, California 96001

voice 530.243.7234  
fax 530.243.7494

3860 Morrow Lane, Suite F  
Chico, California 95928

voice 530.894.8966  
fax 530.894.5143

February 05, 2018

**Lab ID: 18A1102**

RICHARD PERRELLI  
CSU CHICO - ENVIRONMENTAL HEALTH & SAFETY  
400 WEST FIRST STREET  
CHICO, CA 95929-0019  
RE: DRINKING WATER TESTING LEAD PROJECT


Dear RICHARD PERRELLI ,

Enclosed are the analysis results for Work Order number 18A1102. All analyses were performed under strict adherence to our established Quality Assurance Plan. Any abnormalities are listed in the qualifier section of this report.

If you have any questions regarding these results, please feel free to contact us at any time. We appreciate the opportunity to service your environmental testing needs.

Sincerely,

  
For



Ricky D. Jensen  
Laboratory Director

California ELAP Certification Number 1677



www.basiclab.com

2218 Railroad Avenue voice 530.243.7234  
Redding, California 96001 fax 530.243.7494

3860 Morrow Lane, Suite F voice 530.894.8966  
Chico, California 95928 fax 530.894.5143

**Report To:** CSU CHICO - ENVIRONMENTAL HEALTH & SAFETY  
400 WEST FIRST STREET  
CHICO, CA 95929-0019  
**Attention:** RICHARD PERRELLI  
**Project:** DRINKING WATER TESTING LEAD PROJECT


**Lab No:** 18A1102  
**Reported:** 02/05/18  
**Phone:** 898-5126  
**P.O. #** 0000081330

**Metals - Total**

Analyte	Units	Results	Qualifier	MDL	RL	Method	Analyzed	Prepared	Batch
<b>LASS-1MB-R002 - Grab Drinking Water (18A1102-01)</b>			<b>Sampled:01/19/18 08:42</b>			<b>Received:01/26/18 13:31</b>			
Lead	ug/l	ND		5.0		EPA 200.8	02/02/18	02/02/18	B8B0740
<b>LASS-3MB-R002 - Grab Drinking Water (18A1102-02)</b>			<b>Sampled:01/19/18 08:46</b>			<b>Received:01/26/18 13:31</b>			
Lead	ug/l	ND		5.0		EPA 200.8	02/02/18	02/02/18	B8B0740

**Notes and Definitions**

- DET Analyte DETECTED
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- dry Sample results reported on a dry weight basis
- RPD Relative Percent Difference
- < Less than reporting limit
- ≤ Less than or equal to reporting limit
- > Greater than reporting limit
- ≥ Greater than or equal to reporting limit
- MDL Method Detection Limit
- RL/ML Minimum Level of Quantitation
- MCL/AL Maximum Contaminant Level/Action Level
- mg/kg Results reported as wet weight
- TTLC Total Threshold Limit Concentration
- STLC Soluble Threshold Limit Concentration
- TCLP Toxicity Characteristic Leachate Procedure
- Note 1 Received Temperature - according to EPA guidelines, samples for most chemistry methods should be held at ≤6 degrees C after collection, including during transportation, unless the time from sampling to delivery is <2 hours. Regulating agencies may invalidate results if temperature requirements are not met.
- Note 2 According to 40 CFR Part 136 Table II, the following tests should be analyzed in the field within 15 minutes of sampling: pH, chlorine, dissolved oxygen, and sulfite.

  
Approved By



California State University, Chico

400 West 1st Street  
Chico, California 95929-0019  
(916) 898-5126 (Phone)

(530-898-6511 (Fax)

18A1102

Due ~~2-4-18~~  
2-7-18 <sup>PSB</sup>

18A1102  
1

Date of Sampling: 1-19-2018

Lab: Basic Laboratory, Inc.  
2218 Railroad Avenue  
Redding, CA 96001

Basic Laboratory, Inc.  
3860 Morrow Lane, #F  
Chico, CA 95928

Job Number: 17-4612

Client Name: California State University, Chico

Site Address: Campus Wide Water Quality Testing for Lead  
Chico, California

Collected by: Yvette Streeter

Turnaround Time: 8 - 10 Days

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instructions: Please e-mail results as soon as available and include copy of submittal with those results to:  
mpratt@csuchico.edu, and rperrelli@csuchico.edu

Place Label for Each Sample	Information
LASS-1MB-R002 Sample Number <u>YPS</u> Initials Date: <u>1-19-18</u> 24 HR Time: <u>0842</u> COC	Building: <u>LASSEN HALL</u> Outlet: <u>SINK</u>
	Floor: <u>FIRST</u> Manufacturer: <u>UNKNOWN</u>
	Location: <u>MENS RESTROOM</u> Filter: <u>Ø</u> Aerator: <u>Ø</u>
	Description/Observation/Comments: <u>8-2°C</u> <u>Retest</u>
LASS-3MB-R002 Sample Number <u>YPS</u> Initials Date: <u>1-19-18</u> 24 HR Time: <u>0846</u> COC	Building: <u>LASSEN HALL</u> Outlet: <u>SINK -2</u>
	Floor: <u>THIRD</u> Manufacturer: <u>UNKNOWN</u>
	Location: <u>MENS RESTROOM</u> Filter: <u>Ø</u> Aerator: <u>Ø</u>
	Description/Observation/Comments: <u>6.9°C</u> <u>Retest</u>
	Building: _____ Outlet: _____
	Floor: _____ Manufacturer: _____
	Location: _____ Filter: _____ Aerator: _____
	Description/Observation/Comments: _____

Outlet Type: DW: Drinking Water Bubbler

CF: Classroom Faucet

CM: Coffee Machine

WC: Water Cooler

KF: Kitchen Faucet

GF: Glass Filler

BS: Bottle Filling Station

BF: Bathroom Faucet

WD: Water Dispenser

IM: Ice Maker

Delivered by: Yvette Streeter

Date: 1-25-2018

Time: 12:01 AM/PM

Received by: Jill / Yvette

Date: 1/25/2018 / 1/26/18

Time: 12:03 / 0900am AM/PM

Recvd by lab: Pollen 1-26-18 13:31

Logged in by: Pollen 1-26-18 13:47

LASS-1MB-R002 1-26-18 13:11