



www.basiclab.com

2218 Railroad Avenue
Redding, California 96001

voice 530.243.7234
fax 530.243.7494

3860 Morrow Lane, Suite F
Chico, California 95928

voice 530.894.8966
fax 530.894.5143

January 24, 2018

Lab ID: 18A0618


RICHARD BEALL
ENTEK CONSULTING GROUP
4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
RE: CHICO STATE LEAD TESTING 17-4612


Dear RICHARD BEALL ,

Enclosed are the analysis results for Work Order number 18A0618. All analyses were performed under strict adherence to our established Quality Assurance Plan. Any abnormalities are listed in the qualifier section of this report.

If you have any questions regarding these results, please feel free to contact us at any time. We appreciate the opportunity to service your environmental testing needs.

Sincerely,


For



Ricky D. Jensen
Laboratory Director

California ELAP Certification Number 1677



www.basiclab.com

2218 Railroad Avenue
Redding, California 96001

voice 530.243.7234
fax 530.243.7494

3860 Morrow Lane, Suite F
Chico, California 95928

voice 530.894.8966
fax 530.894.5143

Report To: ENTEK CONSULTING GROUP
4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677

Attention: RICHARD BEALL
Project: CHICO STATE LEAD TESTING 17-4612

Lab No: 18A0618
Reported: 01/24/18
Phone: (916) 632-6800
P.O. #

Metals - Total

Analyte	Units	Results	Qualifier	MDL	RL	Method	Analyzed	Prepared	Batch
UV-BLDG05-K01A - Grab Drinking Water (18A0618-01)			Sampled:01/11/18 07:25				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1356	
UV-BLDG05-083 - Grab Drinking Water (18A0618-02)			Sampled:01/11/18 07:26				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1356	
UV-BLDG05-082 - Grab Drinking Water (18A0618-03)			Sampled:01/11/18 07:27				Received:01/12/18 12:48		
Lead	ug/l	7.2		5.0	EPA 200.8	01/21/18	01/21/18	B8A1356	
UV-BLDG05-081 - Grab Drinking Water (18A0618-04)			Sampled:01/11/18 07:28				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1356	
UV-BLDG05-084 - Grab Drinking Water (18A0618-05)			Sampled:01/11/18 07:28				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1356	
UV-BLDG06-K01B - Grab Drinking Water (18A0618-06)			Sampled:01/11/18 07:32				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1356	
UV-BLDG06-111 - Grab Drinking Water (18A0618-07)			Sampled:01/11/18 07:33				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1356	
UV-BLDG06-110 - Grab Drinking Water (18A0618-08)			Sampled:01/11/18 07:34				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1356	
UV-BLDG06-112 - Grab Drinking Water (18A0618-09)			Sampled:01/11/18 07:34				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1356	
UV-BLDG06-109 - Grab Drinking Water (18A0618-10)			Sampled:01/11/18 07:35				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1356	
UV-BLDG06-K01A - Grab Drinking Water (18A0618-11)			Sampled:01/11/18 07:37				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1356	
UV-BLDG06-107 - Grab Drinking Water (18A0618-12)			Sampled:01/11/18 07:38				Received:01/12/18 12:48		
Lead	ug/l	6.9		5.0	EPA 200.8	01/21/18	01/21/18	B8A1356	
UV-BLDG06-106 - Grab Drinking Water (18A0618-13)			Sampled:01/11/18 07:39				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1356	
UV-BLDG06-105 - Grab Drinking Water (18A0618-14)			Sampled:01/11/18 07:40				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1356	
UV-BLDG06-108 - Grab Drinking Water (18A0618-15)			Sampled:01/11/18 07:40				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1356	
UV-BLDG06-K02A - Grab Drinking Water (18A0618-16)			Sampled:01/11/18 07:43				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1356	
UV-BLDG06-115 - Grab Drinking Water (18A0618-17)			Sampled:01/11/18 07:43				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1356	
UV-BLDG06-114 - Grab Drinking Water (18A0618-18)			Sampled:01/11/18 07:44				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1356	
UV-BLDG06-113 - Grab Drinking Water (18A0618-19)			Sampled:01/11/18 07:45				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1356	
UV-BLDG06-116 - Grab Drinking Water (18A0618-20)			Sampled:01/11/18 07:46				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1356	
UV-BLDG06-K02B - Grab Drinking Water (18A0618-21)			Sampled:01/11/18 07:47				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1357	
UV-BLDG06-119 - Grab Drinking Water (18A0618-22)			Sampled:01/11/18 07:48				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1357	

Richard Beall

Approved By

Basic Laboratory Inc

California ELAP Cert #1677 and #2718



www.basiclab.com

2218 Railroad Avenue Redding, California 96001 voice 530.243.7234 fax 530.243.7494

3860 Morrow Lane, Suite F Chico, California 95928 voice 530.894.8966 fax 530.894.5143

Report To: ENTEK CONSULTING GROUP 4200 ROCKLIN ROAD, SUITE 7 ROCKLIN, CA 95677

Attention: RICHARD BEALL Project: CHICO STATE LEAD TESTING 17-4612

Lab No: 18A0618 Reported: 01/24/18 Phone: (916) 632-6800 P.O. #

Metals - Total

Table with columns: Analyte, Units, Results, Qualifier, MDL, RL, Method, Analyzed, Prepared, Batch. Rows include UV-BLDG06-117 through UV-BLDG22-397, all showing Lead results as ND.

Approved By [Signature] Basic Laboratory Inc California ELAP Cert #1677 and #2718



www.basiclab.com

2218 Railroad Avenue Redding, California 96001 voice 530.243.7234 fax 530.243.7494

3860 Morrow Lane, Suite F Chico, California 95928 voice 530.894.8966 fax 530.894.5143

Report To: ENTEK CONSULTING GROUP 4200 ROCKLIN ROAD, SUITE 7 ROCKLIN, CA 95677

Attention: RICHARD BEALL Project: CHICO STATE LEAD TESTING 17-4612

Lab No: 18A0618 Reported: 01/24/18 Phone: (916) 632-6800 P.O. #

Metals - Total

Table with columns: Analyte, Units, Results, Qualifier, MDL, RL, Method, Analyzed, Prepared, Batch. Rows include UV-BLDG22-398 through UV-BLDG24-426, all showing Lead results as ND.

Approved By [Signature]

Basic Laboratory Inc California ELAP Cert #1677 and #2718



www.basiclab.com

2218 Railroad Avenue
Redding, California 96001

voice 530.243.7234
fax 530.243.7494

3860 Morrow Lane, Suite F
Chico, California 95928

voice 530.894.8966
fax 530.894.5143

Report To: ENTEK CONSULTING GROUP
4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677

Attention: RICHARD BEALL
Project: CHICO STATE LEAD TESTING 17-4612

Lab No: 18A0618
Reported: 01/24/18
Phone: (916) 632-6800
P.O. #

Metals - Total

Analyte	Units	Results	Qualifier	MDL	RL	Method	Analyzed	Prepared	Batch
UV-BLDG24-427 - Grab Drinking Water (18A0618-67)			Sampled:01/11/18 08:50				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1359	
UV-BLDG24-425 - Grab Drinking Water (18A0618-68)			Sampled:01/11/18 08:51				Received:01/12/18 12:48		
Lead	ug/l	7.3		5.0	EPA 200.8	01/21/18	01/21/18	B8A1359	
UV-BLDG24-428 - Grab Drinking Water (18A0618-69)			Sampled:01/11/18 08:52				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1359	
UV-BLDG24-K01A - Grab Drinking Water (18A0618-70)			Sampled:01/11/18 08:54				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1359	
UV-BLDG24-435 - Grab Drinking Water (18A0618-71)			Sampled:01/11/18 08:55				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1359	
UV-BLDG24-434 - Grab Drinking Water (18A0618-72)			Sampled:01/11/18 08:56				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1359	
UV-BLDG24-433 - Grab Drinking Water (18A0618-73)			Sampled:01/11/18 08:57				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1359	
UV-BLDG24-436 - Grab Drinking Water (18A0618-74)			Sampled:01/11/18 08:58				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/22/18	01/21/18	B8A1367	
UV-BLDG24-K02A - Grab Drinking Water (18A0618-75)			Sampled:01/11/18 09:01				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/22/18	01/21/18	B8A1367	
UV-BLDG24-447 - Grab Drinking Water (18A0618-76)			Sampled:01/11/18 09:02				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/22/18	01/21/18	B8A1367	
UV-BLDG24-446 - Grab Drinking Water (18A0618-77)			Sampled:01/11/18 09:03				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1359	
UV-BLDG24-445 - Grab Drinking Water (18A0618-78)			Sampled:01/11/18 09:03				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1359	
UV-BLDG24-448 - Grab Drinking Water (18A0618-79)			Sampled:01/11/18 09:04				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1359	
UV-BLDG25-K01A - Grab Drinking Water (18A0618-80)			Sampled:01/11/18 09:08				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1359	
UV-BLDG25-450 - Grab Drinking Water (18A0618-81)			Sampled:01/11/18 09:09				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1360	
UV-BLDG25-449 - Grab Drinking Water (18A0618-82)			Sampled:01/11/18 09:11				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1360	
UV-BLDG25-451 - Grab Drinking Water (18A0618-83)			Sampled:01/11/18 09:10				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1360	
UV-BLDG25-452 - Grab Drinking Water (18A0618-84)			Sampled:01/11/18 09:12				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1360	
UV-BLD25-K02A - Grab Drinking Water (18A0618-85)			Sampled:01/11/18 09:13				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1360	
UV-BLDG25-455 - Grab Drinking Water (18A0618-86)			Sampled:01/11/18 09:14				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1360	
UV-BLDG25-456 - Grab Drinking Water (18A0618-87)			Sampled:01/11/18 09:15				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1360	
UV-BLDG25-453 - Grab Drinking Water (18A0618-88)			Sampled:01/11/18 09:16				Received:01/12/18 12:48		
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1360	

Approved By
Basic Laboratory Inc
California ELAP Cert #1677 and #2718



www.basiclab.com

2218 Railroad Avenue voice 530.243.7234
 Redding, California 96001 fax 530.243.7494

3860 Morrow Lane, Suite F voice 530.894.8966
 Chico, California 95928 fax 530.894.5143


Report To: ENTEK CONSULTING GROUP
 4200 ROCKLIN ROAD, SUITE 7
 ROCKLIN, CA 95677

Attention: RICHARD BEALL
Project: CHICO STATE LEAD TESTING 17-4612

Lab No: 18A0618
Reported: 01/24/18
Phone: (916) 632-6800
P.O. #

Metals - Total

Analyte	Units	Results	Qualifier	MDL	RL	Method	Analyzed	Prepared	Batch
UV-BLDG25-454 - Grab Drinking Water (18A0618-89)			Sampled:01/11/18 09:16			Received:01/12/18 12:48			
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1360	
UV-BLD25-K04A - Grab Drinking Water (18A0618-90)			Sampled:01/11/18 09:18			Received:01/12/18 12:48			
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1360	
UV-BLDG25-462 - Grab Drinking Water (18A0618-91)			Sampled:01/11/18 09:19			Received:01/12/18 12:48			
Lead	ug/l	ND		5.0	EPA 200.8	01/22/18	01/21/18	B8A1367	
UV-BLDG25-463 - Grab Drinking Water (18A0618-92)			Sampled:01/11/18 09:20			Received:01/12/18 12:48			
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1360	
UV-BLDG25-464 - Grab Drinking Water (18A0618-93)			Sampled:01/11/18 09:21			Received:01/12/18 12:48			
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1360	
UV-BLDG25-461 - Grab Drinking Water (18A0618-94)			Sampled:01/11/18 09:21			Received:01/12/18 12:48			
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1360	
UV-BLD25-K03A - Grab Drinking Water (18A0618-95)			Sampled:01/11/18 09:23			Received:01/12/18 12:48			
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1360	
UV-BLDG25-459 - Grab Drinking Water (18A0618-96)			Sampled:01/11/18 09:24			Received:01/12/18 12:48			
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1360	
UV-BLDG25-458 - Grab Drinking Water (18A0618-97)			Sampled:01/11/18 09:25			Received:01/12/18 12:48			
Lead	ug/l	ND		5.0	EPA 200.8	01/21/18	01/21/18	B8A1360	
UV-BLDG25-460 - Grab Drinking Water (18A0618-98)			Sampled:01/11/18 09:26			Received:01/12/18 12:48			
Lead	ug/l	ND		5.0	EPA 200.8	01/22/18	01/21/18	B8A1367	
UV-BLDG25-457 - Grab Drinking Water (18A0618-99)			Sampled:01/11/18 09:27			Received:01/12/18 12:48			
Lead	ug/l	ND		5.0	EPA 200.8	01/22/18	01/21/18	B8A1367	


 Approved By
 Basic Laboratory Inc
 California ELAP Cert #1677 and #2718



www.basiclab.com

2218 Railroad Avenue
Redding, California 96001

voice 530.243.7234
fax 530.243.7494

3860 Morrow Lane, Suite F
Chico, California 95928

voice 530.894.8966
fax 530.894.5143

Report To: ENTEK CONSULTING GROUP
4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677

Attention: RICHARD BEALL

Project: CHICO STATE LEAD TESTING 17-4612

Lab No: 18A0618
Reported: 01/24/18
Phone: (916) 632-6800
P.O. #

Notes and Definitions

- DET Analyte DETECTED
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- dry Sample results reported on a dry weight basis
- RPD Relative Percent Difference
- < Less than reporting limit
- ≤ Less than or equal to reporting limit
- > Greater than reporting limit
- ≥ Greater than or equal to reporting limit
- MDL Method Detection Limit
- RL/ML Minimum Level of Quantitation
- MCL/AL Maximum Contaminant Level/Action Level
- mg/kg Results reported as wet weight
- TTLC Total Threshold Limit Concentration
- STLC Soluble Threshold Limit Concentration
- TCLP Toxicity Characteristic Leachate Procedure
- Note 1 Received Temperature - according to EPA guidelines, samples for most chemistry methods should be held at ≤6 degrees C after collection, including during transportation, unless the time from sampling to delivery is <2 hours. Regulating agencies may invalidate results if temperature requirements are not met.
- Note 2 According to 40 CFR Part 136 Table II, the following tests should be analyzed in the field within 15 minutes of sampling: pH, chlorine, dissolved oxygen, and sulfite.

Approved By

Basic Laboratory Inc

California ELAP Cert #1677 and #2718



18A0618

1

18A0618

Pg 1 of 33

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1/11/18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Andy Roed

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
UV-BLDG05-K01A Sample Number <u>AR</u> Initials	Building: <u>5</u> Floor: <u>1</u> Location: <u>Kitchen</u> Description/Observation/Comments: <u>11.4°</u>
<u>1-11-18</u> Date <u>07:25</u> 24 HR Time COC	*Outlet <u>KF</u> Manufacturer: <u>N/A</u> Filter: Aerator:
UV-BLDG05-083 Sample Number <u>AR</u> Initials	Building: <u>5</u> Floor: <u>1</u> Location: <u>Rm 83</u> Description/Observation/Comments: <u>11.8°</u>
<u>1-11-18</u> Date <u>07:26</u> 24 HR Time COC	*Outlet <u>BF</u> Manufacturer: <u>Delta</u> Filter: Aerator:
UV-BLDG05-082 Sample Number <u>AR</u> Initials	Building: <u>5</u> Floor: <u>1</u> Location: <u>Rm 82</u> Description/Observation/Comments: <u>11.8°</u>
<u>1-11-18</u> Date <u>07:27</u> 24 HR Time COC	*Outlet <u>BF</u> Manufacturer: <u>Delta</u> Filter: Aerator:

Verified SJ


Preserved HNO3 PH<2 1-12-18

Logged TWW 1-12-18 1441

- *Outlet Type: DW = Drinking Water Bubbler, WC = Water Cooler, BS = Bottle Filling Station, WD = Water Dispenser
- CF = Classroom Faucet, KF = Kitchen Faucet, BF = Bathroom Faucet, IM = Ice Maker
- CM = Coffee Machine, GF = Glass Filler

Delivered by: [Signature] Date: 1/11/18 Time: 12:00 AM/PM

Received by: [Signature] Date: 1/11/18 Time: 12:02 AM/PM
1-12-18 12:48 10:00 Relinquished



ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

pg 2 of 33

Date of Sampling: 1/11/18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Andy Roed

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
UV-BLDG05-081 Sample Number <u>AR</u> Initials	Building: <u>5</u> Floor: <u>1</u> Location: <u>Rm 81</u> Description/Observation/Comments: <u>11.5</u>
<u>1-11-18</u> Date <u>07:28</u> 24 HR Time	*Outlet <u>BF</u> Manufacturer: <u>Delta</u> Filter: Aerator:
<u>COC</u>	
UV-BLDG05-084 Sample Number <u>AR</u> Initials	Building: <u>5</u> Floor: <u>1</u> Location: <u>Rm 84</u> Description/Observation/Comments: <u>11.5°</u>
<u>1-11-18</u> Date <u>07:28</u> 24 HR Time	*Outlet <u>BF</u> Manufacturer: <u>Delta</u> Filter: Aerator:
<u>COC</u>	
UV-BLDG06-K01B Sample Number <u>AR</u> Initials	Building: <u>6</u> Floor: <u>1</u> Location: <u>Kitchen</u> Description/Observation/Comments: <u>11.7°</u>
<u>1-11-18</u> Date <u>07:32</u> 24 HR Time	*Outlet <u>KF</u> Manufacturer: <u>VIA</u> Filter: Aerator:
<u>COC</u>	

4

5

6

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1/11/18 Relinquished Date: 1/12/18 Time: 12:00 AM/PM R

Received by: [Signature] Date: 1/11/18 Time: 12:02 AM/PM/10:00



18A0618

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Pg 3 of 33

Date of Sampling: 1/11/18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Andy Roed

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, mmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
UV-BLDG06-111 Sample Number <u>AR</u> Initials Date <u>1-11-18</u> <u>07:33</u> 24 HR Time COC	Building: <u>6</u> *Outlet <u>BF</u> Floor: <u>1</u> Manufacturer: <u>Delta</u> Location: <u>Rm 111</u> Filter: Aerator: Description/Observation/Comments: <u>12.4°</u>
UV-BLDG06-110 Sample Number <u>AR</u> Initials Date <u>1-11-18</u> <u>07:34</u> 24 HR Time COC	Building: <u>6</u> *Outlet <u>BF</u> Floor: <u>1</u> Manufacturer: <u>Delta</u> Location: <u>Rm 110</u> Filter: Aerator: Description/Observation/Comments: <u>11.6°</u>
UV-BLDG06-112 Sample Number <u>AR</u> Initials Date <u>1-11-18</u> <u>07:34</u> 24 HR Time COC	Building: <u>6</u> *Outlet <u>BF</u> Floor: <u>1</u> Manufacturer: <u>Delta</u> Location: <u>Rm 112</u> Filter: Aerator: Description/Observation/Comments: <u>11.2°</u>

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1/11/18 Time: 12:00 AM/PM
 Received by: [Signature] Date: 1/11/18 Time: 12:02 AM/PM 10:00
 Relinquished By: [Signature] Date: 1/12/18



ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1/11/18

Lab: Basic Laboratory, Inc. Basic Laboratory, Inc.
2218 Railroad Avenue 3860 Morrow Lane, # F
Redding, CA 96001 Chico, CA 95928

pg 4 of 33

Job Number: 17-4612

Collected by: Andy Roed

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, mmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
UV-BLDG06-109 Sample Number <u>1-11-18</u> Date <u>AR</u> <u>07:35</u> Initials 24 HR Time COC	Building: <u>6</u> *Outlet <u>BF</u> Floor: <u>1</u> Manufacturer: <u>Delta</u> Location: <u>Rm 109</u> Filter: Aerator: Description/Observation/Comments: <u>11.8°</u>
UV-BLDG06-K01A Sample Number <u>1-11-18</u> Date <u>AR</u> <u>07:37</u> Initials 24 HR Time COC	Building: <u>6</u> *Outlet <u>KF</u> Floor: <u>1</u> Manufacturer: <u>Delta</u> Location: <u>Kitchen</u> Filter: Aerator: Description/Observation/Comments: <u>11.2°</u>
UV-BLDG06-107 Sample Number <u>1-11-18</u> Date <u>AR</u> <u>07:38</u> Initials 24 HR Time COC	Building: <u>6</u> *Outlet <u>BF</u> Floor: <u>1</u> Manufacturer: <u>Delta</u> Location: <u>Rm 107</u> Filter: Aerator: Description/Observation/Comments: <u>11.2°</u>

10

11

12

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1/11/18 Time: 12:00 AM/PM
 Received by: [Signature] Date: 1/11/18 Time: 12:02 AM/PM 10:00



18AUG18

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

pg 5 of 33

Date of Sampling: 1/11/18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Andy Roed

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, mmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
UV-BLDG06-106 Sample Number AR Initials Date: <u>1-11-18</u> 24 HR Time: <u>07:39</u> COC	Building: <u>6</u> *Outlet <u>BF</u>
	Floor: <u>1</u> Manufacturer: <u>Delta</u>
	Location: <u>Rm 106</u> Filter: Aerator:
	Description/Observation/Comments: <u>10.8°</u>
UV-BLDG06-105 Sample Number AR Initials Date: <u>1-11-18</u> 24 HR Time: <u>07:40</u> COC	Building: <u>6</u> *Outlet <u>BF</u>
	Floor: <u>1</u> Manufacturer: <u>Delta</u>
	Location: <u>Rm 105</u> Filter: Aerator:
	Description/Observation/Comments: <u>11.2°</u>
UV-BLDG06-108 Sample Number AR Initials Date: <u>1-11-18</u> 24 HR Time: <u>0740</u> COC	Building: <u>6</u> *Outlet <u>BF</u>
	Floor: <u>1</u> Manufacturer: <u>Delta</u>
	Location: <u>Rm 108</u> Filter: Aerator:
	Description/Observation/Comments: <u>11.3°</u>

13

14

15

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1/11/18 Time: 12:01 AM/PM

Received by: [Signature] Date: 1/11/18 Time: 12:02 AM/PM
[Signature] Date: 1/12/18 Time: 10:00



18A0618

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

pg 6 of 33

Date of Sampling: 1 / 11 /18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Andy Roed

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, metzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
UV-BLDG06-K02A Sample Number AR Initials Date 07:43 24 HR Time COC	Building: <u>B 6</u> *Outlet <u>KF</u>
	Floor: <u>2</u> Manufacturer: <u>Delta</u>
	Location: <u>R. Kitchen</u> Filter: Aerator:
	Description/Observation/Comments: <u>11.0'</u>
UV-BLDG06-115 Sample Number AR Initials Date 07:43 24 HR Time COC	Building: <u>6</u> *Outlet <u>BF</u>
	Floor: <u>2</u> Manufacturer: <u>Delta</u>
	Location: <u>Rm 115</u> Filter: Aerator:
	Description/Observation/Comments: <u>11.3'</u>
UV-BLDG06-114 Sample Number AR Initials Date 07:44 24 HR Time COC	Building: <u>6</u> *Outlet <u>BF</u>
	Floor: <u>2</u> Manufacturer: <u>Delta</u>
	Location: <u>Rm 114</u> Filter: Aerator:
	Description/Observation/Comments: <u>10.9</u>

16

17

18

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1/11/18 Time: 12:00 AM/PM

Received by: [Signature] Date: 1/11/18 Time: 12:02 AM/PM 10:00



18A0618

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Page 7 of 33

Date of Sampling: 1/11/18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Andy Roed

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, metzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
UV-BLDG06-113 Sample Number <u>AR</u> Initials Date: <u>1-11-18</u> 24 HR Time: <u>07:45</u> COC	Building: <u>6</u> Floor: <u>2</u> Location: <u>Rm 113</u> Description/Observation/Comments: <u>245TW 11.1</u> *Outlet: <u>BF</u> Manufacturer: <u>Delta</u> Filter: Aerator:
UV-BLDG06-116 Sample Number <u>AR</u> Initials Date: <u>1-11-18</u> 24 HR Time: <u>07:46</u> COC	Building: <u>6</u> Floor: <u>2</u> Location: <u>Rm 116</u> Description/Observation/Comments: <u>11.4</u> *Outlet: <u>BF</u> Manufacturer: <u>Delta</u> Filter: Aerator:
UV-BLDG06-K02B Sample Number <u>AR</u> Initials Date: <u>1-11-18</u> 24 HR Time: <u>07:47</u> COC	Building: <u>6</u> Floor: <u>2</u> Location: <u>Kitchen</u> Description/Observation/Comments: <u>11.3</u> *Outlet: <u>KF</u> Manufacturer: <u>Delta</u> Filter: Aerator:

19

20

21

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1/11/18 Time: 12:11 AM/PM
 Received by: [Signature] Date: 1/11/18 Time: 12:02 AM/PM / 10:00



18A0618

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

pg 8 of 33

Date of Sampling: 1/11/18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Andy Roed

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
UV-BLDG06-119 Sample Number <u>AR</u> Initials Date <u>1-11-18</u> 24 HR Time <u>0948</u> COC	Building: <u>6</u> *Outlet <u>BF</u>
	Floor: <u>2</u> Manufacturer: <u>Delta</u>
	Location: <u>Rm 119</u> Filter: Aerator:
	Description/Observation/Comments: <u>11.4°</u>
UV-BLDG06-117 Sample Number <u>AR</u> Initials Date <u>1-11-18</u> 24 HR Time <u>0949</u> COC	Building: <u>6</u> *Outlet <u>BF</u>
	Floor: <u>2</u> Manufacturer: <u>Delta</u>
	Location: <u>Rm 119</u> Filter: Aerator:
	Description/Observation/Comments: <u>11.9°</u>
UV-BLDG06-120 Sample Number <u>AR</u> Initials Date <u>1-11-18</u> 24 HR Time <u>0950</u> COC	Building: <u>6</u> *Outlet <u>BF</u>
	Floor: <u>2</u> Manufacturer: <u>Delta</u>
	Location: <u>Rm 120</u> Filter: Aerator:
	Description/Observation/Comments: <u>12.3°</u>

22

23

24

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1/11/18 Time: 12:00 AM/PM

Received by: [Signature] Date: 1/11/18 Time: 12:02 AM/PM / 10:00



18A0618

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

pg 9 of 33

Date of Sampling: 1/11/18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Andy Roed

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, metzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
UV-BLDG06-118 Sample Number <u>AR</u> Initials Date: <u>1-11-18</u> 24 HR Time: <u>07:51</u> COC	Building: <u>6</u> *Outlet <u>BF</u>
	Floor: <u>2</u> Manufacturer: <u>Delta</u>
	Location: <u>Rm 118</u> Filter: Aerator:
	Description/Observation/Comments: <u>11.9°</u>
UV-BLDG22-377 Sample Number <u>AR</u> Initials Date: <u>1-11-18</u> 24 HR Time: <u>07:57</u> COC	Building: <u>22</u> *Outlet <u>KF</u>
	Floor: <u>1</u> Manufacturer: <u>N/A</u>
	Location: <u>Rm 377</u> Filter: Aerator:
	Description/Observation/Comments: <u>11.7°</u>
UV-BLDG22-378 Sample Number <u>AR</u> Initials Date: <u>1-11-18</u> 24 HR Time: <u>07:58</u> COC	Building: <u>22</u> *Outlet <u>KF</u>
	Floor: <u>1</u> Manufacturer: <u>N/A</u>
	Location: <u>Rm 378</u> Filter: Aerator:
	Description/Observation/Comments: <u>11.7°</u>

25

26

27

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1/11/18 Time: 12:00 AM/PM
 Received by: [Signature] Date: 1/11/18 Time: 12:02 AM/PM / 10:00



18A0618

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

pg 10 of 33

Date of Sampling: 1/11/18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Andy Roed

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, metzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information	
UV-BLDG22-390 Sample Number <u>AR</u> Initials Date <u>1-11-18</u> 24 HR Time <u>08:00</u> COC	Building: <u>22</u>	*Outlet <u>KF</u>
	Floor: <u>2</u>	Manufacturer: <u>N/A</u>
	Location: <u>Rm 390</u>	Filter: Aerator:
	Description/Observation/Comments: <u>12.4°</u>	
UV-BLDG22-389 Sample Number <u>AR</u> Initials Date <u>1-11-18</u> 24 HR Time <u>08:00</u> COC	Building: <u>22</u>	*Outlet <u>KF</u>
	Floor: <u>2</u>	Manufacturer: <u>N/A</u>
	Location: <u>Rm 389</u>	Filter: Aerator:
	Description/Observation/Comments: <u>12.8°</u>	
UV-BLDG22-381 Sample Number <u>AR</u> Initials Date <u>1-11-18</u> 24 HR Time <u>08:00</u> COC	Building: <u>22</u>	*Outlet <u>KF</u>
	Floor: <u>1</u>	Manufacturer: <u>N/A</u>
	Location: <u>Rm 381</u>	Filter: Aerator:
	Description/Observation/Comments: <u>12.5</u>	

28

29

30

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1/11/18 Time: 12:00 AM/PM

Received by: [Signature] Date: 1/11/18 Time: 12:02 AM/PM / 10:00



18A0618

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Pg 11 of 33

Date of Sampling: 1/11/18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Andy Roed

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
UV-BLDG22-380 Sample Number <u>AR</u> Initials Date: <u>1-11-18</u> 24 HR Time: <u>08:03</u> COC	Building: <u>22</u> *Outlet <u>KF</u> Floor: <u>1</u> Manufacturer: <u>N/A</u> Location: <u>Rm 380</u> Filter: Aerator: Description/Observation/Comments: <u>12.2°</u>
UV-BLDG22-379 Sample Number <u>AR</u> Initials Date: <u>1-11-18</u> 24 HR Time: <u>08:04</u> COC	Building: <u>22</u> *Outlet <u>KF</u> Floor: <u>1</u> Manufacturer: <u>N/A</u> Location: <u>Rm 379</u> Filter: Aerator: Description/Observation/Comments: <u>10.1°</u>
UV-BLDG22-382 Sample Number <u>AR</u> Initials Date: <u>1-11-18</u> 24 HR Time: <u>08:05</u> COC	Building: <u>22</u> *Outlet <u>KF</u> Floor: <u>1</u> Manufacturer: <u>N/A</u> Location: <u>Rm 382</u> Filter: Aerator: Description/Observation/Comments: <u>12.2°</u>

31

32

33

Z:\Clients\Chico State\17-4612 Campus Wide Water Testing - Lead\Water COC & Forms\Water Request Andy.wpd

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1/11/18 Time: 12:00 AM/PM

Received by: [Signature] Date: 1/11/18 Time: 12:02 AM/PM / 10:00



ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX



Pg 12 of 33

Date of Sampling: 1/11/18

Lab: Basic Laboratory, Inc.
2218 Railroad Avenue
Redding, CA 96001

Basic Laboratory, Inc.
3860 Morrow Lane, # F
Chico, CA 95928

Job Number: 17-4612

Collected by: Andy Roed

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
UV-BLDG22-391 Sample Number Date <u>AR</u> <u>0807</u> Initials 24 HR Time COC	Building: <u>22</u> *Outlet <u>KF</u>
	Floor: <u>2</u> Manufacturer: <u>N/A</u>
	Location: <u>Rm 391</u> Filter: Aerator:
	Description/Observation/Comments: <u>10.9°</u>
UV-BLDG22-392 Sample Number Date <u>AR</u> <u>08:07</u> Initials 24 HR Time COC	Building: <u>22</u> *Outlet <u>KF</u>
	Floor: <u>2</u> Manufacturer: <u>N/A</u>
	Location: <u>Rm 392</u> Filter: Aerator:
	Description/Observation/Comments: <u>12.3°</u>
UV-BLDG22-393 Sample Number Date <u>AR</u> <u>08:08</u> Initials 24 HR Time COC	Building: <u>22</u> *Outlet <u>KF</u>
	Floor: <u>2</u> Manufacturer: <u>N/A</u>
	Location: <u>Rm 393</u> Filter: Aerator:
	Description/Observation/Comments: <u>12.6°</u>

34

35

36

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1/11/18 Time: 12:00 AM/PM
 Received by: [Signature] Relinquished By: [Signature] Date: 1/11/18 / 1/12/18 Time: 12:02 AM/PM / 10:00



18A0618

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Pg 13 of 33

Date of Sampling: 1/11/18

Lab: Basic Laboratory, Inc.
2218 Railroad Avenue
Redding, CA 96001

Basic Laboratory, Inc.
3860 Morrow Lane, # F
Chico, CA 95928

Job Number: 17-4612

Collected by: Andy Roed

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, metzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
UV-BLDG22-394 Sample Number <u>AR</u> Initials Date: <u>1-11-18</u> 24 HR Time: <u>08:09</u> COC	Building: <u>22</u> *Outlet <u>KF</u> Floor: <u>2</u> Manufacturer: <u>N/A</u> Location: <u>Rm 394</u> Filter: Aerator: Description/Observation/Comments: <u>12.2°</u>
UV-BLDG22-384 Sample Number <u>AR</u> Initials Date: <u>1-11-18</u> 24 HR Time: <u>08:11</u> COC	Building: <u>22</u> *Outlet <u>KF</u> Floor: <u>1</u> Manufacturer: <u>N/A</u> Location: <u>Rm 384</u> Filter: Aerator: Description/Observation/Comments: <u>10.7</u>
UV-BLDG22-383 Sample Number <u>AR</u> Initials Date: <u>1-11-18</u> 24 HR Time: <u>08:12</u> COC	Building: <u>22</u> *Outlet <u>KF</u> Floor: <u>1</u> Manufacturer: <u>N/A</u> Location: <u>Rm 383</u> Filter: Aerator: Description/Observation/Comments: <u>9.4°</u>

37

38

39

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1/11/18 Time: 12:00 AM/PM

Received by: [Signature] Date: 1/11/18/1/12/18 Time: 12:02 AM/PM/10:00



ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Pg 14 of 33

Date of Sampling: 1/11/18

Lab: Basic Laboratory, Inc.
2218 Railroad Avenue
Redding, CA 96001

Basic Laboratory, Inc.
3860 Morrow Lane, # F
Chico, CA 95928

Job Number: 17-4612

Collected by: Andy Roed

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
UV-BLDG22-385 Sample Number <u>AR</u> Initials Date <u>1-11-18</u> <u>08:12</u> 24 HR Time COC	Building: <u>22</u> *Outlet <u>KF</u> Floor: <u>1</u> Manufacturer: <u>N/A</u> Location: <u>Rm 385</u> Filter: Aerator: Description/Observation/Comments: <u>10.1</u>
UV-BLDG22-386 Sample Number <u>AR</u> Initials Date <u>1-11-18</u> <u>08:13</u> 24 HR Time COC	Building: <u>22</u> *Outlet <u>KF</u> Floor: <u>1</u> Manufacturer: <u>N/A</u> Location: <u>Rm 386</u> Filter: Aerator: Description/Observation/Comments: <u>11.6</u>
UV-BLDG22-396 Sample Number <u>AR</u> Initials Date <u>1-11-18</u> <u>08:15</u> 24 HR Time COC	Building: <u>22</u> *Outlet <u>KF</u> Floor: <u>2</u> Manufacturer: <u>N/A</u> Location: <u>Rm 396</u> Filter: Aerator: Description/Observation/Comments: <u>10.3</u>

40

41

42

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1/11/18 Time: 12:00 AM/PM

Received by: [Signature] Date: 1/11/18 Time: 12:02 AM/PM 10:00



ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Pg 15 of 33

Date of Sampling: 1 / 11 / 18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Andy Roed

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
UV-BLDG22-395 Sample Number <u>AR</u> Initials <u>1-11-18</u> Date <u>08:16</u> 24 HR Time COC	Building: <u>22</u> *Outlet <u>KF</u> Floor: <u>2</u> Manufacturer: <u>N/A</u> Location: <u>Rm 395</u> Filter: Aerator: Description/Observation/Comments: <u>10.6</u>
UV-BLDG22-397 Sample Number <u>AR</u> Initials <u>1-11-18</u> Date <u>08:17</u> 24 HR Time COC	Building: <u>22</u> *Outlet <u>KF</u> Floor: <u>2</u> Manufacturer: <u>N/A</u> Location: <u>Rm 397</u> Filter: Aerator: Description/Observation/Comments: <u>10.6</u>
UV-BLDG22-398 Sample Number <u>AR</u> Initials <u>1-11-18</u> Date <u>08:17</u> 24 HR Time COC	Building: <u>22</u> *Outlet <u>KF</u> Floor: <u>2</u> Manufacturer: <u>N/A</u> Location: <u>Rm 398</u> Filter: Aerator: Description/Observation/Comments: <u>11.3</u>

43

44

45

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1 / 11 / 18 Time: 12:00 AM/PM
 Received by: [Signature] Date: 1 / 11 / 18 Time: 12:02 AM/PM / 10:00



18A0618

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Pg 16 of 33

Date of Sampling: 1/11/18

Lab: Basic Laboratory, Inc.
2218 Railroad Avenue
Redding, CA 96001

Basic Laboratory, Inc.
3860 Morrow Lane, # F
Chico, CA 95928

Job Number: 17-4612

Collected by: Andy Roed

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
UV-BLDG22-387 Sample Number <u>AR</u> Date <u>1-11-18</u> Initials <u>AR</u> 24 HR Time <u>08:20</u> COC	Building: <u>22</u> *Outlet <u>K F</u> Floor: <u>1</u> Manufacturer: <u>N/A</u> Location: <u>Rm 387</u> Filter: Aerator: Description/Observation/Comments: <u>10.1°</u>
UV-BLDG22-388 Sample Number <u>AR</u> Date <u>1-11-18</u> Initials <u>AR</u> 24 HR Time <u>08:21</u> COC	Building: <u>22</u> *Outlet <u>K F</u> Floor: <u>1</u> Manufacturer: <u>N/A</u> Location: <u>Rm 388</u> Filter: Aerator: Description/Observation/Comments: <u>825 TW 9.6°</u>
UV-BLDG22-399 Sample Number <u>AR</u> Date <u>1-11-18</u> Initials <u>AR</u> 24 HR Time <u>08:22</u> COC	Building: <u>22</u> *Outlet <u>K F</u> Floor: <u>1</u> Manufacturer: <u>NA</u> Location: <u>Rm 399</u> Filter: Aerator: Description/Observation/Comments: <u>10.1°</u>

46

47

48

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1/11/18 Time: 12:00 AM/PM

Received by: [Signature] Date: 1/11/18 Time: 12:02 AM/PM 10:00



ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
 ROCKLIN, CA 95677
 (916) 632-6800 PHONE (916) 632-6812 FAX

pg 17 of 33

Date of Sampling: 1/11/18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
 Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Andy Roed

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
 Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information	
UV-BLDG22-400 Sample Number <u>AR</u> Initials Date <u>1-11-18</u> <u>08:23</u> 24 HR Time COC	Building: <u>22</u>	*Outlet <u>KF</u>
	Floor: <u>2</u>	Manufacturer: <u>N/A</u>
	Location: <u>Rm 400</u>	Filter: Aerator:
	Description/Observation/Comments: <u>9.4°</u>	
UV-BLDG23-K01C Sample Number <u>AR</u> Initials Date <u>1-11-18</u> <u>08:27</u> 24 HR Time COC	Building: <u>23</u>	*Outlet <u>KF</u>
	Floor: <u>1</u>	Manufacturer: <u>N/A</u>
	Location: <u>9 Kitchen</u>	Filter: Aerator:
	Description/Observation/Comments: <u>8.5°</u>	
UV-BLDG23-402 Sample Number <u>AR</u> Initials Date <u>1-11-18</u> <u>08:28</u> 24 HR Time COC	Building: <u>23</u>	*Outlet <u>BF</u>
	Floor: <u>1</u>	Manufacturer: <u>CFG</u>
	Location: <u>Rm 402</u>	Filter: Aerator:
	Description/Observation/Comments: <u>8.9°</u>	

49
50
51

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1/11/18 Time: 12:00 AM/PM

Received by: [Signature] Date: 1/11/18 Time: 12:02 AM/PM
1-12-18 10:00



ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
 ROCKLIN, CA 95677
 (916) 632-6800 PHONE (916) 632-6812 FAX

Pg 18 of 33

Date of Sampling: 1/11/18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
 Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Andy Roed

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
 Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, mmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information	
UV-BLDG23-403 Sample Number <u>AR</u> Initials Date <u>1-11-18</u> 24 HR Time <u>08:29</u> COC	Building: <u>23</u>	*Outlet <u>BF</u>
	Floor: <u>1</u>	Manufacturer: <u>CFG</u>
	Location: <u>Rm 403</u>	Filter: Aerator:
	Description/Observation/Comments: <u>9.6</u>	
UV-BLDG23-404 Sample Number <u>AR</u> Initials Date <u>1-11-18</u> 24 HR Time <u>08:29</u> COC	Building: <u>23</u>	*Outlet <u>BF</u>
	Floor: <u>1</u>	Manufacturer: <u>CFG</u>
	Location: <u>Rm 404</u>	Filter: Aerator:
	Description/Observation/Comments: <u>9.8°C</u>	
UV-BLDG23-401 Sample Number <u>AR</u> Initials Date <u>1-11-18</u> 24 HR Time <u>08:30</u> COC	Building: <u>23</u>	*Outlet <u>BF</u>
	Floor: <u>1</u>	Manufacturer: <u>CFG</u>
	Location: <u>Rm 401</u>	Filter: Aerator:
	Description/Observation/Comments: <u>8.9°C</u>	

52
53
54

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1/11/18 Time: 12:00 AM/PM
 Received by: [Signature] Date: 1/11/18 / 1-12-18 Time: 12:02 AM/PM / 10:00



18AUG10

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Pg 19 of 33

Date of Sampling: 1/11/18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Andy Roed

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
UV-BLDG23-K02B Sample Number <u>AR</u> Initials Date <u>1-11-18</u> 24 HR Time <u>0833</u> COC	Building: <u>23</u> Floor: <u>2</u> Location: <u>Kitchen</u> *Outlet <u>KF</u> Manufacturer: <u>N/A</u> Filter: Aerator: Description/Observation/Comments: <u>10.7</u>
UV-BLDG23-419 Sample Number <u>AR</u> Initials Date <u>1-11-18</u> 24 HR Time <u>08:34</u> COC	Building: <u>23</u> Floor: <u>2</u> Location: <u>Room 419</u> *Outlet <u>BF</u> Manufacturer: <u>CFG</u> Filter: Aerator: Description/Observation/Comments: <u>9.0'</u>
UV-BLDG23-418 Sample Number <u>AR</u> Initials Date <u>1-11-18</u> 24 HR Time <u>08:34</u> COC	Building: <u>23</u> Floor: <u>2</u> Location: <u>Rm 418</u> *Outlet <u>BF</u> Manufacturer: <u>CFG</u> Filter: Aerator: Description/Observation/Comments: <u>10.3"</u>

55
56
57

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1/11/18 Time: 12:00 AM/PM

Received by: [Signature] Date: 1/11/18 Time: 12:02 AM/PM
[Signature] Date: 1/12/18 Time: 10:00



18A0618

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Pg 20 of 33

Date of Sampling: 1/11/18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Andy Roed

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, metzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
UV-BLDG23-420 Sample Number <u>AR</u> Initials	Building: <u>23</u> Floor: <u>2</u> Location: <u>Rm 420</u> Description/Observation/Comments: <u>10.1°</u>
<u>1-11-18</u> Date <u>08:35</u> 24 HR Time COC	*Outlet <u>BF</u> Manufacturer: <u>CFG</u> Filter: Aerator:
UV-BLDG23-417 Sample Number <u>AR</u> Initials	Building: <u>23</u> Floor: <u>2</u> Location: <u>Rm 417</u> Description/Observation/Comments: <u>11.4°</u>
<u>1-11-18</u> Date <u>08:36</u> 24 HR Time COC	*Outlet <u>BF</u> Manufacturer: <u>CFG</u> Filter: Aerator:
UV-BLDG23-K02A Sample Number <u>AR</u> Initials	Building: <u>23</u> Floor: <u>2</u> Location: <u>Kitchen</u> Description/Observation/Comments: <u>10.2</u>
<u>1-11-18</u> Date <u>08:38</u> 24 HR Time COC	*Outlet <u>KF</u> Manufacturer: <u>N/A</u> Filter: Aerator:

58

59

60

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1/11/18 Time: 12:01 AM/PM

Received by: [Signature] Date: 1/11/18 Time: 12:02 AM/PM
[Signature] Relinquished By: [Signature] Date: 1-12-18 Time: 10:00



18A0618

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

pg 21 of 33

Date of Sampling: 1 / 11 / 18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Andy Roed

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, metzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information	
UV-BLDG23-423 Sample Number <u>AR</u> Initials Date <u>1-11-18</u> 24 HR Time <u>08:38</u> COC	Building: <u>23</u>	*Outlet <u>BF</u>
	Floor: <u>2</u>	Manufacturer: <u>CFG</u>
	Location: <u>Rm 423</u>	Filter: Aerator:
	Description/Observation/Comments: <u>9.4</u>	
UV-BLDG23-422 Sample Number <u>AR</u> Initials Date <u>1-11-18</u> 24 HR Time <u>08:39</u> COC	Building: <u>23</u>	*Outlet <u>BF</u>
	Floor: <u>2</u>	Manufacturer: <u>CFG</u>
	Location: <u>Rm 422</u>	Filter: Aerator:
	Description/Observation/Comments: <u>10.4</u>	
UV-BLDG23-424 Sample Number <u>AR</u> Initials Date <u>1-11-18</u> 24 HR Time <u>08:40</u> COC	Building: <u>23</u>	*Outlet <u>BF</u>
	Floor: <u>2</u>	Manufacturer: <u>CFG</u>
	Location: <u>Rm 424</u>	Filter: Aerator:
	Description/Observation/Comments: <u>8.4</u>	

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1 / 11 / 18 Time: 12:00 AM/PM

Received by: [Signature] Date: 1 / 11 / 18 Time: 12:02 AM/PM 10:00



18A0610

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Pg 22 of 33

Date of Sampling: 1/11/18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Andy Roed

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, metzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
UV-BLDG23-421 Sample Number <u>AR</u> Initials Date: <u>1-11-18</u> 24 HR Time: <u>08:41</u> COC	Building: <u>23</u> Floor: <u>2</u> Location: <u>Rm 421</u> Description/Observation/Comments: <u>9.4</u> *Outlet <u>BF</u> Manufacturer: <u>CFG</u> Filter: Aerator:
UV-BLDG24-K01C Sample Number <u>AR</u> Initials Date: <u>1-11-18</u> 24 HR Time: <u>08:47</u> COC	Building: <u>24</u> Floor: <u>1</u> Location: <u>Kitchen</u> Description/Observation/Comments: <u>9.8</u> <u>& spray nozzle</u> *Outlet <u>KF</u> Manufacturer: <u>N/A</u> Filter: Aerator:
UV-BLDG24-426 Sample Number <u>AR</u> Initials Date: <u>1-11-18</u> 24 HR Time: <u>08:49</u> COC	Building: <u>24</u> Floor: <u>1</u> Location: <u>Rm 426</u> Description/Observation/Comments: <u>10.4</u> *Outlet <u>BF</u> Manufacturer: <u>CFG</u> Filter: Aerator:

64
65
66

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1/11/18 Time: 12:00 AM/PM
 Received by: [Signature] Relinquished by: [Signature] Date: 1/11/18 / 1-12-18 Time: 12:02 AM/PM / 10:00



18A0610

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Pg 23 of 33

Date of Sampling: 1/11/18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Andy Roed

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information	
UV-BLDG24-427 Sample Number <u>AR</u> Initials	<u>1-11-18</u> Date <u>08:50</u> 24 HR Time COC	Building: <u>24</u> *Outlet <u>BF</u> Floor: <u>1</u> Manufacturer: <u>CFG</u> Location: <u>Rm 427</u> Filter: Aerator: Description/Observation/Comments: <u>10.1°</u>
UV-BLDG24-425 Sample Number <u>AR</u> Initials	<u>1-11-18</u> Date <u>08:51</u> 24 HR Time COC	Building: <u>24</u> *Outlet <u>BF</u> Floor: <u>1</u> Manufacturer: <u>CFG</u> Location: <u>Rm 425</u> Filter: Aerator: Description/Observation/Comments: <u>11.6°</u>
UV-BLDG24-428 Sample Number <u>AR</u> Initials	<u>1-11-18</u> Date <u>08:52</u> 24 HR Time COC	Building: <u>24</u> *Outlet <u>BF</u> Floor: <u>1</u> Manufacturer: <u>CFG</u> Location: <u>Rm 428</u> Filter: Aerator: Description/Observation/Comments: <u>10.6</u>

67
68
69

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1/11/18 Time: 12:00 AM/PM

Received by: [Signature] Date: 1/11/18 Time: 12:02 AM/PM
Requested by [Signature] Date: 1/12/18 Time: 10:00



18A0618

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Pg 24 of 33

Date of Sampling: 1/11/18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Andy Roed

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
UV-BLDG24-K01A Sample Number <u>AR</u> Initials	Building: <u>24</u> Floor: <u>1</u> Location: <u>Kitchen</u> Description/Observation/Comments: <u>10.1</u>
<u>1-11-18</u> Date <u>08:54</u> 24 HR Time COC	*Outlet <u>KF</u> Manufacturer: <u>N/A</u> Filter: Aerator:
UV-BLDG24-435 Sample Number <u>AR</u> Initials	Building: <u>24</u> Floor: <u>1</u> Location: <u>Rm 435</u> Description/Observation/Comments: <u>10.3°</u>
<u>1-11-18</u> Date <u>08:55</u> 24 HR Time COC	*Outlet <u>BF</u> Manufacturer: <u>CFG</u> Filter: Aerator:
UV-BLDG24-434 Sample Number <u>AR</u> Initials	Building: <u>24</u> Floor: <u>1</u> Location: <u>Rm 434</u> Description/Observation/Comments: <u>9.1</u>
<u>1-11-18</u> Date <u>08:56</u> 24 HR Time COC	*Outlet <u>BF</u> Manufacturer: <u>CFG</u> Filter: Aerator:

70

71

72

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1/11/18 Time: 12:00 AM/PM

Received by: [Signature] Date: 1/11/18 Time: 12:02 AM/PM
Relinquished By: [Signature] Date: 1-12-18



18A0618

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Pg 25 of 33

Date of Sampling: 1/11/18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Andy Roed

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, metzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
UV-BLDG24-433 Sample Number <u>AR</u> Initials	Building: <u>24</u> *Outlet <u>BF</u> Floor: <u>1</u> Manufacturer: <u>CFG</u> Location: <u>Rm 433</u> Filter: Aerator: Date: <u>1-11-18</u> Time: <u>08:57</u> 24 HR Time COC Description/Observation/Comments: <u>9.8°</u>
UV-BLDG24-436 Sample Number <u>AR</u> Initials	Building: <u>24</u> *Outlet <u>BF</u> Floor: <u>1</u> Manufacturer: <u>CFG</u> Location: <u>Rm 436</u> Filter: Aerator: Date: <u>1-11-18</u> * Time: <u>08:58</u> PSD 24 HR Time COC Description/Observation/Comments: <u>9.7°</u> <u>* per bottle</u>
UV-BLDG24-K02A Sample Number <u>AR</u> Initials	Building: <u>24</u> *Outlet <u>KF</u> Floor: <u>2</u> Manufacturer: <u>N/A</u> Location: <u>Kitchen</u> Filter: Aerator: Date: <u>1-11-18</u> Time: <u>09:01</u> 24 HR Time COC Description/Observation/Comments: <u>1.3°</u>

73

74

75

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1/11/18 Time: 12:00 AM/PM

Received by: [Signature] Date: 1/12/18 Time: 12:02 AM/PM 10:00



18A0618

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Pg 26 of 33

Date of Sampling: 1/11/18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Andy Roed

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
UV-BLDG24-447 Sample Number <u>AR</u> Initials <u>1-11-18</u> Date <u>0902</u> 24 HR Time COC	Building: <u>24</u> Floor: <u>2</u> Location: <u>Rm 447</u> Description/Observation/Comments: <u>10.4"</u> *Outlet <u>BF</u> Manufacturer: <u>CFG</u> Filter: Aerator:
UV-BLDG24-446 Sample Number <u>AR</u> Initials <u>1-11-18</u> Date <u>09:03</u> 24 HR Time COC	Building: <u>24</u> Floor: <u>2</u> Location: <u>Rm 446</u> Description/Observation/Comments: <u>4.3</u> *Outlet <u>BF</u> Manufacturer: <u>CFG</u> Filter: Aerator:
UV-BLDG24-445 Sample Number <u>AR</u> Initials <u>1-11-18</u> Date <u>09:03</u> 24 HR Time COC	Building: <u>24</u> Floor: <u>2</u> Location: <u>Rm 445</u> Description/Observation/Comments: <u>4.8</u> *Outlet <u>BF</u> Manufacturer: <u>CFG</u> Filter: Aerator:

76
77
78

Z:\Clients\Chico State\17-4612 Campus Wide Water Testing - Lead\Water COC & Forms\Water Request Andy.wpd

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1/11/18 Time: 12:00 AM/PM
 Received by: [Signature] Date: 1/11/18 Time: 12:02 AM/PM/10:00
Requested by



18A0610

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

pg 27 of 33

Date of Sampling: 1/11/18

Lab: Basic Laboratory, Inc. Basic Laboratory, Inc.
2218 Railroad Avenue 3860 Morrow Lane, # F
Redding, CA 96001 Chico, CA 95928

Job Number: 17-4612

Collected by: Andy Roed

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
<u>UV-BLDG24-448</u> Sample Number <u>AR</u> Initials <u>1-11-18</u> Date <u>09:04</u> 24 HR Time COC	Building: <u>24</u> Floor: <u>2</u> Location: <u>Rm 448</u> Description/Observation/Comments: <u>4.1°</u> *Outlet <u>BF</u> Manufacturer: <u>CFG</u> Filter: Aerator:
<u>UV-BLD25-KO1A</u> Sample Number <u>AR</u> Initials <u>1-11-18</u> Date <u>09:08*</u> 24 HR Time COC	Building: <u>25</u> Floor: <u>1</u> Location: <u>Kitchen</u> Description/Observation/Comments: <u>4.3</u> <u>*9:08 per bottle</u> *Outlet <u>KF</u> Manufacturer: <u>N/A</u> Filter: Aerator:
<u>UV-BLDG25-450</u> Sample Number <u>AR</u> Initials <u>1-11-18</u> Date <u>0909</u> 24 HR Time COC	Building: <u>25</u> Floor: <u>1</u> Location: <u>Rm 450</u> Description/Observation/Comments: <u>4.9</u> *Outlet <u>BF</u> Manufacturer: <u>CFG</u> Filter: Aerator:

79

80

81

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1/11/18 Time: 12:00 AM/PM

Received by: [Signature] Date: 1/11/18 Time: 12:07 AM/PM/10:00



18A0618

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

pg 28 of 33

Date of Sampling: 1/11/18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Andy Roed

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample		Information	
UV-BLDG25-449	<u>1-11-18</u>	Building: <u>25</u>	*Outlet <u>BF</u>
Sample Number	Date	Floor: <u>1</u>	Manufacturer: <u>CFG</u>
<u>AR</u>	<u>09:11</u>	Location: <u>Rm 449</u>	Filter: Aerator:
Initials	24 HR Time	Description/Observation/Comments: <u>6.1</u>	
	BOTTLE		
UV-BLDG25-451	<u>1-11-18</u>	Building: <u>25</u>	*Outlet <u>BF</u>
Sample Number	Date	Floor: <u>1</u>	Manufacturer: <u>CFG</u>
<u>AR</u>	<u>9:10</u> <u>09:10</u>	Location: <u>Rm 45</u>	Filter: Aerator:
Initials	24 HR Time	Description/Observation/Comments: <u>5.3</u> <u>* off bottle - clarification</u>	
	COC		
UV-BLDG25-452	<u>1-11-18</u>	Building: <u>25</u>	*Outlet <u>BF</u>
Sample Number	Date	Floor: <u>1</u>	Manufacturer: <u>CFG</u>
<u>AR</u>	<u>09:12</u>	Location: <u>Rm 252</u>	Filter: Aerator:
Initials	24 HR Time	Description/Observation/Comments: <u>5.8</u>	
	COC		

82

83

84

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1/11/18 Time: 12:00 AM/PM

Received by: [Signature] Relinquished by: [Signature] Date: 1/11/18 / 1-12-18 Time: 12:02 AM/PM



ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Pg 29 of 33

Date of Sampling: 1/11/18

Lab: Basic Laboratory, Inc. Basic Laboratory, Inc.
2218 Railroad Avenue 3860 Morrow Lane, # F
Redding, CA 96001 Chico, CA 95928

Job Number: 17-4612

Collected by: Andy Roed

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
<u>UV-BLDG-KO2A</u> <u>1-11-18</u> Sample Number Date <u>AR</u> <u>0913</u> Initials 24 HR Time COC	Building: <u>25</u> *Outlet <u>KF</u> Floor: <u>1</u> Manufacturer: <u>N/A</u> Location: <u>Kitchen</u> Filter: Aerator: Description/Observation/Comments: <u>1.4°</u>
<u>UV-BLDG25-455</u> <u>1-11-18</u> Sample Number Date <u>AR</u> <u>09:14</u> Initials 24 HR Time COC	Building: <u>25</u> *Outlet <u>BF</u> Floor: <u>1</u> Manufacturer: <u>CFG</u> Location: <u>Rm 455</u> Filter: Aerator: Description/Observation/Comments: <u>0.4°</u>
<u>UV-BLDG25-456</u> <u>1-11-18</u> Sample Number Date <u>AR</u> <u>09:15</u> Initials 24 HR Time COC	Building: <u>25</u> *Outlet <u>BF</u> Floor: <u>1</u> Manufacturer: <u>CFG</u> Location: <u>Rm 456</u> Filter: Aerator: Description/Observation/Comments: <u>2.5°</u>

85
86
87

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1/11/18 Time: 12:00 AM/PM

Received by: [Signature] Date: 1/11/18 Time: 12:02 AM/PM
[Signature] Date: 1-12-18 Time: 10:00



18A0618

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

pg 30 of 33

Date of Sampling: 1/11/18

Lab: Basic Laboratory, Inc. Basic Laboratory, Inc.
2218 Railroad Avenue 3860 Morrow Lane, # F
Redding, CA 96001 Chico, CA 95928

Job Number: 17-4612

Collected by: Andy Roed

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
UV-BLDG25-453 Sample Number <u>AR</u> Initials <u>1-11-18</u> Date <u>09:16</u> 24 HR Time COC	Building: <u>25</u> *Outlet <u>BF</u> Floor: <u>1</u> Manufacturer: <u>CFG</u> Location: <u>Rm 453</u> Filter: Aerator: Description/Observation/Comments: <u>1.3°</u>
UV-BLDG25-454 Sample Number <u>AR</u> Initials <u>1-11-18</u> Date <u>09:16</u> 24 HR Time COC	Building: <u>25</u> *Outlet <u>BF</u> Floor: <u>1</u> Manufacturer: <u>CFG</u> Location: <u>Rm 454</u> Filter: Aerator: Description/Observation/Comments: <u>0.2°</u>
UV-BLDG25-104A Sample Number <u>AR</u> Initials <u>1-11-18</u> Date <u>09:18</u> 24 HR Time COC	Building: <u>25</u> *Outlet <u>KF</u> Floor: <u>2</u> Manufacturer: <u>N/A</u> Location: <u>Kitchen</u> Filter: Aerator: Description/Observation/Comments: <u>2.8</u>

88

89

90

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1/11/18 Time: 12:00 AM/PM

Received by: [Signature] Date: 1/11/18 Time: 12:02 AM/PM / 10:00



ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

pg 31 of 33

Date of Sampling: 1/11/18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Andy Roed

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information												
UV-BLDG25-462 Sample Number <u>AR</u> Initials	<table border="1"> <tr> <td><u>1-11-18</u> Date</td> <td>Building: <u>25</u></td> <td>*Outlet <u>BF</u></td> </tr> <tr> <td><u>09:19</u> 24 HR Time</td> <td>Floor: <u>2</u></td> <td>Manufacturer: <u>CFG</u></td> </tr> <tr> <td><u>COC</u></td> <td>Location: <u>Rm 462</u></td> <td>Filter: Aerator:</td> </tr> <tr> <td></td> <td colspan="2">Description/Observation/Comments: <u>8.8</u></td> </tr> </table>	<u>1-11-18</u> Date	Building: <u>25</u>	*Outlet <u>BF</u>	<u>09:19</u> 24 HR Time	Floor: <u>2</u>	Manufacturer: <u>CFG</u>	<u>COC</u>	Location: <u>Rm 462</u>	Filter: Aerator:		Description/Observation/Comments: <u>8.8</u>	
<u>1-11-18</u> Date	Building: <u>25</u>	*Outlet <u>BF</u>											
<u>09:19</u> 24 HR Time	Floor: <u>2</u>	Manufacturer: <u>CFG</u>											
<u>COC</u>	Location: <u>Rm 462</u>	Filter: Aerator:											
	Description/Observation/Comments: <u>8.8</u>												
UV-BLDG25-463 Sample Number <u>AR</u> Initials	<table border="1"> <tr> <td><u>1-11-18</u> Date</td> <td>Building: <u>25</u></td> <td>*Outlet <u>BF</u></td> </tr> <tr> <td><u>0920</u> 24 HR Time</td> <td>Floor: <u>2</u></td> <td>Manufacturer: <u>CFG</u></td> </tr> <tr> <td><u>COC</u></td> <td>Location: <u>Rm 463</u></td> <td>Filter: Aerator:</td> </tr> <tr> <td></td> <td colspan="2">Description/Observation/Comments: <u>8.4</u></td> </tr> </table>	<u>1-11-18</u> Date	Building: <u>25</u>	*Outlet <u>BF</u>	<u>0920</u> 24 HR Time	Floor: <u>2</u>	Manufacturer: <u>CFG</u>	<u>COC</u>	Location: <u>Rm 463</u>	Filter: Aerator:		Description/Observation/Comments: <u>8.4</u>	
<u>1-11-18</u> Date	Building: <u>25</u>	*Outlet <u>BF</u>											
<u>0920</u> 24 HR Time	Floor: <u>2</u>	Manufacturer: <u>CFG</u>											
<u>COC</u>	Location: <u>Rm 463</u>	Filter: Aerator:											
	Description/Observation/Comments: <u>8.4</u>												
UV-BLDG25-464 Sample Number <u>AR</u> Initials	<table border="1"> <tr> <td><u>1-11-18</u> Date</td> <td>Building: <u>25</u></td> <td>*Outlet <u>BF</u></td> </tr> <tr> <td><u>09:21</u> 24 HR Time</td> <td>Floor: <u>2</u></td> <td>Manufacturer: <u>CFG</u></td> </tr> <tr> <td><u>COC</u></td> <td>Location: <u>Rm 464</u></td> <td>Filter: Aerator:</td> </tr> <tr> <td></td> <td colspan="2">Description/Observation/Comments: <u>4.3</u></td> </tr> </table>	<u>1-11-18</u> Date	Building: <u>25</u>	*Outlet <u>BF</u>	<u>09:21</u> 24 HR Time	Floor: <u>2</u>	Manufacturer: <u>CFG</u>	<u>COC</u>	Location: <u>Rm 464</u>	Filter: Aerator:		Description/Observation/Comments: <u>4.3</u>	
<u>1-11-18</u> Date	Building: <u>25</u>	*Outlet <u>BF</u>											
<u>09:21</u> 24 HR Time	Floor: <u>2</u>	Manufacturer: <u>CFG</u>											
<u>COC</u>	Location: <u>Rm 464</u>	Filter: Aerator:											
	Description/Observation/Comments: <u>4.3</u>												

91

92

93

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1/11/18 Time: 12:00 AM/PM

Received by: [Signature] Date: 1/11/18 Time: 12:02 AM/PM
Requested By Date: 1/12/18 Time: 12:00 AM/PM



18A0618

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

pg 32 of 33

Date of Sampling: 1/11/18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Andy Roed

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
UV-BLDG25-461 Sample Number <u>AR</u> Initials <u>1-11-18</u> Date <u>0921</u> 24 HR Time COC	Building: <u>25</u> Floor: <u>2</u> Location: <u>Rm 461</u> Description/Observation/Comments: <u>4.6°</u> *Outlet <u>BF</u> Manufacturer: <u>CFG</u> Filter: Aerator:
UV-BLDG25-K03A Sample Number <u>AR</u> Initials <u>1-11-18</u> Date <u>0923</u> 24 HR Time COC	Building: <u>25</u> Floor: <u>2</u> Location: <u>R Kitchen</u> Description/Observation/Comments: <u>4.5°</u> *Outlet <u>KF</u> Manufacturer: <u>CFG</u> Filter: Aerator:
UV-BLDG25-459 Sample Number <u>AR</u> Initials <u>1-11-18</u> Date <u>0924</u> 24 HR Time COC	Building: <u>25</u> Floor: <u>2</u> Location: <u>Rm 459</u> Description/Observation/Comments: <u>7.8°</u> *Outlet <u>BF</u> Manufacturer: <u>CFG</u> Filter: Aerator:

94
95
96

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1/11/18 Time: 12:00 AM/PM

Received by: [Signature] Date: 1/11/18 Time: 12:02 AM/PM
1-12-18 10:00

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
 ROCKLIN, CA 95677
 (916) 632-6800 PHONE (916) 632-6812 FAX

Pg 33 of 33

Date of Sampling: 1/11/18

Lab: Basic Laboratory, Inc. Basic Laboratory, Inc.
 2218 Railroad Avenue 3860 Morrow Lane, # F
 Redding, CA 96001 Chico, CA 95928

Job Number: 17-4612

Collected by: Andy Roed

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
 Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information	
UV-BLDG25-458 Sample Number <u>AR</u> Initials Date <u>1-11-18</u> 24 HR Time COC <u>09:25</u>	Building: <u>25</u>	*Outlet <u>BF</u>
	Floor: <u>2</u>	Manufacturer: <u>CFG</u>
	Location: <u>Rm 458</u>	Filter: Aerator:
	Description/Observation/Comments: <u>5.4°</u>	
UV-BLDG25-460 Sample Number <u>AR</u> Initials Date <u>1-11-18</u> 24 HR Time COC <u>09:26</u>	Building: <u>25</u>	*Outlet <u>BF</u>
	Floor: <u>2</u>	Manufacturer: <u>CFG</u>
	Location: <u>Rm 460</u>	Filter: Aerator:
	Description/Observation/Comments: <u>3.8°</u>	
UV-BLDG25-457 Sample Number <u>AR</u> Initials Date <u>1-11-18</u> 24 HR Time COC <u>09:27</u>	Building: <u>25</u>	*Outlet <u>BF</u>
	Floor: <u>2</u>	Manufacturer: <u>CFG</u>
	Location: <u>Rm 457</u>	Filter: Aerator:
	Description/Observation/Comments: <u>3.2°</u>	

91
96
99

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1/11/18 Time: 12:00 AM/PM

Received by: [Signature] Date: 1/11/18 Time: 12:02 AM/PM
 Requisitioned By: [Signature] Date: 1/12/18 Time: 10:00