



www.basiclab.com

2218 Railroad Avenue
Redding, California 96001

voice 530.243.7234
fax 530.243.7494

3860 Morrow Lane, Suite F
Chico, California 95928

voice 530.894.8966
fax 530.894.5143

January 08, 2018

Lab ID: 18A0244


RICHARD BEALL
ENTEK CONSULTING GROUP
4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
RE: CHICO STATE LEAD TESTING 17-4612


Dear RICHARD BEALL ,

Enclosed are the analysis results for Work Order number 18A0244. All analyses were performed under strict adherence to our established Quality Assurance Plan. Any abnormalities are listed in the qualifier section of this report.

If you have any questions regarding these results, please feel free to contact us at any time. We appreciate the opportunity to service your environmental testing needs.

Sincerely,


For



Ricky D. Jensen
Laboratory Director

California ELAP Certification Number 1677



www.basiclab.com

2218 Railroad Avenue voice 530.243.7234
 Redding, California 96001 fax 530.243.7494


3860 Morrow Lane, Suite F voice 530.894.8966
 Chico, California 95928 fax 530.894.5143

Report To: ENTEK CONSULTING GROUP
 4200 ROCKLIN ROAD, SUITE 7
 ROCKLIN, CA 95677
Attention: RICHARD BEALL
Project: CHICO STATE LEAD TESTING 17-4612

Lab No: 18A0244
Reported: 01/08/18
Phone: (916) 632-6800
P.O. #

Metals - Total

Analyte	Units	Results	Qualifier	MDL	RL	Method	Analyzed	Prepared	Batch
WHIT-9RR-002 - Grab Drinking Water (18A0244-01)			Sampled:01/04/18 07:43						
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0923	
WHIT-9MB-001 - Grab Drinking Water (18A0244-02)			Sampled:01/04/18 07:46						
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0923	
WHIT-9MB-002 - Grab Drinking Water (18A0244-03)			Sampled:01/04/18 07:46						
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0923	
WHIT-9RR-001 - Grab Drinking Water (18A0244-04)			Sampled:01/04/18 07:54						
Lead	ug/l	5.2		5.0	EPA 200.8	01/07/18	01/07/18	B8A0923	
WHIT-9WB-001 - Grab Drinking Water (18A0244-05)			Sampled:01/04/18 07:57						
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0923	
WHIT-9WB-002 - Grab Drinking Water (18A0244-06)			Sampled:01/04/18 07:57						
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0923	
WHIT-8RR-002 - Grab Drinking Water (18A0244-07)			Sampled:01/04/18 08:03						
Lead	ug/l	5.4		5.0	EPA 200.8	01/07/18	01/07/18	B8A0923	
WHIT-8MB-001 - Grab Drinking Water (18A0244-08)			Sampled:01/04/18 08:05						
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0923	
WHIT-8MB-002 - Grab Drinking Water (18A0244-09)			Sampled:01/04/18 08:05						
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0923	
WHIT-8RR-001 - Grab Drinking Water (18A0244-10)			Sampled:01/04/18 08:13						
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0923	
WHIT-8WB-001 - Grab Drinking Water (18A0244-11)			Sampled:01/04/18 08:21						
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0923	
WHIT-8WB-002 - Grab Drinking Water (18A0244-12)			Sampled:01/04/18 08:21						
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0923	
WHIT-7RR-001 - Grab Drinking Water (18A0244-13)			Sampled:01/04/18 08:30						
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0923	
WHIT-7WB-001 - Grab Drinking Water (18A0244-14)			Sampled:01/04/18 08:32						
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0923	
WHIT-7WB-002 - Grab Drinking Water (18A0244-15)			Sampled:01/04/18 08:32						
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0923	
WHIT-6RR-001 - Grab Drinking Water (18A0244-16)			Sampled:01/04/18 08:47						
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0923	
WHIT-6MB-001 - Grab Drinking Water (18A0244-17)			Sampled:01/04/18 08:49						
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0923	
WHIT-6MB-002 - Grab Drinking Water (18A0244-18)			Sampled:01/04/18 08:49						
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0923	
WHIT-7RR-002 - Grab Drinking Water (18A0244-19)			Sampled:01/04/18 08:37						
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0923	
WHIT-7MB-001 - Grab Drinking Water (18A0244-20)			Sampled:01/04/18 08:41						
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0923	
WHIT-7MB-002 - Grab Drinking Water (18A0244-21)			Sampled:01/04/18 08:41						
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0924	
WHIT-4RR-001 - Grab Drinking Water (18A0244-22)			Sampled:01/04/18 09:30						
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0924	


 Approved By

Basic Laboratory Inc
 California ELAP Cert #1677 and #2718



www.basiclab.com

2218 Railroad Avenue voice 530.243.7234
Redding, California 96001 fax 530.243.7494

3860 Morrow Lane, Suite F voice 530.894.8966
Chico, California 95928 fax 530.894.5143

Report To: ENTEK CONSULTING GROUP
4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677

Attention: RICHARD BEALL
Project: CHICO STATE LEAD TESTING 17-4612

Lab No: 18A0244
Reported: 01/08/18
Phone: (916) 632-6800
P.O. #

Metals - Total

Analyte	Units	Results	Qualifier	MDL	RL	Method	Analyzed	Prepared	Batch
WHIT-4WB-001 - Grab Drinking Water (18A0244-23)			Sampled:01/04/18 09:32				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0924	
WHIT-4WB-002 - Grab Drinking Water (18A0244-24)			Sampled:01/04/18 09:32				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0924	
WHIT-5RR-002 - Grab Drinking Water (18A0244-25)			Sampled:01/04/18 09:15				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0924	
WHIT-5MB-001 - Grab Drinking Water (18A0244-26)			Sampled:01/04/18 09:17				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0924	
WHIT-5MB-002 - Grab Drinking Water (18A0244-27)			Sampled:01/04/18 09:17				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0924	
WHIT-5RR-001 - Grab Drinking Water (18A0244-28)			Sampled:01/04/18 09:09				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0924	
WHIT-5WB-001 - Grab Drinking Water (18A0244-29)			Sampled:01/04/18 09:12				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0924	
WHIT-5WB-002 - Grab Drinking Water (18A0244-30)			Sampled:01/04/18 09:12				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0924	
WHIT-6RR-002 - Grab Drinking Water (18A0244-31)			Sampled:01/04/18 08:54				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0924	
WHIT-6WB-001 - Grab Drinking Water (18A0244-32)			Sampled:01/04/18 08:49				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0924	
WHIT-6WB-002 - Grab Drinking Water (18A0244-33)			Sampled:01/04/18 08:49				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0924	
WHIT-001-001 - Grab Drinking Water (18A0244-34)			Sampled:01/04/18 10:21				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0924	
WHIT-001-002 - Grab Drinking Water (18A0244-35)			Sampled:01/04/18 10:24				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0924	
WHIT-2RR-002 - Grab Drinking Water (18A0244-36)			Sampled:01/04/18 10:04				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0924	
WHIT-2MB-001 - Grab Drinking Water (18A0244-37)			Sampled:01/04/18 10:11				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0924	
WHIT-2MB-002 - Grab Drinking Water (18A0244-38)			Sampled:01/04/18 10:11				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0924	
WHIT-2RR-001 - Grab Drinking Water (18A0244-39)			Sampled:01/04/18 10:04				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0924	
WHIT-2WB-001 - Grab Drinking Water (18A0244-40)			Sampled:01/04/18 10:04				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0924	
WHIT-2WB-002 - Grab Drinking Water (18A0244-41)			Sampled:01/04/18 10:04				Received:01/04/18 12:05		
Lead	ug/l	5.7		5.0	EPA 200.8	01/07/18	01/07/18	B8A0925	
WHIT-3RR-002 - Grab Drinking Water (18A0244-42)			Sampled:01/04/18 09:56				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0925	
WHIT-3WB-001 - Grab Drinking Water (18A0244-43)			Sampled:01/04/18 09:58				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0925	
WHIT-3WB-002 - Grab Drinking Water (18A0244-44)			Sampled:01/04/18 09:58				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0925	

Approved By

Basic Laboratory Inc
California ELAP Cert #1677 and #2718



www.basiclab.com

2218 Railroad Avenue voice 530.243.7234
Redding, California 96001 fax 530.243.7494


3860 Morrow Lane, Suite F voice 530.894.8966
Chico, California 95928 fax 530.894.5143

Report To: ENTEK CONSULTING GROUP
4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
Attention: RICHARD BEALL
Project: CHICO STATE LEAD TESTING 17-4612

Lab No: 18A0244
Reported: 01/08/18
Phone: (916) 632-6800
P.O. #

Metals - Total

Analyte	Units	Results	Qualifier	MDL	RL	Method	Analyzed	Prepared	Batch
WHIT-3RR-001 - Grab Drinking Water (18A0244-45)			Sampled:01/04/18 09:47				Received:01/04/18 12:05		
Lead	ug/l	5.3		5.0	EPA 200.8	01/07/18	01/07/18	B8A0925	
WHIT-3MB-001 - Grab Drinking Water (18A0244-46)			Sampled:01/04/18 09:50				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0925	
WHIT-3MB-002 - Grab Drinking Water (18A0244-47)			Sampled:01/04/18 09:50				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0925	
WHIT-4RR-002 - Grab Drinking Water (18A0244-48)			Sampled:01/04/18 09:38				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0925	
WHIT-4MB-001 - Grab Drinking Water (18A0244-49)			Sampled:01/04/18 09:40				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0925	
WHIT-4MB-002 - Grab Drinking Water (18A0244-50)			Sampled:01/04/18 09:40				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0925	
SUTT-109-005 - Grab Drinking Water (18A0244-51)			Sampled:01/04/18 07:40				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0925	
SUTT-109-006 - Grab Drinking Water (18A0244-52)			Sampled:01/04/18 07:45				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0925	
SUTT-109-003 - Grab Drinking Water (18A0244-53)			Sampled:01/04/18 07:48				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0925	
SUTT-109-002 - Grab Drinking Water (18A0244-54)			Sampled:01/04/18 07:52				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0925	
SUTT-SODA-113-001 - Grab Drinking Water (18A0244-55)			Sampled:01/04/18 08:01				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0925	
SUTT-SODA-110-001 - Grab Drinking Water (18A0244-56)			Sampled:01/04/18 08:06				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0925	
SUTT-107-002 - Grab Drinking Water (18A0244-57)			Sampled:01/04/18 08:14				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0925	
SUTT-107-001 - Grab Drinking Water (18A0244-58)			Sampled:01/04/18 08:17				Received:01/04/18 12:05		
Lead	ug/l	11.2		5.0	EPA 200.8	01/07/18	01/07/18	B8A0925	
SUTT-106-001 - Grab Drinking Water (18A0244-59)			Sampled:01/04/18 08:23				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0925	
SUTT-SODA-101-001 - Grab Drinking Water (18A0244-60)			Sampled:01/04/18 08:29				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0925	
SUTT-BSMT-001 - Grab Drinking Water (18A0244-61)			Sampled:01/04/18 08:38				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0925	
SUTT-HW-241-001 - Grab Drinking Water (18A0244-62)			Sampled:01/04/18 08:50				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0925	
SUTT-HW-241-002 - Grab Drinking Water (18A0244-63)			Sampled:01/04/18 08:55				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0925	
SUTT-HW-241-003 - Grab Drinking Water (18A0244-64)			Sampled:01/04/18 08:58				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0925	
SUTT-HW-208-001 - Grab Drinking Water (18A0244-65)			Sampled:01/04/18 09:06				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0925	
SUTT-HW-208-002 - Grab Drinking Water (18A0244-66)			Sampled:01/04/18 09:08				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0925	


Approved By

Basic Laboratory Inc
California ELAP Cert #1677 and #2718



www.basiclab.com

2218 Railroad Avenue voice 530.243.7234
 Redding, California 96001 fax 530.243.7494

3860 Morrow Lane, Suite F voice 530.894.8966
 Chico, California 95928 fax 530.894.5143

Report To: ENTEK CONSULTING GROUP
 4200 ROCKLIN ROAD, SUITE 7
 ROCKLIN, CA 95677

Attention: RICHARD BEALL

Project: CHICO STATE LEAD TESTING 17-4612

Lab No: 18A0244
Reported: 01/08/18
Phone: (916) 632-6800
P.O. #

Metals - Total

Analyte	Units	Results	Qualifier	MDL	RL	Method	Analyzed	Prepared	Batch
SUTT-HW-208-003 - Grab	Drinking Water	(18A0244-67)	Sampled:01/04/18 09:09				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0926	
SUTT-HW-313-001 - Grab	Drinking Water	(18A0244-68)	Sampled:01/04/18 09:18				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0926	
SUTT-HW-313-002 - Grab	Drinking Water	(18A0244-69)	Sampled:01/04/18 09:20				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0926	
SUTT-HW-313-003 - Grab	Drinking Water	(18A0244-70)	Sampled:01/04/18 09:21				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0926	
SUTT-HW-341-001 - Grab	Drinking Water	(18A0244-71)	Sampled:01/04/18 09:33				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0926	
SUTT-HW-341-002 - Grab	Drinking Water	(18A0244-72)	Sampled:01/04/18 09:35				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0926	
SUTT-HW-341-003 - Grab	Drinking Water	(18A0244-73)	Sampled:01/04/18 09:36				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0926	
SUTT-HW-438-001 - Grab	Drinking Water	(18A0244-74)	Sampled:01/04/18 09:46				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0926	
SUTT-HW-438-002 - Grab	Drinking Water	(18A0244-75)	Sampled:01/04/18 09:48				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0926	
SUTT-HW-438-003 - Grab	Drinking Water	(18A0244-76)	Sampled:01/04/18 09:49				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0926	
SUTT-HW-413-001 - Grab	Drinking Water	(18A0244-77)	Sampled:01/04/18 09:58				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0926	
SUTT-HW-413-002 - Grab	Drinking Water	(18A0244-78)	Sampled:01/04/18 09:59				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0926	
SUTT-HW-413-003 - Grab	Drinking Water	(18A0244-79)	Sampled:01/04/18 10:00				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0926	
SUTT-HW-538-001 - Grab	Drinking Water	(18A0244-80)	Sampled:01/04/18 10:09				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0926	
SUTT-HW-538-002 - Grab	Drinking Water	(18A0244-81)	Sampled:01/04/18 10:10				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0922	
SUTT-HW-538-003 - Grab	Drinking Water	(18A0244-82)	Sampled:01/04/18 10:11				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0922	
SUTT-HW-513-001 - Grab	Drinking Water	(18A0244-83)	Sampled:01/04/18 10:20				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0922	
SUTT-HW-513-002 - Grab	Drinking Water	(18A0244-84)	Sampled:01/04/18 10:21				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0922	
SUTT-HW-513-003 - Grab	Drinking Water	(18A0244-85)	Sampled:01/04/18 10:22				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0922	
SUTT-HW-269-001 - Grab	Drinking Water	(18A0244-86)	Sampled:01/04/18 10:36				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0922	
SUTT-HW-269-002 - Grab	Drinking Water	(18A0244-87)	Sampled:01/04/18 10:37				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0922	
SUTT-HW-269-003 - Grab	Drinking Water	(18A0244-88)	Sampled:01/04/18 10:38				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0922	


 Approved By

Basic Laboratory Inc
 California ELAP Cert #1677 and #2718



www.basiclab.com

2218 Railroad Avenue voice 530.243.7234
Redding, California 96001 fax 530.243.7494

3860 Morrow Lane, Suite F voice 530.894.8966
Chico, California 95928 fax 530.894.5143

Report To: ENTEK CONSULTING GROUP
4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677

Attention: RICHARD BEALL
Project: CHICO STATE LEAD TESTING 17-4612

Lab No: 18A0244
Reported: 01/08/18
Phone: (916) 632-6800
P.O. #

Metals - Total

Analyte	Units	Results	Qualifier	MDL	RL	Method	Analyzed	Prepared	Batch
SUTT-HW-369-001 - Grab	Drinking Water	(18A0244-89)	Sampled:01/04/18 10:57				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0922	
SUTT-HW-369-002 - Grab	Drinking Water	(18A0244-90)	Sampled:01/04/18 10:58				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0922	
SUTT-HW-369-003 - Grab	Drinking Water	(18A0244-91)	Sampled:01/04/18 10:59				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0922	
SUTT-163P-001 - Grab	Drinking Water	(18A0244-92)	Sampled:01/04/18 11:07				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0922	
SUTT-163P-002 - Grab	Drinking Water	(18A0244-93)	Sampled:01/04/18 11:08				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0922	
SUTT-153P-001 - Grab	Drinking Water	(18A0244-94)	Sampled:01/04/18 11:11				Received:01/04/18 12:05		
Lead	ug/l	ND		5.0	EPA 200.8	01/07/18	01/07/18	B8A0922	

Notes and Definitions

- DET Analyte DETECTED
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- dry Sample results reported on a dry weight basis
- RPD Relative Percent Difference
- < Less than reporting limit
- ≤ Less than or equal to reporting limit
- > Greater than reporting limit
- ≥ Greater than or equal to reporting limit
- MDL Method Detection Limit
- RL/ML Minimum Level of Quantitation
- MCL/AL Maximum Contaminant Level/Action Level
- mg/kg Results reported as wet weight
- TTLC Total Threshold Limit Concentration
- STLC Soluble Threshold Limit Concentration
- TCLP Toxicity Characteristic Leachate Procedure
- Note 1 Received Temperature - according to EPA guidelines, samples for most chemistry methods should be held at ≤6 degrees C after collection, including during transportation, unless the time from sampling to delivery is <2 hours. Regulating agencies may invalidate results if temperature requirements are not met.
- Note 2 According to 40 CFR Part 136 Table II, the following tests should be analyzed in the field within 15 minutes of sampling: pH, chlorine, dissolved oxygen, and sulfite.

Approved By

Basic Laboratory Inc
California ELAP Cert #1677 and #2718



18A0244
1

18A0244
1-16-18

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 / 4 / 18

Lab: Basic Laboratory, Inc.
2218 Railroad Avenue
Redding, CA 96001

Basic Laboratory, Inc.
3860 Morrow Lane, # F
Chico, CA 95928

Job Number: 17-4612

Collected by: Rick Beall

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample		Information	
WHIT-9RR-002 Sample Number	<u>1-4-18</u> Date	Building: <u>Whitney Hall</u>	Outlet <u>WC</u>
<u>YRS</u> Initials	<u>0743</u> 24 HR Time COC	Floor: <u>9th</u>	Manufacturer: <u>Haws</u>
		Location: <u>Hall by Mens RR</u>	Filter: <u>Aerator</u>
		Description/Observation/Comments: <u>18.6°</u>	
WHIT-9MB-001 Sample Number	<u>1-4-18</u> Date	Building: <u>Whitney Hall</u>	Outlet <u>BF</u>
<u>RB</u> Initials	<u>0746</u> 24 HR Time COC	Floor: <u>9th</u>	Manufacturer: <u>Delta</u>
		Location: <u>Mens Restroom</u>	Filter: <u>Aerator</u>
		Description/Observation/Comments: <u>18.8°</u>	
WHIT-9MB-002 Sample Number	<u>1-4-18</u> Date	Building: <u>Whitney Hall</u>	Outlet <u>BF</u>
<u>YRS</u> Initials	<u>0746</u> 24 HR Time COC	Floor: <u>9th</u>	Manufacturer: <u>Delta</u>
		Location: <u>Mens Restroom</u>	Filter: <u>Aerator</u>
		Description/Observation/Comments: <u>18.6</u>	
<u>Preserved w/ HAD3 pH < 2 1-4-18 17134</u>			

Verified SS

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: Rick Beall Date: 1 / 4 / 18 Time: 1200 AM/PM

Received by: [Signature] Date: 1 / 4 / 18 Time: 12:05 AM/PM

Received by Lab: Father Thelhelmsen 1-4-18 TW 1-4-18 17:04 TW 1726



18A0244

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 14 18

Lab: Basic Laboratory, Inc. Basic Laboratory, Inc.
2218 Railroad Avenue 3860 Morrow Lane, # F
Redding, CA 96001 Chico, CA 95928

Job Number: 17-4612

Collected by: Rick Beall

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
WHIT-9RR-001 Sample Number <u>yes</u> Initials <u>0754</u> Date <u>1-4-18</u> 24 HR Time COC	Building: <u>Whitney Hall</u> Outlet: <u>WC</u>
	Floor: <u>9th</u> Manufacturer: <u>Unknown</u>
	Location: <u>Hall by Womens RR</u> Filter: Aerator:
	Description/Observation/Comments: <u>18.9^c</u>
WHIT-9WB-001 Sample Number <u>yes</u> Initials <u>0757</u> Date <u>1-4-18</u> 24 HR Time COC	Building: <u>Whitney Hall</u> Outlet: <u>BF</u>
	Floor: <u>9th</u> Manufacturer: <u>Delta</u>
	Location: <u>Womens Restroom</u> Filter: Aerator:
	Description/Observation/Comments: <u>18.8^c</u>
WHIT-9WB-002 Sample Number <u>yes</u> Initials <u>0757</u> Date <u>1-4-18</u> 24 HR Time COC	Building: <u>Whitney Hall</u> Outlet: <u>BF</u>
	Floor: <u>9th</u> Manufacturer: <u>Delta</u>
	Location: <u>Womens Restroom</u> Filter: Aerator:
	Description/Observation/Comments: <u>18.9</u>

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: Rick Beall Date: 1 14 18 Time: 1200 AM/PM

Received by: [Signature] Date: 1 14 18 Time: 12:05 AM/PM

Received By Lab: RLW 1-4-18 1726 1704



18A0244

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 1 4 18

Lab: Basic Laboratory, Inc. Basic Laboratory, Inc.
2218 Railroad Avenue 3860 Morrow Lane, # F
Redding, CA 96001 Chico, CA 95928

Job Number: 17-4612

Collected by: Rick Beall

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
WHIT-8RR-002 Sample Number <u>1-4-18</u> Date <u>YRS</u> Initials <u>0803</u> 24 HR Time COC	Building: <u>Whitney Hall</u> Floor: <u>8th Floor</u> Location: <u>Hallway by Mens RA</u> Description/Observation/Comments: Outlet: <u>WC</u> Manufacturer: <u>Unknown</u> Filter: Aerator: <u>18.9°</u>
-8MB- WHIT-8WB-001 Sample Number <u>1-4-18</u> Date <u>YRS</u> Initials <u>0805</u> 24 HR Time COC	Building: <u>Whitney Hall</u> Floor: <u>8th</u> Location: <u>Mens Restroom</u> Description/Observation/Comments: Outlet: <u>BF</u> Manufacturer: <u>Delta</u> Filter: Aerator: <u>18.4°</u>
WHIT-8MB-002 Sample Number <u>1-4-18</u> Date <u>YRS</u> Initials <u>0805</u> 24 HR Time COC	Building: <u>Whitney Hall</u> Floor: <u>8th</u> Location: <u>Mens Restroom</u> Description/Observation/Comments: Outlet: <u>BF</u> Manufacturer: <u>Delta</u> Filter: Aerator: <u>18.8°</u>

-7

-8

-9

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: Rick Beall Date: 1 1 4 18 Time: 12:00 AM/PM

Received by: J. Hill Date: 1 1 4 18 Time: 12:05 AM/PM

Received By Lab: TW 1-4-18 12:05 1704



18A0244

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 1 4 18

Lab: Basic Laboratory, Inc. Basic Laboratory, Inc.
2218 Railroad Avenue 3860 Morrow Lane, # F
Redding, CA 96001 Chico, CA 95928

Job Number: 17-4612

Collected by: Rick Beall

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
WHIT-8RR-002-001 Sample Number Date <u>1-4-18</u> Initials <u>YS</u> 24 HR Time <u>0813</u> COC	Building: <u>Whitney Hall</u> Floor: <u>8th</u> Location: <u>Hall by Womens RR</u> Description/Observation/Comments: <u>* per email attached</u> Outlet <u>WC</u> Manufacturer: <u>Unknown</u> Filter: Aerator: 19.1°
WHIT-8MB-001 Sample Number Date <u>1-4-18</u> Initials <u>YPS</u> 24 HR Time <u>0821</u> COC	Building: <u>Whitney Hall</u> Floor: <u>8th</u> Location: <u>Womens Restroom</u> Description/Observation/Comments: 19.2° Outlet <u>BF</u> Manufacturer: <u>Delta</u> Filter: Aerator:
WHIT-8WB-002 Sample Number Date <u>1-4-18</u> Initials <u>YPS</u> 24 HR Time <u>0821</u> COC	Building: <u>Whitney Hall</u> Floor: <u>8th</u> Location: <u>Womens</u> Description/Observation/Comments: 18.8° Outlet <u>BF</u> Manufacturer: <u>Delta</u> Filter: Aerator:

-10

-11

-12

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: Rick Beall Date: 1 1 4 18 Time: 1200 AM/PM

Received by: J. Hall Date: 1 1 4 18 Time: 12:05 AM/PM

Received By Lab: TW 1-4-18 1726 1704



18A0244

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 14 18

Lab: Basic Laboratory, Inc. Basic Laboratory, Inc.
2218 Railroad Avenue 3860 Morrow Lane, # F
Redding, CA 96001 Chico, CA 95928

Job Number: 17-4612

Collected by: Rick Beall

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
WHIT-7RR-001 Sample Number <u>1-4-18</u> Date <u>ups</u> Initials <u>0830</u> 24 HR Time COC	Building: <u>Whitney Hall</u> Outlet <u>WC</u>
	Floor: <u>7th</u> Manufacturer: <u>Unknown</u>
	Location: <u>Hall by Womens RR</u> Filter: Aerator:
	Description/Observation/Comments: <u>18.2c</u>
WHIT-7WB-001 Sample Number <u>1-4-18</u> Date <u>ups</u> Initials <u>0832</u> 24 HR Time COC	Building: <u>Whitney Hall</u> Outlet <u>BF</u>
	Floor: <u>7th</u> Manufacturer: <u>Delta</u>
	Location: <u>Womens Restroom</u> Filter: Aerator:
	Description/Observation/Comments: <u>18.9c</u>
WHIT-7WB-002 Sample Number <u>1-4-18</u> Date <u>ups</u> Initials <u>0832</u> 24 HR Time COC	Building: <u>Whitney Hall</u> Outlet <u>BF</u>
	Floor: <u>7th</u> Manufacturer: <u>Delta</u>
	Location: <u>Womens Restroom</u> Filter: Aerator:
	Description/Observation/Comments: <u>18.8c</u>

-B

14

12.7

15

13.7

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: Rick Beall Date: 1 14 18 Time: 1200 AM/PM

Received by: J. L. P. Date: 1 14 18 Time: 12:05 AM/PM

Received By Lab: TW 1-4-18 1726-1704



18A0244

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
 ROCKLIN, CA 95677
 (916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 1 4 18

Lab: Basic Laboratory, Inc. Basic Laboratory, Inc.
 2218 Railroad Avenue 3860 Morrow Lane, # F
 Redding, CA 96001 Chico, CA 95928

Job Number: 17-4612

Collected by: Rick Beall

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
 Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, metzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
WHIT-6RR-001 Sample Number <u>1-4-18</u> Date <u>UPS</u> Initials <u>0847</u> 24 HR Time COC	Building: <u>Whitney Hall</u> Floor: <u>6th</u> Location: <u>Hallway by mens RR</u> Description/Observation/Comments: <u>173</u>
WHIT-6MB-001 Sample Number <u>1-4-18</u> Date <u>UPS</u> Initials <u>0849</u> 24 HR Time COC	Building: <u>Whitney Hall</u> Floor: <u>6th</u> Location: <u>mens Restroom</u> Description/Observation/Comments: <u>152</u>
WHIT-6MB-002 Sample Number <u>1-4-18</u> Date <u>UPS</u> Initials <u>0849</u> 24 HR Time COC	Building: <u>Whitney Hall</u> Floor: <u>6th</u> Location: <u>mens Restroom</u> Description/Observation/Comments: <u>154</u>

-16

-17

-18

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: Rick Beall Date: 1 1 4 18 Time: 1200 AM/PM

Received by: [Signature] Date: 1 1 4 18 Time: 12:05 AM/PM

Received By Lab: TW 1-4-18 17:26 1704



18A0244

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 14 18

Lab: Basic Laboratory, Inc.
2218 Railroad Avenue
Redding, CA 96001

Basic Laboratory, Inc.
3860 Morrow Lane, # F
Chico, CA 95928

Job Number: 17-4612

Collected by: Rick Beall

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample		Information	
WHIT-7RR-002	<u>1-4-18</u>	Building: <u>Whitney Hall</u>	Outlet <u>WC</u>
Sample Number	Date	Floor: <u>7th</u>	Manufacturer: <u>Unknown</u>
<u>hrs</u>	<u>0837</u>	Location: <u>Hallway by Mens RR</u>	Filter: Aerator:
Initials	24 HR Time COC	Description/Observation/Comments:	<u>18.2°</u>
WHIT-7MB-001	<u>1-4-18</u>	Building: <u>Whitney Hall</u>	Outlet <u>BF</u>
Sample Number	Date	Floor: <u>7th</u>	Manufacturer: <u>Delta</u>
<u>hrs</u>	<u>0841</u>	Location: <u>Mens Restroom</u>	Filter: Aerator:
Initials	24 HR Time COC	Description/Observation/Comments:	<u>18.3°</u>
WHIT-7MB-002	<u>1-4-18</u>	Building: <u>Whitney Hall</u>	Outlet <u>BF</u>
Sample Number	Date	Floor: <u>7th</u>	Manufacturer: <u>Delta</u>
<u>hrs</u>	<u>0841</u>	Location: <u>Mens Restroom</u>	Filter: Aerator:
Initials	24 HR Time COC	Description/Observation/Comments:	<u>17.1°</u>

-19

-20

-21

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: Rick Beall Date: 1 14 18 Time: 12:00 AM/PM

Received by: [Signature] Date: 1 14 18 Time: 12:05 AM/PM

Received by Lab: TW 1-4-18 17261704



18A0244

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
 ROCKLIN, CA 95677
 (916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 14 18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
 Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Rick Beall

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
 Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample		Information	
WHIT-4RR-001 Sample Number <u>YRS</u> Initials	<u>1-4-18</u> Date <u>0930</u> 24 HR Time COC	Building: <u>Whitney Hall</u>	Outlet <u>WC</u>
		Floor: <u>4th Floor</u>	Manufacturer: <u>Unknown</u>
		Location: <u>Hallway by Womens RR</u>	Filter: Aerator:
		Description/Observation/Comments: <u>18.8</u>	
WHIT-4WB-001 Sample Number <u>YRS</u> Initials	<u>1-4-18</u> Date <u>0932</u> 24 HR Time COC	Building: <u>Whitney Hall</u>	Outlet <u>BF</u>
		Floor: <u>4th</u>	Manufacturer: <u>Delta</u>
		Location: <u>Womens Restroom</u>	Filter: Aerator:
		Description/Observation/Comments: <u>18.3 TW</u> <u>18.3</u>	
WHIT-4WB-002 Sample Number <u>YRS</u> Initials	<u>1-4-18</u> Date <u>0932</u> 24 HR Time COC	Building: <u>Whitney Hall</u>	Outlet <u>BF</u>
		Floor: <u>4th</u>	Manufacturer: <u>Delta</u>
		Location: <u>Womens Restroom</u>	Filter: Aerator:
		Description/Observation/Comments: <u>14.2</u> <u>13.8</u>	

-22

-23

-24

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: Rick Beall Date: 1 14 18 Time: 1200 AM/PM

Received by: J. P. [Signature] Date: 1 14 18 Time: 12:05 AM/PM

Received by lab [Signature] TW 1-4-18 17:26, 1704



18A0244

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 1 4 /18

Lab: Basic Laboratory, Inc. Basic Laboratory, Inc.
2218 Railroad Avenue 3860 Morrow Lane, # F
Redding, CA 96001 Chico, CA 95928

Job Number: 17-4612

Collected by: Rick Beall

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information	
WHIT-5RR-002 Sample Number <u>YES</u> Initials Date <u>1-4-18</u> <u>0915</u> 24 HR Time COC	Building: <u>Whitney Hall</u>	Outlet <u>WC</u>
	Floor: <u>5th</u>	Manufacturer: <u>Unknown</u>
	Location: <u>Hallway by Mens RR</u>	Filter: Aerator:
	Description/Observation/Comments: <u>17.3C</u>	
WHIT-5MB-001 Sample Number <u>YES</u> Initials Date <u>1-4-18</u> <u>* 9:17</u> 24 HR Time COC	Building: <u>Whitney Hall</u>	Outlet <u>BF</u>
	Floor: <u>5th</u>	Manufacturer: <u>Delta</u>
	Location: <u>Mens Restroom</u>	Filter: Aerator:
	Description/Observation/Comments: <u>18.0C</u> <u>* Per attached email</u> <u>No Time on bottle</u>	
WHIT-5MB-002 Sample Number <u>YES</u> Initials Date <u>1-4-18</u> <u>0917</u> 24 HR Time COC	Building: <u>Whitney Hall</u>	Outlet <u>BF</u>
	Floor: <u>5th</u>	Manufacturer: <u>Delta</u>
	Location: <u>Mens Restroom</u>	Filter: Aerator:
	Description/Observation/Comments: <u>17.5C</u>	

-25

-26

-27

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: Rick Beall Date: 1 1 4 /18 Time: 1200 AM/PM

Received by: J.H.P. Date: 1 1 4 /18 Time: 12:05 AM/PM

Received by Lab: RW 1-4-18 17:00 1704



18A0244

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1/14/18

Lab: Basic Laboratory, Inc. Basic Laboratory, Inc.
2218 Railroad Avenue 3860 Morrow Lane, # F
Redding, CA 96001 Chico, CA 95928

Job Number: 17-4612

Collected by: Rick Beall

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
WHIT-5RR-001 Sample Number <u>YRS</u> Initials <u>1-4-18</u> Date <u>909</u> 24 HR Time COC	Building: <u>Whitney Hall</u> Outlet <u>WC</u>
	Floor: <u>5th</u> Manufacturer: <u>Unknown</u>
	Location: <u>Hallway by Womens RR</u> Filter: Aerator:
	Description/Observation/Comments: <u>18.4</u>
WHIT-5WB-001 Sample Number <u>YRS</u> Initials <u>1-4-18</u> Date <u>0912</u> 24 HR Time COC	Building: <u>Whitney Hall</u> Outlet <u>BF</u>
	Floor: <u>5th</u> Manufacturer: <u>Delta</u>
	Location: <u>Womens Restroom</u> Filter: Aerator:
	Description/Observation/Comments: <u>17.3^c</u>
WHIT-5WB-002 Sample Number <u>YRS</u> Initials <u>1-4-18</u> Date <u>0912</u> 24 HR Time COC	Building: <u>Whitney Hall</u> Outlet <u>BF</u>
	Floor: <u>5th</u> Manufacturer: <u>Delta</u>
	Location: <u>Womens Restroom</u> Filter: Aerator:
	Description/Observation/Comments: <u>18.4</u>

-28

-29

-30

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: Rick Beall Date: 1/14/18 Time: 12:00 AM/PM

Received by: [Signature] Date: 1/14/18 Time: 12:05 AM/PM

Received by lab: TW 1-4-18 17261704



18A0244

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
 ROCKLIN, CA 95677
 (916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 / 4 / 18

Lab: Basic Laboratory, Inc. Basic Laboratory, Inc.
 2218 Railroad Avenue 3860 Morrow Lane, # F
 Redding, CA 96001 Chico, CA 95928

Job Number: 17-4612

Collected by: Rick Beall

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
 Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information	
WHIT-6RR-002 Sample Number <u>YRS</u> Initials Date <u>1-4-18</u> 24 HR Time <u>0854</u> COC	Building: <u>Whitney Hall</u>	Outlet <u>WC</u>
	Floor: <u>6th</u>	Manufacturer: <u>Unknown</u>
	Location: <u>Hall by Womens RR</u>	Filter: Aerator:
	Description/Observation/Comments: <u>16.6°</u>	
^{GWB} WHIT-6MB-001 Sample Number <u>YRS</u> Initials Date <u>1-4-18</u> 24 HR Time <u>0849</u> COC	Building: <u>Whitney Hall</u>	Outlet <u>BF</u>
	Floor: <u>6th</u>	Manufacturer: <u>Delta</u>
	Location: <u>Womens Restroom</u>	Filter: Aerator:
	Description/Observation/Comments: <u>16.6°</u>	
^{GWB} WHIT-6MB-002 Sample Number <u>YRS</u> Initials Date <u>1-4-18</u> 24 HR Time <u>0849</u> COC	Building: <u>Whitney Hall</u>	Outlet <u>BF</u>
	Floor: <u>6th</u>	Manufacturer: <u>Delta</u>
	Location: <u>Womens Restroom</u>	Filter: Aerator:
	Description/Observation/Comments: <u>16.1</u>	

-31

-32

-33

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: Rick Beall Date: 1 / 4 / 18 Time: 12:00 AM/PM

Received by: T. Wilhelmson Date: 1 / 4 / 18 Time: 12:05 AM/PM

Received by: T. Wilhelmson Date: 1-4-18 Time: 17:26 AM/PM 704



18A0244

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
 ROCKLIN, CA 95677
 (916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 14 18

Lab: Basic Laboratory, Inc. Basic Laboratory, Inc.
 2218 Railroad Avenue 3860 Morrow Lane, # F
 Redding, CA 96001 Chico, CA 95928

Job Number: 17-4612

Collected by: Rick Beall

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
 Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, mmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample		Information	
WHIT-001-001 Sample Number Date <u>1-4-18</u> Initials <u>UPES</u> 24 HR Time <u>1021</u> COC		Building: <u>Whitney Hall</u>	Outlet <u>WC</u>
		Floor: <u>Basement</u>	Manufacturer: <u>EIKay</u>
		Location: <u>Hall by Womens RR</u>	Filter: Aerator:
		Description/Observation/Comments: <u>18.0°</u>	
WHIT-001-002 Sample Number Date <u>1-4-18</u> Initials <u>UPES</u> 24 HR Time <u>1024</u> COC		Building: <u>Whitney Hall</u>	Outlet <u>BS</u>
		Floor: <u>Basement</u>	Manufacturer: <u>Fisher</u>
		Location: <u>Hall by Womens RR</u>	Filter: Aerator:
		Description/Observation/Comments: <u>9.1°</u>	
		Building:	Outlet
		Floor:	Manufacturer:
		Location:	Filter: Aerator:
		Description/Observation/Comments:	

-34

-35

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: Rick Beall Date: 1 14 18 Time: 1200 AM/PM

Received by: [Signature] Date: 1 14 18 Time: 12:05 AM/PM

Received by Lab [Signature] 1-4-18 1704



18A0244

ENTEK CONSULTING GROUP, INC.
 4200 ROCKLIN ROAD, SUITE 7
 ROCKLIN, CA 95677
 (916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1/4/18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
 Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Rick Beall

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
 Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
WHIT-2RR-002 Sample Number <u>WPS</u> Initials <u>1-4-18</u> Date <u>1004</u> 24 HR Time COC	Building: <u>Whitney Hall</u> Outlet: <u>WC</u>
	Floor: <u>2nd</u> Manufacturer: <u>Unknown</u>
	Location: <u>Hallway by Mens RR</u> Filter: Aerator:
	Description/Observation/Comments: <u>17.2°</u>
WHIT-2MB-001 Sample Number <u>WPS</u> Initials <u>1-4-18</u> Date <u>1011</u> 24 HR Time COC	Building: <u>Whitney Hall</u> Outlet: <u>BF</u>
	Floor: <u>2nd</u> Manufacturer: <u>Delta</u>
	Location: <u>Mens Restroom</u> Filter: Aerator:
	Description/Observation/Comments: <u>8.9°</u>
WHIT-2MB-002 Sample Number <u>WPS</u> Initials <u>1-4-18</u> Date <u>1011</u> 24 HR Time COC	Building: <u>Whitney Hall</u> Outlet: <u>BF</u>
	Floor: <u>2nd</u> Manufacturer: <u>CFG</u>
	Location: <u>Mens Restroom</u> Filter: Aerator:
	Description/Observation/Comments: <u>7.5°</u>

-36

-37

-38

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: Rick Beall Date: 1/4/18 Time: 1200 AM/PM

Received by: [Signature] Date: 1/4/18 Time: 12:05 AM/PM

Received by Lab: [Signature] TW 1/4/18 1726/1704



18A0244

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
 ROCKLIN, CA 95677
 (916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 14 18

Lab: Basic Laboratory, Inc. Basic Laboratory, Inc.
 2218 Railroad Avenue 3860 Morrow Lane, # F
 Redding, CA 96001 Chico, CA 95928

Job Number: 17-4612

Collected by: Rick Beall

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
 Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information	
WHIT-2RR-001 Sample Number <u>YPS</u> Initials Date <u>1-4-18</u> 24 HR Time <u>1004</u> COC	Building: <u>Whitney Hall</u>	Outlet <u>WC</u>
	Floor: <u>2nd</u>	Manufacturer: <u>Unknown</u>
	Location: <u>Hallway by Womens Rm</u>	Filter: Aerator:
	Description/Observation/Comments: <u>15.3°</u>	
WHIT-2WB-001 Sample Number <u>YPS</u> Initials Date <u>1-4-18</u> 24 HR Time <u>1004</u> COC	Building: <u>Whitney Hall</u>	Outlet <u>BF</u>
	Floor: <u>2nd</u>	Manufacturer:
	Location: <u>Womens Restroom</u>	Filter: Aerator:
	Description/Observation/Comments: <u>8.6°</u>	
WHIT-2WB-002 Sample Number <u>YPS</u> Initials Date <u>1-4-18</u> 24 HR Time <u>1004</u> COC	Building: <u>Whitney Hall</u>	Outlet <u>BF</u>
	Floor: <u>2nd</u>	Manufacturer:
	Location: <u>Womens Restroom</u>	Filter: Aerator:
	Description/Observation/Comments: <u>12.4</u>	

-39

-40

-41

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: Rick Beall Date: 1 14 18 Time: 12:00 AM/PM

Received by: [Signature] Date: 1 14 18 Time: 12:05 AM/PM
Received by [Signature] TW 1-4-18 17:26/1704



18A0244

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 4 18

Lab: Basic Laboratory, Inc. Basic Laboratory, Inc.
2218 Railroad Avenue 3860 Morrow Lane, # F
Redding, CA 96001 Chico, CA 95928

Job Number: 17-4612

Collected by: Rick Beall

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, mmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information	
WHIT-3RR-002 Sample Number <u>1-4-18</u> Date <u>yes</u> Initials <u>0956</u> 24 HR Time COC	Building: <u>Whitney Hall</u>	Outlet <u>WC</u>
	Floor: <u>3rd</u>	Manufacturer: <u>Unknown</u>
	Location: <u>Hallway by Womens RR</u>	Filter: Aerator:
	Description/Observation/Comments: <u>16.6^c</u>	
WHIT-3WB-001 Sample Number <u>1-4-18</u> Date <u>yes</u> Initials <u>0958</u> 24 HR Time COC	Building: <u>Whitney Hall</u>	Outlet <u>BF</u>
	Floor: <u>3rd</u>	Manufacturer:
	Location: <u>Womens RR</u>	Filter: Aerator:
	Description/Observation/Comments: <u>10.9^c</u>	
WHIT-3WB-002 Sample Number <u>1-4-18</u> Date <u>yes</u> Initials <u>0958</u> 24 HR Time COC	Building: <u>Whitney Hall</u>	Outlet <u>BF</u>
	Floor: <u>3rd</u>	Manufacturer:
	Location: <u>Womens Restroom</u>	Filter: Aerator:
	Description/Observation/Comments: <u>17.2</u>	

42

43

44

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: Rick Beall Date: 1 4 18 Time: 12:00 AM/PM

Received by: J.L.P. Date: 1 4 18 Time: 12:05 AM/PM

Received by Lab: TLW 1-4-18 1926 1704



18A0244

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
 ROCKLIN, CA 95677
 (916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 14 18

Lab: Basic Laboratory, Inc. Basic Laboratory, Inc.
 2218 Railroad Avenue 3860 Morrow Lane, # F
 Redding, CA 96001 Chico, CA 95928

Job Number: 17-4612

Collected by: Rick Beall

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
 Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample		Information	
WHIT-3RR-001 Sample Number <u>ys</u> Initials Date <u>1-4-18</u> 24 HR Time <u>0947</u> COC		Building: <u>Whitney Hall</u>	Outlet <u>WC</u>
		Floor: <u>3rd</u>	Manufacturer: <u>unknown</u>
		Location: <u>Hall by Mens RR</u>	Filter: Aerator:
		Description/Observation/Comments: <u>17.2°</u>	
WHIT-3MB-001 Sample Number <u>yes</u> Initials Date <u>1-4-18</u> 24 HR Time <u>0950</u> COC		Building: <u>Whitney Hall</u>	Outlet <u>BF</u>
		Floor: <u>3rd</u>	Manufacturer: <u>Delta</u>
		Location: <u>Mens Restroom</u>	Filter: Aerator:
		Description/Observation/Comments: <u>15.5</u>	
WHIT-3MB-002 Sample Number <u>ups</u> Initials Date <u>1-4-18</u> 24 HR Time <u>0950</u> COC		Building: <u>Whitney Hall</u>	Outlet <u>BF</u>
		Floor: <u>3rd</u>	Manufacturer: <u>Delta</u>
		Location: <u>Mens Restroom</u>	Filter: Aerator:
		Description/Observation/Comments: <u>13.2°</u>	

*Outlet Type: DW = Drinking Water Bubler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: Rick Beall Date: 1 14 18 Time: 1200 AM/PM

Received by: [Signature] Date: 1 14 18 Time: 12:05 AM/PM

Received by: [Signature] Date: 1-4-18 Time: 12:05 PM 704



18A0244

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 / 4 / 18

Lab: Basic Laboratory, Inc. Basic Laboratory, Inc.
2218 Railroad Avenue 3860 Morrow Lane, # F
Redding, CA 96001 Chico, CA 95928

Job Number: 17-4612

Collected by: Rick Beall

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
WHIT-4RR-002 Sample Number Date <u>1-14-18</u> Initials <u>YRS</u> 24 HR Time <u>0938</u> COC	Building: <u>Whitney Hall</u> Outlet <u>WC</u>
	Floor: <u>4th</u> Manufacturer: <u>Unknown</u>
	Location: <u>Hallway by Mens RR</u> Filter: Aerator:
	Description/Observation/Comments: <u>13.6°</u>
WHIT-4MB-001 Sample Number Date <u>1-4-18</u> Initials <u>YRS</u> 24 HR Time <u>0940</u> COC	Building: <u>Whitney Hall</u> Outlet <u>BF</u>
	Floor: <u>4th</u> Manufacturer: <u>Delta</u>
	Location: <u>Mens Restroom</u> Filter: Aerator:
	Description/Observation/Comments: <u>17.4°</u>
WHIT-4MB-002 Sample Number Date <u>1-4-18</u> Initials <u>YRS</u> 24 HR Time <u>0940</u> COC	Building: <u>Whitney Hall</u> Outlet <u>BF</u>
	Floor: <u>4th</u> Manufacturer: <u>Delta</u>
	Location: <u>Mens Restroom</u> Filter: Aerator:
	Description/Observation/Comments: <u>14.2</u>

48

49

50

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: Rick Beall Date: 1 / 4 / 18 Time: 1200 AM/PM

Received by: J. H. P. Date: 1 / 4 / 18 Time: 12:05 AM/PM

Received by: TW 1-4-18 1726-1714

ENTEK CONSULTING GROUP, INC.

 4200 ROCKLIN ROAD, SUITE 7
 ROCKLIN, CA 95677
 (916) 632-6800 PHONE (916) 632-6812 FAX

 Date of Sampling: 01 / 4 / 18

 Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
 Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Ryan Metzen

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

 Site Address: Campus Wide Water Quality Testing for Lead
 Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8
Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample		Information	
SUTT-109-005 Sample Number <u>RM</u> Initials	<u>01-04-18</u> Date <u>07:40</u> 24 HR Time COC	Building: <u>Sutter Dining</u>	*Outlet <u>SINK KF</u>
		Floor: <u>1</u>	Manufacturer: <u>Fisher</u>
		Location: <u>Dining Hall/Kitchen</u>	Filter: Aerator:
		Description/Observation/Comments: <u>Kitchen Area; Prep Sink; Near Walk-in</u>	
SUTT-109-006 Sample Number <u>RM</u> Initials	<u>01-04-18</u> Date <u>07:45</u> 24 HR Time COC	Building: <u>Sutter</u>	*Outlet <u>SINK KF</u>
		Floor: <u>1</u>	Manufacturer: <u>Fisher</u>
		Location: <u>Dining Hall/Kitchen</u>	Filter: Aerator:
		Description/Observation/Comments: <u>Kitchen Area; Prep Sink</u>	
SUTT-109-003 Sample Number <u>RM</u> Initials	<u>1-4-18</u> Date <u>07:48</u> 24 HR Time COC	Building: <u>Sutter</u>	*Outlet <u>SINK/Pot Filler^{KF}</u>
		Floor: <u>1</u>	Manufacturer: <u>UNKNOWN</u>
		Location: <u>Dining Hall/Kitchen</u>	Filter: Aerator:
		Description/Observation/Comments: <u>Kitchen Area; Pot Filler</u>	

-51

-52

-53

Verified ST

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

 Delivered by: Ryan Metzen Date: 1 / 4 / 18 Time: 12:00 AM/PM

 Received by: [Signature] Date: 1 / 4 / 18 Time: 12:05 AM/PM

 Received By Lab: TBW 726 1704



18A0244

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 / 4 / 18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Ryan Metzger

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample		Information	
SUTT-109-002	<u>1-4-18</u>	Building: <u>SUTHER</u>	*Outlet <u>Sink/Pot Filter</u> ^{KF}
Sample Number	Date	Floor: <u>1</u>	Manufacturer: <u>Unknown</u>
<u>RM</u>	<u>07:52</u>	Location: <u>Dining Hall/Kitchen</u>	Filter: <u>Aerator</u>
Initials	24 HR Time	Description/Observation/Comments: <u>Kitchen Area; Pot Filter; new walk-in</u> <u>17.4</u>	
	COC		
SUTT-SODA- 127 113-001	<u>1-4-18</u>	Building: <u>SUTHER</u>	*Outlet <u>Soda Machine/IM</u>
Sample Number	Date	Floor: <u>1</u>	Manufacturer: <u>Cornelius</u>
<u>RM</u>	<u>08:01</u>	Location: <u>Dining Hall</u>	Filter: <u>Aerator</u>
Initials	24 HR Time	Description/Observation/Comments: <u>Soda Machine; Dining Hall; Water Dispenser</u> <u>14.8°</u>	
	COC		
SUTT-Soda-110-01	1-4-18	Building: <u>SUTHER</u>	*Outlet <u>Soda Machine/IM</u>
Sample Number	Date	Floor: <u>1</u>	Manufacturer: <u>Cornelius</u>
<u>RM</u>	<u>06:06</u>	Location: <u>Dining Hall</u>	Filter: <u>Aerator</u>
Initials	24 HR Time	Description/Observation/Comments: <u>Soda machine; new main stage</u> <u>17.8°</u>	
	COC		

*Outlet Type: DW = Drinking Water bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1 / 4 / 18 Time: 12:00 AM/PM

Received by: [Signature] Date: 1 / 4 / 18 Time: 12:05 AM/PM

Revised Box Labels TW 1-4-18 1726 1704



18 A0244

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 / 4 / 18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Ryan Metzen

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
SUTT-106-002 Sample Number RM Initials <u>1-4-18</u> Date <u>08:14</u> 24 HR Time COC	Building: <u>Sutter</u> *Outlet <u>Sink KF</u> Floor: <u>1</u> Manufacturer: <u>Fisher</u> Location: <u>Dining Hall/Kitchen</u> Filter: <u>Aerator</u> Description/Observation/Comments: <u>Prep Sink; Kitchen</u> <u>16.9°C</u>
SUTT-107-001 Sample Number RM Initials <u>1-4-18</u> Date <u>08:17</u> 24 HR Time COC	Building: <u>Sutter</u> *Outlet <u>Sink KF</u> Floor: <u>Dining Hall/Kitchen</u> Manufacturer: <u>Fisher</u> Location: <u>Dining Hall/Kitchen</u> Filter: <u>Aerator</u> Description/Observation/Comments: <u>Quinoa cooker</u> <u>16.3°C</u>
SUTT-106-001 Sample Number RM Initials <u>1-4-18</u> Date <u>08:23</u> 24 HR Time COC	Building: <u>Sutter</u> *Outlet <u>Sink KF</u> Floor: <u>1</u> Manufacturer: <u>T&S</u> Location: <u>Dining Hall/Kitchen</u> Filter: <u>Aerator</u> Description/Observation/Comments: <u>Paste cooker; Food Y Area</u> <u>18.1°C</u>

-57

-58

-59

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1 / 4 / 18 Time: 12:00 AM/PM
 Received by: [Signature] Date: 1 / 4 / 18 Time: 12:05 AM/PM

Received By Lab: TRW 1-4-18 1726, 1704



18A0244

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 / 4 / 18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Ryan Metzen

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
SUT-SODA-101-001 1-4-18 Sample Number Date RM 08:24 Initials 24 HR Time COC	Building: SUTHER
	*Outlet Soda Machine/IM
	Floor: 1
	Manufacturer: Carnelios
	Location: Dining Hall
	Filter: Aerator:
	Description/Observation/Comments: Soda machine; SUTHER case sign 16.3°
SUTT-BSMT-001 1-4-18 Sample Number Date RM 08:38 Initials 24 HR Time COC	Building: SUTHER
	*Outlet KF
	Floor: Basement
	Manufacturer: Delta
	Location: Break Room
	Filter: Aerator:
	Description/Observation/Comments: Potential Aerosol 16.1°
SUTT-HW-241-001 1-4-18 Sample Number Date RM 08:50 Initials 24 HR Time COC	Building: SUTHER
	*Outlet WC
	Floor: 2
	Manufacturer: Elkay
	Location: 241N LAUNDRY HALLWAY
	Filter: Aerator:
	Description/Observation/Comments: Chilled water cooler; LO; 241 Hallway near Laundry 241N 14.3°

-60

-61

-62

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: Ryan Metzen Date: 1 / 4 / 18 Time: 12:00 AM/PM

Received by: [Signature] Date: 1 / 4 / 18 Time: 12:05 AM/PM

Received by Lab: RLW 1-4-18 1726 1704



18A0244

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 / 4 / 18

Lab: Basic Laboratory, Inc. Basic Laboratory, Inc.
2218 Railroad Avenue 3860 Morrow Lane, # F
Redding, CA 96001 Chico, CA 95928

Job Number: 17-4612

Collected by: Ryan Metzen

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
SUTT-HW-241-002 Sample Number <u>1-4-18</u> Date <u>BM</u> Initials <u>08:55</u> 24 HR Time COC BOTTLE	Building: <u>SUTHER</u> *Outlet <u>WC</u>
	Floor: <u>2</u> Manufacturer: <u>ELKAY</u>
	Location: <u>241W LAUNDRY Hallway</u> Filter: Aerator:
	Description/Observation/Comments: <u>13.8°</u> <u>Hi</u>
SUTT-HW-241-003 Sample Number <u>1-4-18</u> Date <u>BM</u> Initials <u>08:58</u> 24 HR Time COC	Building: <u>SUTHER</u> *Outlet <u>BS</u>
	Floor: <u>2</u> Manufacturer: <u>ELKAY</u>
	Location: <u>241W LAUNDRY Hallway</u> Filter: Aerator:
	Description/Observation/Comments: <u>15.8°</u> <u>Bottle Filter</u>
SUTT-HW-208-001 Sample Number <u>1-4-18</u> Date <u>BM</u> Initials <u>09:06</u> 24 HR Time COC	Building: <u>SUTHER</u> *Outlet <u>WC</u>
	Floor: <u>2</u> Manufacturer: <u>ELKAY</u>
	Location: <u>208 Custodial Hallway</u> Filter: Aerator:
	Description/Observation/Comments: <u>14.1</u>

-63

-64

-65

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1 / 4 / 18 Time: 12:00 AM/PM

Received by: [Signature] Date: 1 / 4 / 18 Time: 12:06 AM/PM

Received by Lab: [Signature] TLW 1-4-18 47.260 / 704



ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

18A022

Date of Sampling: 1 / 4 / 18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Ryan Metzger

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
SUTT-HW-208-002 Sample Number <u>RM</u> Initials Date <u>1-4-18</u> <u>09:08</u> 24 HR Time COC	Building: <u>Sutter</u> *Outlet <u>WC</u>
	Floor: <u>2</u> Manufacturer: <u>Elmex</u>
	Location: <u>208 custodial hallway N</u> Filter: Aerator:
	Description/Observation/Comments: <u>Hi</u> <u>16.8°</u>
SUTT-HW-208-003 Sample Number <u>RM</u> Initials Date <u>1-4-18</u> <u>09:09</u> 24 HR Time COC	Building: <u>Sutter</u> *Outlet <u>BS</u>
	Floor: <u>2</u> Manufacturer: <u>Elmex</u>
	Location: <u>208 custodial hallway N</u> Filter: Aerator:
	Description/Observation/Comments: <u>Bottle Filler</u> <u>15.9°</u>
SUTT-HW-313-001 Sample Number <u>RM</u> Initials Date <u>1-4-18</u> <u>09:18</u> 24 HR Time COC	Building: <u>Sutter</u> *Outlet <u>WC</u>
	Floor: <u>3</u> Manufacturer: <u>Elmex</u>
	Location: <u>Access from Room 313 N</u> Filter: Aerator:
	Description/Observation/Comments: <u>Low</u> <u>14.6°</u>

-66

-67

-68

*Outlet Type:

DW = Drinking Water Bubbler
CF = Classroom Faucet
CM = Coffee Machine

WC = Water Cooler
KF = Kitchen Faucet
GF = Glass Filler

BS = Bottle Filling Station
BF = Bathroom Faucet

WD = Water Dispenser
IM = Ice Maker

Delivered by: [Signature]

Date: 1 / 4 / 18

Time: 12:00 AM (PM)

Received by: [Signature]

Date: 1 / 4 / 18

Time: 12:07 AM (PM)

Received By Lab: TW

1-4-18 1726 (2) 704



18A0244

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
 ROCKLIN, CA 95677
 (916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 / 4 / 18

Lab: Basic Laboratory, Inc. Basic Laboratory, Inc.
 2218 Railroad Avenue 3860 Morrow Lane, # F
 Redding, CA 96001 Chico, CA 95928

Job Number: 17-4612

Collected by: Ryan Metzger

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
 Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information	
SUTT-HW-313-002 Sample Number <u>1-4-18</u> Date RM Initials <u>09:20</u> 24 HR Time COC	Building: Sutter	*Outlet WC
	Floor: 3	Manufacturer: Elkay
	Location: Across from Room 313 N	Filter: Aerator:
	Description/Observation/Comments: High 151°	
SUTT-HW-313-003 Sample Number <u>1-4-18</u> Date RM Initials <u>09:21</u> 24 HR Time COC	Building: Sutter	*Outlet BS
	Floor: 3	Manufacturer: Elkay
	Location: Across from Room 313 N	Filter: Aerator:
	Description/Observation/Comments: Bottle Filler 13.8°	
SUTT-HW-341-001 Sample Number <u>1-4-18</u> Date RM Initials <u>09:33</u> 24 HR Time COC	Building: Sutter	*Outlet WC
	Floor: 3	Manufacturer: Elkay
	Location: 341 N LAUNDRY ROOM	Filter: Aerator:
	Description/Observation/Comments: 14.1°	

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1 / 4 / 18 Time: 12:00 AM/PM

Received by: [Signature] Date: 1 / 4 / 18 Time: 12:07 AM/PM

Received By (Lab): TLW 17-261704



18A0244

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
 ROCKLIN, CA 95677
 (916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 / 4 / 18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
 Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Ryan Metzen

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
 Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
SUTT-HW-341-002 Sample Number <u>RM</u> Initials Date: <u>1-4-18</u> 24 HR Time: <u>09:35</u> COC	Building: <u>SUTHER</u> Floor: <u>3</u> Location: <u>341 W Laundry Room</u> Description/Observation/Comments: <u>High</u> *Outlet <u>WC</u> Manufacturer: <u>Elkay</u> Filter: Aerator: <u>14.5°</u>
SUTT-HW-341-003 Sample Number <u>RM</u> Initials Date: <u>1-4-18</u> 24 HR Time: <u>09:36</u> COC	Building: <u>SUTHER</u> Floor: <u>3</u> Location: <u>341 N Laundry Room</u> Description/Observation/Comments: <u>Bottle Filter</u> *Outlet <u>BS</u> Manufacturer: <u>Elkay</u> Filter: Aerator: <u>14.6°</u>
SUTT-HW- 300 -001 Sample Number <u>RM</u> Initials Date: <u>1-4-18</u> 24 HR Time: <u>09:46</u> COC	Building: <u>SUTHER</u> Floor: <u>4</u> Location: <u>438 W LAUNDRY</u> Description/Observation/Comments: <u>Low</u> *Outlet <u>WC</u> Manufacturer: <u>Elkay</u> Filter: Aerator: <u>14.4°</u>

-72

-73

-74

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: Ryan Metzen Date: 1 / 4 / 18 Time: 12:00 AM/PM

Received by: [Signature] Date: 1 / 4 / 18 Time: 12:07 AM/PM

Received By Lab: [Signature] TLW 1-4-18 1726 1704



18A0244

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 / 4 / 18

Lab: Basic Laboratory, Inc. Basic Laboratory, Inc.
2218 Railroad Avenue 3860 Morrow Lane, # F
Redding, CA 96001 Chico, CA 95928

Job Number: 17-4612

Collected by: Ryan Metzen

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information	
<p>938 SUTT-HW-369-002 Sample Number <u>1-4-18</u> Date EM <u>09:48</u> Initials 24 HR Time COC</p>	Building: <u>Sutter</u>	*Outlet <u>WC</u>
	Floor: <u>4</u>	Manufacturer: <u>Elkay</u>
	Location: <u>4138 N Laundry</u>	Filter: Aerator:
	Description/Observation/Comments: <u>High</u> <u>14.4°</u>	
<p>938 SUTT-HW-369-003 Sample Number <u>1-4-18</u> Date EM <u>09:49</u> Initials 24 HR Time COC</p>	Building: <u>Sutter</u>	*Outlet <u>BS</u>
	Floor: <u>4</u>	Manufacturer: <u>Elkay</u>
	Location: <u>438 N LAUNDRY</u>	Filter: Aerator:
	Description/Observation/Comments: <u>Bottle Filler</u> <u>14.2°</u>	
<p>SUTT-HW-413-001 <u>1-4-18</u> Sample Number Date RM <u>09:58</u> Initials 24 HR Time COC</p>	Building: <u>Sutter</u>	*Outlet <u>WC</u>
	Floor: <u>4</u>	Manufacturer: <u>Elkay</u>
	Location: <u>413 N Across from 413 N</u>	Filter: Aerator:
	Description/Observation/Comments: <u>14.4°</u>	

-75

-76

-77

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1 / 4 / 18 Time: 12:00 AM/PM

Received by: [Signature] Date: 1 / 4 / 18 Time: 12:10 AM/PM

received by lab

TW

1726 1704



18A0244

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 / 4 / 18

Lab: Basic Laboratory, Inc. Basic Laboratory, Inc.
2218 Railroad Avenue 3860 Morrow Lane, # F
Redding, CA 96001 Chico, CA 95928

Job Number: 17-4612

Collected by: Ryan Metzen

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and pperelli@csuchico.edu

Place Label for Each Sample	Information	
SUTT-HW-413-002 Sample Number <u>1-4-18</u> Date <u>RM</u> Initials <u>09:59</u> 24 HR Time COC	Building: <u>SUTHER</u>	*Outlet <u>WC</u>
	Floor: <u>4</u>	Manufacturer: <u>EIKing</u>
	Location: <u>Across from 413 N</u>	Filter: Aerator:
	Description/Observation/Comments: <u>16.7°</u>	
SUTT-HW-413-003 Sample Number <u>1-4-18</u> Date <u>RM</u> Initials <u>10:00</u> 24 HR Time COC	Building: <u>SUTHER</u>	*Outlet <u>BS</u>
	Floor: <u>4</u>	Manufacturer: <u>EIKing</u>
	Location: <u>Across from 413 N</u>	Filter: Aerator:
	Description/Observation/Comments: <u>14.6°</u>	
SUTT-HW-538-001 Sample Number <u>1-4-18</u> Date <u>RM</u> Initials <u>10:09</u> 24 HR Time COC	Building: <u>SUTHER</u>	*Outlet <u>WC</u>
	Floor: <u>5</u>	Manufacturer: <u>EIKing</u>
	Location: <u>538 N Laundry Room</u>	Filter: Aerator:
	Description/Observation/Comments: <u>13.7°</u>	

-78

-79

-80

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1 / 4 / 18 Time: 12:00 AM/PM

Received by: [Signature] Date: 1 / 4 / 18 Time: 12:10 AM/PM

Received by Lab: TLW 1-4-18 192(m) 704



18A0244

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 / 4 / 18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Ryan Metzen

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample		Information	
SUTT-HW-538-002 Sample Number <u>RM</u> Initials	<u>1-4-18</u> Date <u>10:16</u> 24 HR Time COC	Building: <u>Sutter</u>	*Outlet <u>WC</u>
		Floor: <u>5</u>	Manufacturer: <u>Elkay</u>
		Location: <u>538N Laundry Room</u>	Filter: <u>Aerator</u>
		Description/Observation/Comments: <u>14.2°</u>	
SUTT-HW-538-003 Sample Number <u>RM</u> Initials	<u>1-4-18</u> Date <u>10:11</u> 24 HR Time COC	Building: <u>Sutter</u>	*Outlet <u>BS</u>
		Floor: <u>5</u>	Manufacturer: <u>Elkay</u>
		Location: <u>538N Laundry Room</u>	Filter: <u>Aerator</u>
		Description/Observation/Comments: <u>14.5°</u>	
SUTT-HW-513-001 Sample Number <u>RM</u> Initials	<u>1-4-18</u> Date <u>10:20</u> 24 HR Time COC	Building: <u>Sutter</u>	*Outlet <u>WC</u>
		Floor: <u>5</u>	Manufacturer: <u>Elkay</u>
		Location: <u>513 N Hallway</u>	Filter: <u>Aerator</u>
		Description/Observation/Comments: <u>13.9°</u>	

81

82

83

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1 / 4 / 18 Time: 12:00 AM/PM

Received by: [Signature] Date: 1 / 4 / 18 Time: 12:10 AM/PM

Received at Lab: TW 1-4-18 1726/704



13A0244

ENTEK CONSULTING GROUP, INC.
4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 / 4 / 18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Ryan Metzen

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
SUTT-HW-513-002 Sample Number <u>1-4-18</u> Date <u>RM</u> <u>10:21</u> Initials 24 HR Time COC	Building: <u>Sutter</u> *Outlet <u>WC</u>
	Floor: <u>5</u> Manufacturer: <u>Elkay</u>
	Location: <u>513 N Hallway</u> Filter: Aerator:
	Description/Observation/Comments: <u>14.3°</u>
SUTT-HW-513-003 Sample Number <u>1-4-18</u> Date <u>RM</u> <u>10:22</u> Initials 24 HR Time COC	Building: <u>Sutter</u> *Outlet <u>BS</u>
	Floor: <u>5</u> Manufacturer: <u>Elkay</u>
	Location: <u>513 W Hallway</u> Filter: Aerator:
	Description/Observation/Comments: <u>14.4°</u>
SUTT-HW-269-001 Sample Number <u>1-4-18</u> Date <u>RM</u> <u>10:36</u> Initials 24 HR Time COC	Building: <u>Sutter</u> *Outlet <u>WC</u>
	Floor: <u>2</u> Manufacturer: <u>Elkay</u>
	Location: <u>Next 269 S Laundry</u> Filter: Aerator:
	Description/Observation/Comments: <u>15.2°</u>

84

85

86

*Outlet Type: DW = Drinking Water bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: [Signature] Date: 1 / 4 / 18 Time: 12:00 AM/PM

Received by: [Signature] Date: 1 / 4 / 18 Time: 12:10 AM/PM

Received by: [Signature] Date: 1-4-18 Time: 12:10 PM



18A0244

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
 ROCKLIN, CA 95677
 (916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 / 4 / 18

Lab: Basic Laboratory, Inc. 2218 Railroad Avenue Redding, CA 96001
 Basic Laboratory, Inc. 3860 Morrow Lane, # F Chico, CA 95928

Job Number: 17-4612

Collected by: Ryan Metzen

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
 Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
SUTT-HW-269-002 Sample Number <u>RM</u> Initials Date <u>1-4-18</u> 24 HR Time <u>10:37</u> COC	Building: <u>SUTCV</u> *Outlet <u>WC</u>
	Floor: <u>2 South</u> Manufacturer: <u>Elkay</u>
	Location: <u>South wing 269 Laundry Room</u> Filter: <u>Aerator</u>
	Description/Observation/Comments: <u>High 13.6°</u>
SUTT-HW-269-003 Sample Number <u>RM</u> Initials Date <u>1-4-18</u> 24 HR Time <u>10:38</u> COC	Building: <u>SUTCV</u> *Outlet <u>BS</u>
	Floor: <u>2 South</u> Manufacturer: <u>Elkay</u>
	Location: <u>South wing 269 Laundry Room</u> Filter: <u>Aerator</u>
	Description/Observation/Comments: <u>Bottle Filler 13.4°</u>
SUTT-HW- 438 -001 Sample Number <u>RM</u> Initials Date <u>1-4-18</u> 24 HR Time <u>10:57</u> COC	Building: <u>SUTCV</u> *Outlet <u>WC</u>
	Floor: <u>3</u> Manufacturer: <u>Elkay</u>
	Location: <u>369 S Laundry Room</u> Filter: <u>Aerator</u>
	Description/Observation/Comments: <u>13.4°</u>

87

88

89

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: Ryan Metzen Date: 1 / 4 / 18 Time: 12:00 AM/PM

Received by: [Signature] Date: 1 / 4 / 18 Time: 12:10 AM/PM

Received By Lab's TLW 1-4-18 12:10 1704



18A0244

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1 / 4 / 18

Lab: Basic Laboratory, Inc. Basic Laboratory, Inc.
2218 Railroad Avenue 3860 Morrow Lane, # F
Redding, CA 96001 Chico, CA 95928

Job Number: 17-4612

Collected by: Ryan Metzen

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information
<p>³⁶⁹ SUTT-HW-438-002 <u>1-4-18</u> Sample Number Date <u>RM</u> <u>10:58</u> Initials 24 HR Time COC</p>	<p>Building: <u>SUTHER</u> *Outlet <u>WC</u> Floor: <u>3 South</u> Manufacturer: <u>Elkay</u> Location: <u>369S Laundry</u> Filter: Aerator: Description/Observation/Comments: <u>12.8°</u></p>
<p>³⁶⁹ SUTT-HW-438-003 <u>1-4-18</u> Sample Number Date <u>RM</u> <u>10:59</u> Initials 24 HR Time COC</p>	<p>Building: *Outlet <u>BS</u> Floor: <u>3 South</u> Manufacturer: <u>Elkay</u> Location: <u>369S Laundry</u> Filter: Aerator: Description/Observation/Comments: <u>11.0°</u></p>
<p>SUTT-163P-001 <u>1-4-18</u> Sample Number Date <u>RM</u> <u>11:07</u> Initials 24 HR Time COC</p>	<p>Building: <u>SUTHER</u> *Outlet <u>WC</u> Floor: <u>1</u> Manufacturer: <u>Elkay</u> Location: <u>New 163P Custodian Room</u> Filter: Aerator: Description/Observation/Comments: <u>Low</u> <u>12.1°</u></p>

90

91

92

*Outlet Type: DW = Drinking Water Bubbler WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
CM = Coffee Machine GF = Glass Filler

Delivered by: Ryan Metzen Date: 1 / 4 / 18 Time: 12:00 AM/PM

Received by: Jill P. Date: 1 / 4 / 18 Time: 12:10 AM/PM

Received Bulab: TLW 1-4-18 17261704



13A0244

ENTEK CONSULTING GROUP, INC.

4200 ROCKLIN ROAD, SUITE 7
ROCKLIN, CA 95677
(916) 632-6800 PHONE (916) 632-6812 FAX

Date of Sampling: 1/4/18

Lab: Basic Laboratory, Inc. Basic Laboratory, Inc.
2218 Railroad Avenue 3860 Morrow Lane, # F
Redding, CA 96001 Chico, CA 95928

Job Number: 17-4612

Collected by: Ryan Metzen

Client Name: California State University, Chico

Turnaround Time: 8-10 Day

Site Address: Campus Wide Water Quality Testing for Lead
Chico, California

ANALYSIS REQUESTED: Lead in Water by EPA 200.8

Special Instruction: Please e-mail results as soon as available and include copy of submittal with those results to mainoffice@entekgroup.com, rbeall@entekgroup.com, rmetzen@entekgroup.com, mpratt@csuchico.edu and rperrelli@csuchico.edu

Place Label for Each Sample	Information	
SUTT-163P-002 Sample Number <u>RM</u> Initials Date <u>1-4-18</u> <u>11:08</u> 24 HR Time COC	Building: <u>Sutter</u>	*Outlet <u>WC</u>
	Floor: <u>1</u>	Manufacturer: <u>Elway</u>
	Location: <u>Near Room 163P Custodian Room</u>	Filter: Aerator:
	Description/Observation/Comments: <u>High 12.5°</u>	
SUTT-153P-001 Sample Number <u>RM</u> Initials Date <u>1-4-18</u> <u>11:11</u> 24 HR Time COC	Building: <u>Sutter</u>	*Outlet <u>KF</u>
	Floor: <u>1</u>	Manufacturer: <u>Unknown</u>
	Location: <u>Room 153P Telecom</u>	Filter: Aerator:
	Description/Observation/Comments: <u>12.1°</u>	
	Building:	*Outlet
	Floor:	Manufacturer:
	Location:	Filter: Aerator:
	Description/Observation/Comments:	

93

94

Z:\Clients\Chico State\17-4612 Campus Wide Water Testing - Lead\Water COC & Forms\Water Request Ryan.wpd

*Outlet Type: DW = Drinking Water Bubblers WC = Water Cooler BS = Bottle Filling Station WD = Water Dispenser
 CF = Classroom Faucet KF = Kitchen Faucet BF = Bathroom Faucet IM = Ice Maker
 CM = Coffee Machine GF = Glass Filler

Delivered by: Rperrelli Date: 1/4/18 Time: 12:00 AM/PM

Received by: [Signature] Date: 1/4/18 Time: 12:10 AM/PM

Received by: [Signature] TRW 1-4-18 +726 1704

TerriLynn Wilhelmson

From: Richard Beall <rbeall@entekgroup.com>
Sent: Sunday, January 07, 2018 1:48 PM
To: TerriLynn Wilhelmson
Subject: RE: BASIC LABORATORY 18A0244

TerriLynn,

Answers in **Red** below after each questions.

Let us hope our documentation is a little cleaner in the next two weeks.

Thanks again.

Rick Beall, CIH, CSP
President
Entek Consulting Group, Inc.
4200 Rocklin Road, Suite 7
Rocklin, CA 95677
(916) 632-6800 office
(916) 632-6812 fax
(916) 417-5276 cell
rbeall@entekgroup.com
www.entekgroup.com

From: TerriLynn Wilhelmson [<mailto:twilhelmson@basiclab.com>]
Sent: Friday, January 05, 2018 8:47 AM
To: Richard Beall
Subject: BASIC LABORATORY 18A0244

Hi Rick,

I have a few questions and I have attached a picture to verify. There are two sample ID's with ...WHIT-8RR-002 time was 08:03 , the first one (sample ID 7) was written over on the paper work, the second one was printed 002 and the time was 813. I have a bottle for both. The second one (sample ID 10) the sample ID on the bottle ends with 001 and the time matches. Do you want me to change sample ID 10 to 001 to match the bottle? Yes, the COC should have been -001

Next, on sample 17 & 18 The sample ID's says 6MB.... But the bottle says 6WB.... Which should it be. MB or WB? Both should be 6MB, (which is consistent with the collection of the Men's Hallway sample 2 minutes earlier at 0847).

Finally, on sample 26, ID WHIT-5MB-001 there is no time on the paper work or the bottle. Do you have a record of the time? 0917 (same time collected concurrently as sample -002 in the same bathroom).

I have attached a copy of our chain of custody and a photo of the bottles for you to see.