

# California State University, Chico



## ADDENDUM #1

Addendum Date: May 13, 2021

### REQUEST FOR QUALIFICATIONS

FOR

Engineered Arc Flash Study

RFQ2021-01MM

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents and any previous Addenda. The Bidder shall acknowledge his/her acceptance of this addendum by writing its number designation on the SOQ Cover Letter. Failure to do so may subject Bidder to disqualification. In case of conflict between Bidding Documents and this Addendum, this Addendum shall govern.

**STATEMENT OF QUALIFICATIONS DUE:**

**May 19, 2021 BY 3:00PM**

### Revisions

#### MODIFICATIONS TO REQUEST FOR QUALIFICATIONS

The University is providing the following clarifications or revisions based on questions from proposers.

1. Question:

Regarding Section 8, #5 - Safety

This section references a request to complete an Infrared Inspection on the equipment. Our concern is if there are items labeled from a previous arc flash as  $>40$  cal/cm<sup>2</sup> or even Dangerous. These items cannot be inspected while energized and we would like to know what the plans are for this equipment  $>40$  cal/cm<sup>2</sup>?

**Answer:**

**IR scan will not be required for items labeled from a previous arc flash as  $>40$  cal/cm<sup>2</sup> or even Dangerous IF items do not have IR windows.**

**IR windows are installed at new Main Switchgear.**

---

All other terms, conditions, and provisions of the original #RFQ2021-01MM shall remain the same.

DATE: May 13, 2021

*University File Copy Signed*

Michael McNair  
Contracts Coordinator  
Procurement and Contract Services